

Australian Standard[®]

**Electric cables—Polymeric
insulated**

**Part 1: For working voltages
1.9/3.3 (3.6) kV up to and
including 19/33 (36) kV**

This Australian Standard was prepared by Committee EL/3, Electric Wires and Cables. It was approved on behalf of the Council of Standards Australia on 31 August 1993 and published on 20 December 1993.

The following interests are represented on Committee EL/3:

Australian Electrical and Electronic Manufacturers Association
Department of Defence
Electrical regulatory authorities
Electricity Supply Association of Australia
Office of Energy, N.S.W.
Railways of Australia Committee
Testing interests

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 92043.

Australian Standard[®]

**Electric cables—Polymeric
insulated**

**Part 1: For working voltages
1.9/3.3 (3.6) kV up to and
including 19/33 (36) kV**

First published as AS 1429.1 — 1979.
Revised and redesignated AS 1429 — 1985.
Revised and redesignated AS 1429.1 — 1993.

Incorporating:
Amdt 1—1995

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 8567 6

PREFACE

This Standard was prepared by the Standards Australia Committee on Electric Wires and Cables to supersede AS 1429—1985, *Polymeric insulated cables for electricity supply at working voltages 1.9/3.3 kV up to and including 19/33 kV*.

In the Standard, Sections 1 to 3 cover the general requirements for cables with individually or collectively screened cores, Section 4 requirements are specific to cables with individually screened cores, and Section 5 requirements are specific to three-core cables with collectively screened cores.

This revised Standard differs from the previous edition in the following significant ways:

- (a) The low density polyethylene insulation, the conductor and insulation thermoplastic screens, and the 75°C rated PVC sheath have been deleted.
- (b) More detailed requirements and recommendations are specified for the (metallic) individual or collective screens. Copper tape screens have been deleted.
- (c) Provision (optional) has been made for the water-blocking of single-core cables, for protection from boring insects, and for the metre marking of cables.
- (d) Some changes have been made to cable tests and criteria.
- (e) Requirements for high voltage d.c. test after installation have been deleted.
- (f) The Standard now includes all the necessary data for determining the dimensions of protective coverings, and test requirements have been combined into one table.

In the preparation of this Standard, consideration was given to the following publications and acknowledgment is made of the assistance received:

IEC 229	Tests on cable oversheaths which have a special protective function and are applied by extrusion
IEC 502	Extruded solid dielectric insulated power cables for rated voltages from 1 kV up to 30 kV
IEC 811	Common test methods for insulating and sheathing materials of electric cables
AEIC CS5	Thermoplastic and crosslinked polyethylene insulated shielded power cables rated 5 kV through 35 kV
AEIC CS6	Ethylene propylene rubber insulated shielded power cables rated 5 kV through 69 kV
NEMA No WC 7	Cross-linked-thermosetting-polyethylene-insulated wire and cable for the transmission and distribution of electrical energy
NEMA No WC 8	Ethylene-propylene-rubber-insulated wire and cable for the transmission and distribution of electrical energy

The nominal cross-sectional areas of the conductors specified herein are identical with the values specified in AS 1125, *Conductors in insulated electric cables and flexible cords*. The dimensions for insulation and non-metallic sheath thicknesses are identical with the values recommended in IEC 502. Certain tests and criteria in this Standard are more stringent than those in IEC 502.

Two types of insulation and non-metallic sheath compounds are specified in this Standard, namely insulation comprising cross-linked polyethylene (XLPE) or ethylene propylene rubber (EPR) and non-metallic sheath comprising polyvinyl chloride (PVC) or high density polyethylene (HDPE).

Although the Standard provides tables of insulation thicknesses and the necessary information to establish precisely the dimensions of the cable protective coverings, no cable dimension tables are provided owing to the variety of cable constructions that could possibly affect such dimensions.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	6
1.2 REFERENCED DOCUMENTS	6
1.3 DEFINITIONS	6
SECTION 2 CONSTRUCTION	
2.1 OPERATING VOLTAGES	8
2.2 MAXIMUM CONDUCTOR TEMPERATURE	8
2.3 CONDUCTORS	8
2.4 CONDUCTOR SCREEN	8
2.5 INSULATION	9
2.6 INSULATION SCREEN	9
2.7 INDIVIDUAL OR COLLECTIVE SCREEN	10
2.8 IDENTIFICATION OF CORES	10
2.9 LAYING-UP	11
2.10 FILLERS, BINDERS, AND BARRIER TAPES	12
2.11 METAL SHEATH	12
2.12 SEPARATION SHEATH	12
2.13 BEDDING (METAL SHEATHED CABLES ONLY)	13
2.14 ARMOUR	13
2.15 NON-METALLIC SHEATH	14
2.16 SERVING (ARMoured METAL SHEATHED CABLES ONLY)	15
2.17 WATER-BLOCKING (OPTIONAL)	15
2.18 PROTECTION FROM BORING INSECTS (OPTIONAL)	15
2.19 CABLE IDENTIFICATION	15
2.20 METRE MARKING ON CABLE (OPTIONAL)	16
2.21 PREPARATION FOR DELIVERY	16
2.22 MARKING OF DRUMS	16
SECTION 3 TESTS	
3.1 TESTS	18
SECTION 4 REQUIREMENTS SPECIFIC TO CABLES COMPRISING INDIVIDUALLY SCREENED CORES	
4.1 GENERAL	26
4.2 SPECIFIC REQUIREMENTS	26
SECTION 5 REQUIREMENTS SPECIFIC TO THREE-CORE CABLES COMPRISING COLLECTIVELY SCREENED CORES	
5.1 GENERAL	27
5.2 SPECIFIC REQUIREMENTS	27

APPENDICES

A	THE FICTITIOUS CALCULATION METHOD FOR THE DETERMINATION OF THE DIMENSIONS OF INSULATION SCREEN AND PROTECTIVE COVERINGS	28
B	PURCHASING GUIDELINES	31
C	RECOMMENDATIONS FOR CABLE INDIVIDUAL OR COLLECTIVE SCREENS	32
D	TEST FOR EFFECTIVENESS OF WATER-BLOCKING	33
E	RECOMMENDED DIAMETER OF DRUM BARREL AND INSTALLATION BENDING RADIUS FOR CABLES	35
F	RECOMMENDATIONS FOR SAMPLE SELECTION AND RETEST PROCEDURE FOR SPECIAL TESTS	36
G	VOID	37
H	IMPULSE TEST	40
I	ROUNDING OF NUMBERS	42
J	TESTS AFTER INSTALLATION	43

STANDARDS AUSTRALIA

Australian Standard**Electric cables—Polymeric insulated**

Part 1: For working voltages 1.9/3.3 (3.6) kV
up to and including 19/33 (36) kV

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE This Standard specifies requirements for cross-linked polyethylene (XLPE) and ethylene propylene rubber (EPR) insulated cables for fixed installations for electricity supply.

NOTE: Optional requirements for water-blocking, protection from boring insects and metre marking on cable are provided in Clauses 2.17, 2.18 and 2.20.

Section 4 applies to single-core and three-core cables comprising individually screened cores and Section 5 applies to three-core cables comprising collectively screened cores.

1.2 REFERENCED DOCUMENTS The following documents are referred to in this Standard:

AS

- 1018 Partial discharge measurements
- 1125 Conductors in insulated electric cables and flexible cords
- 1660 Methods of test for electric cables, cords and conductors
- 1931 High voltage testing techniques
- 2857 Timber drums for insulated electric cables and bare conductors
- 2893 Electric cables—Lead and lead alloy sheaths—Composition
- 3863 Galvanized mild steel wire for armouring cables
- 3983 Metal drums for insulated electric cables and bare conductors

IEC

- 986 Guide to the short-circuit temperature limits of electric cables with a rated voltage from 1.8/3 (3.6) kV to 18/30 (36) kV

1.3 DEFINITIONS For the purposes of this Standard, the relevant definitions in the referenced Standards and those below apply:

1.3.1 Approximate value—a value which is neither guaranteed nor checked.

1.3.2 Collective screen—a metallic screen applied over the laid-up core assembly.

1.3.3 Conductor screen—a layer or layers of non-metallic semiconductive material applied directly over the conductor.

1.3.4 Core (of a cable)—an assembly comprising a conductor, semiconductive conductor screen, insulation and semiconductive insulation screen.

1.3.5 Direction of lay—the slope of the core, screen wire or armour wire, or the like when the cable is held vertically.

It is right-hand when the slope is in the direction of the central part of the letter Z, and left-hand when the slope is in the direction of the central part of the letter S.