

AS 1768—1991
NZS/AS 1768—1991

Australian Standard®
New Zealand Standard

Lightning protection

This Standard was prepared under a joint arrangement by Standards Australia and the Standards Association of New Zealand. It was approved for publication on behalf of the Council of Standards Australia on 18 September 1991 and on behalf of the Standards Council of New Zealand on 6 September 1991. It was published on 9 December 1991.

The following organizations are represented on the Committees responsible for this Standard:

Standards Australia Committee EL/24, Protection Against Lightning

Association of Consulting Engineers Australia
Australian Corrosion Association
Australian Electrical and Electronic Manufacturers Association
Australian Institute of Petroleum
Building Owners and Managers Association of Australia
Confederation of Australian Industry
Department of Defence
Department of Minerals and Energy, N.S.W.
Department of Administrative Services—Australian Construction Services
Electricity Supply Association of Australia
Institution of Engineers Australia
Public Works Department, N.S.W.
Railways of Australia Committee
Telecom Australia
University of Queensland
Standards Association of New Zealand

Standards Association of New Zealand Electrotechnical Board, 60/–, was responsible for coordinating the New Zealand participation.

Review of Standards. To keep abreast of progress in industry, Joint Australian/New Zealand Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Joint Standards and related publications will be found in the Standards Australia and Standards New Zealand Catalogue of Publications; this information is supplemented each month by the magazines 'The Australian Standard' and 'Standards New Zealand', which subscribing members receive, and which give details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Joint Standards, addressed to the head office of either Standards Australia or Standards New Zealand, are welcomed. Notification of any inaccuracy or ambiguity found in a Joint Australian/New Zealand Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AS 1768—1991
NZS/AS 1768—1991

Australian Standard[®]
New Zealand Standard

Lightning protection

In Australia
First published as AS MC1—1969.
Revised and redesignated AS 1768—1975.
Second edition 1983.
Third edition 1991.

In New Zealand
First published as NZS/AS 1768—1991.

PUBLISHED JOINTLY BY:

STANDARDS AUSTRALIA
(Standards Association of Australia), 1 The Crescent, Homebush,
NSW, Australia

STANDARDS NEW ZEALAND
Level 10, Standards House,
155 The Terrace,
Wellington 6001 New Zealand

ISBN 0 7262 7132 2

PREFACE

This Standard is issued as a joint Standard under the terms of the Memorandum of Understanding between Standards Australia and the Standards Association of New Zealand with the objective of reducing technical barriers to trade between the two nations. It was prepared by the Standards Australia Committee on Protection against Lightning and, in Australia, it supersedes AS 1768–1983.

This Standard is intended to provide authoritative guidance on the principles and practice of lightning protection for a wide range of structures and systems, but excludes those owned or operated by public utilities and statutory authorities. It is not intended for mandatory application but, if called up in a contractual situation, compliance with this Standard requires compliance with all relevant clauses of the Standard. Alternative methods of protection to those described in this Standard will be the subject of future consideration.

In general, it is not economically possible to provide total protection against all the possible damaging effects of lightning, but the recommendations in this Standard will reduce the probability of damage to a low level, and will minimize any lightning damage that does occur. Guidance is given to methods of enhancing the level of protection against lightning damage, if this is required in a particular situation.

Following a review of submissions relating to AS 1768–1983, several changes and additions have been made to this Standard. Information is given on the protection of persons and equipment within buildings from the harmful effects of lightning strikes to the building, or to electrical power or communication services entering the building from remote sites. Revised recommendations are given relating to the compatibility of materials used in lightning protection systems, especially from the point of view of minimizing galvanic corrosion of components. In addition, changes have been made to recommendations for protection of the sides of tall buildings.

Unless it has been specified that lightning protection must be provided, the first decision to make is whether the lightning protection is needed. Section 2 provides guidance to assist in this decision. Section 3 provides advice on the protection of persons from lightning, mainly relating to the behaviour of persons when not inside substantial buildings. Once a decision is made that lightning protection is necessary, Section 4 will provide details on interception lightning protection for the building or structure. This includes information on the size, material, and form of conductors, the positioning of air terminations and downconductors, and the requirements for the earth terminations. Persons and equipment within buildings can be at risk from the indirect effects of lightning and Section 5 gives recommendations on the protective measures that may need to be applied.

Section 6 describes methods of lightning protection of various items not covered in earlier sections, such as communications aerials, chimneys, boats, fences, and trees. A new clause has been included on methods for protecting domestic dwellings, where a complete protection system may not be justified, but some protection is considered desirable.

Section 7 sets out recommendations for the protection of structures with explosive or highly flammable contents. Section 8 gives advice on inspecting, testing, and maintaining lightning protection systems.

A number of appendices are included which provide additional information and advice. The appendices form an integral part of this Standard unless specifically stated otherwise, i.e. appendices identified as 'informative' only provide supportive or background information and are therefore not an integral part of this Standard.

© Copyright — STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Users of Standards are reminded that copyright subsists in all Standards Australia and Standards New Zealand publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia or Standards New Zealand may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia or Standards New Zealand. Permission may be conditional on an appropriate royalty payment. Australian requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia. New Zealand requests should be directed to Standards New Zealand.

Up to 10 percent of the technical content pages of a Standard may be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia or Standards New Zealand.

Inclusion of copyright material in computer software programs is also permitted without royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia or Standards New Zealand at any time.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 APPLICATION	5
1.3 REFERENCED DOCUMENTS	5
1.4 DEFINITIONS	5
SECTION 2 ANALYSIS OF NEED FOR PROTECTION	
2.1 NEED FOR PERSONAL PROTECTION	7
2.2 NEED FOR PROTECTION OF BUILDINGS AND CONTENTS	7
2.3 NEED FOR PROTECTION OF PERSONS AND EQUIPMENT WITHIN BUILDINGS	8
SECTION 3 BEHAVIOURAL PRECAUTIONS FOR PERSONAL SAFETY	
3.1 SCOPE OF SECTION	13
3.2 PERSONAL CONDUCT	13
3.3 EFFECT ON PERSONS AND TREATMENT FOR INJURY BY LIGHTNING	13
SECTION 4 PROTECTION OF BUILDINGS	
4.1 SCOPE OF SECTION	14
4.2 ZONES OF PROTECTION	14
4.3 METHODS OF PROTECTION	14
4.4 MATTERS TO BE CONSIDERED WHEN PLANNING PROTECTION	18
4.5 MATERIALS	21
4.6 FORM AND SIZE OF CONDUCTORS	23
4.7 JOINTS	24
4.8 FASTENERS	24
4.9 AIR TERMINATIONS	24
4.10 DOWNCONDUCTORS	26
4.11 TEST LINKS	27
4.12 EARTH TERMINATIONS	27
4.13 EARTHING ELECTRODES	29
4.14 METAL IN AND ON A STRUCTURE	30
SECTION 5 PROTECTION OF PERSONS AND EQUIPMENT WITHIN BUILDINGS	
5.1 SCOPE OF SECTION	33
5.2 NEED FOR PROTECTION	33
5.3 MODES OF ENTRY OF LIGHTNING IMPULSES	33
5.4 GENERAL CONSIDERATIONS FOR PROTECTION	34
5.5 PROTECTION OF PERSONS WITHIN BUILDINGS	36
5.6 PROTECTION OF EQUIPMENT	37
SECTION 6 PROTECTION OF MISCELLANEOUS STRUCTURES AND PROPERTY	
6.1 SCOPE OF SECTION	42
6.2 STRUCTURES WITH RADIO AND TELEVISION AERIALS	42
6.3 STRUCTURES NEAR TREES	42
6.4 PROTECTION OF TREES	42
6.5 CHIMNEYS, METAL GUY-WIRES OR CABLES	43
6.6 PROTECTION OF MINES	43
6.7 PROTECTION OF BOATS	44
6.8 FENCES	45
6.9 MISCELLANEOUS STRUCTURES	46
6.10 PROTECTION OF HOUSES AND SMALL BUILDINGS	47

STANDARDS AUSTRALIA/STANDARDS ASSOCIATION OF NEW ZEALAND

Australian/New Zealand Standard
Lightning protection

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE This Standard sets out guidelines for the protection of persons and property from hazards arising from exposure to lightning. The recommendations specifically cover the following applications:

- (a) The protection of persons, both outdoors, where they may be at risk from the direct effects of a lightning strike, and indoors, where they may be at risk indirectly as a consequence of lightning currents being conducted into the building.
- (b) The protection of a variety of buildings or structures, including those with explosive or highly-flammable contents, and mines.
- (c) The protection of sensitive electronic equipment (e.g. facsimile machines, modems, computers) from overvoltages resulting from a lightning strike to the building or its associated services.

The nature of lightning and the principles of lightning protection are discussed and guidance is given to assist in a determination of whether protective measures should be taken.

The recommendations in this Standard do not apply to the protection of large scale power or communications systems, nor do they apply to the protection of special structures such as oil and gas platforms.

1.2 APPLICATION This Standard does not override any statutory requirements but may be used in conjunction with such requirements.

Compliance with the recommendations of this Standard will not necessarily prevent damage or personal injury due to lightning but will reduce the probability of such damage or injury occurring.

1.3 REFERENCED DOCUMENTS The documents referred to in this Standard are listed in Appendix F.

1.4 DEFINITIONS For the purpose of this Standard, the definitions below apply.

1.4.1 Air termination—a conductor or rod of a lightning protection system, positioned so as to intercept a lightning discharge, which establishes a zone of protection.

1.4.2 Air termination network—a network of air terminations and interconnecting conductors which forms the part of a lightning protection system which is intended to intercept lightning discharges.

1.4.3 Base conductors (base tapes)—conductors placed around the perimeter of a structure near ground level interconnected to a number of earth terminations to distribute the lightning currents amongst them.

1.4.4 Bond (bonding conductor)—a conductor intended to provide electrical connection between the lightning protection system and other metalwork and between various metal parts of a structure or between earthing systems.

1.4.5 Downconductor—a conductor which connects an air termination with an earth termination.

1.4.6 Earth impedance (Z)—the electrical impedance of an electrode or structure to earth, derived from the earth potential rise divided by the impulse current to earth causing that rise. It is a relatively complex function and depends on—

- (a) the resistance component (R) as measured by an earth tester;
- (b) the reactance component (X), depending on the circuit path to the general body of earth; and
- (c) a modifying (reducing) time-related component depending on soil ionization caused by high current and fast rise times.

1.4.7 Earth potential rise (EPR)—the increase in electrical potential of an earth electrode or earthed structure, with respect to distant earth, caused by the discharge of current to the general body of earth through the impedance of that electrode or structure.

1.4.8 Earthing boss (terminal lug)—a metal boss specially designed and welded to process plant, storage tanks, or steelwork to which earthing conductors are attached by means of removable studs and nuts or bolts.

1.4.9 Earthing conductor—the conductor by which the final connection to an earth electrode is made.