

Australian Standard<sup>®</sup>

---

**Disturbances in mains supply  
networks**

**Part 4: Limitation of voltage  
fluctuations caused by industrial  
equipment**

---

This Australian Standard was prepared by Committee EL/34, Electric Waveform Distortion. It was approved on behalf of the Council of Standards Australia on 15 March 1991 and published on 13 May 1991.

---

The following interests are represented on Committee EL/34:

Australian Electrical and Electronic Manufacturers Association  
Bureau of Steel Manufacturers of Australia  
Confederation of Australian Industry  
Department of Defence  
Electricity Supply Association of Australia  
Institution of Engineers, Australia  
Institution of Radio and Electronics Engineers, Australia  
Monash University  
Railways of Australia Committee  
Telecom Australia  
University of Sydney  
University of Wollongong  
Water Board, Sydney

---

**Review of Australian Standards.** *To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

*Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.*

*Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.*

Australian Standard<sup>®</sup>

---

**Disturbances in mains supply  
networks**

**Part 4: Limitation of voltage  
fluctuations caused by industrial  
equipment**

---

First published as AS 2279.4—1985.  
Second edition—1991.

## PREFACE

This Standard was prepared by the Standards Australia Committee on Electric Waveform Distortion. It is one part of a Standard on disturbances in mains supply networks, the four parts being as follows:

Part 1—*Limitation of harmonics caused by household and similar electrical appliances*

Part 2—*Limitation of harmonics caused by industrial equipment*

Part 3—*Limitation of voltage fluctuations caused by household and similar electrical appliances*

Part 4—*Limitation of voltage fluctuations caused by industrial equipment*

This Standard should be read in conjunction with the Regulations, Service Rules and Installation Rules of the supply authority approving the connection.

Part 4 of this Standard provides guidance on the acceptable limits of voltage fluctuations caused by industrial equipment. In particular, this guidance is intended for application to equipment which is intended exclusively for industrial, professional or commercial purposes with ratings greater than 4.8 kV.A and which produces voltage changes in the range of one change per hour to 1800 changes per minute.

Part 4 also concerns specific equipment subject to individual consideration by the supply authority before it may be connected to the system.

---

## CONTENTS

	<i>Page</i>
1 SCOPE	3
2 REFERENCED DOCUMENTS . . . . .	3
3 GENERAL . . . . .	3
4 SUPPLY AUTHORITY RIGHT OF APPROVAL . . . . .	3
5 DEFINITIONS . . . . .	3
6 VOLTAGE FLUCTUATION LIMITS . . . . .	4
7 MULTIPLE VOLTAGE FLUCTUATIONS . . . . .	6
8 IMPLEMENTATION . . . . .	6
APPENDIX A CALCULATION OF MAGNITUDE OF VOLTAGE CHANGE DUE TO INDUSTRIAL EQUIPMENT . . . . .	10

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

# STANDARDS AUSTRALIA

## Australian Standard

### Disturbances in mains supply networks

#### Part 4—Limitation of voltage fluctuations caused by industrial equipment

**1 SCOPE** Part 4 of this Standard provides guidance on the acceptable limits of voltage fluctuations at the point of common coupling caused by industrial equipment supplied from high or low voltage electricity supply systems.

The switching of equipment or variations in its loading may cause changes in voltage which could result in the unsatisfactory operation of other equipment and undesirable effects such as flicker in incandescent lamps.

Part 4 of this Standard is applicable to all electrical equipment other than that covered by AS 2279.3. In particular, this Part is intended for application to equipment which—

- (a) is intended exclusively for industrial, professional or commercial purposes and with a rating greater than 4.8 kV.A; and
- (b) produces voltage changes in the range of one change per day to 1800 changes per minute.

In addition, it concerns specific equipment subject to individual consideration by the supply authority before it may be connected to the system.

Equipment which would produce voltage fluctuations and would fall within the Scope of Part 4 of this Standard includes pump and compressor motors, welding plant, furnaces, elevators, equipment for manufacturing processes, mining, lighting and air conditioning.

This Standard does not apply to voltage unbalance in supply systems or intermittent transient disturbances e.g. spikes and dips.

**2 REFERENCED DOCUMENTS** The following documents are referred to in this Standard:

AS	
2279	Disturbances in mains supply networks
2279.3	Part 3: Limitation of voltage fluctuations caused by household and similar electrical appliances
IEC	
868	Flickermeter. Functional and design specifications

**3 GENERAL** By necessity, the limits contained in this Standard have been based on certain simplifying assumptions. They are to be taken as a guide to good engineering practice with regard to voltage fluctuations.

Adherence to the recommended values should minimize the likelihood of interference with or visual annoyance to other consumers.

**4 SUPPLY AUTHORITY RIGHT OF APPROVAL** This Standard does not override the Regulations, Service Rules or Installation Rules of the supply authority that will approve the connection of the equipment.

**5 DEFINITIONS** For the purpose of this Standard, the following definitions apply:

**5.1 Point of common coupling (PCC)**—the point in the public supply network, electrically nearest to the consumer for whom the new connection is proposed, at which other consumers' loads are, or may be, connected.

NOTE: It is possible to obtain a greater voltage fluctuation on the supply side of the PCC with certain types of installation, such as when reactive power compensation is used in conjunction with a large fluctuating load. These will require Stage 3 assessment (see Clause 6.1.1(c)) which should provide for this possibility. Stage 3 considerations should also be applied for supply systems having low fault levels and which are sensitive to fluctuating loads.

**5.2 Transmission system**—a system conveying electrical energy in bulk at high voltages, generally over long distances.

NOTE: Standard voltage levels in Australia are 66, 110, 132, 220, 275, 330 and 500 kV.

**5.3 Subtransmission system**—a system conveying electrical energy, obtained from a transmission system or power station to a primary distribution system.

NOTE: Customary voltage levels in Australia are 22, 33, 66, 110 and 132 kV.