

Australian Standard®

---

**Medical gas systems—Installation  
and testing of non-flammable  
medical gas pipeline systems**

---

This Australian Standard was prepared by Committee HT/4, Medical Gases and Pipeline Services. It was approved on behalf of the Council of Standards Australia on 5 June 1991 and published on 16 September 1991.

---

The following interests are represented on Committee HT/4:

Association of Consulting Engineers, Australia  
Australian Society of Anaesthetists  
Building Management Authority, W.A.  
Confederation of Australian Industry  
Department of Community Services and Health  
Department of Health, N.S.W.  
Health Department, W.A.  
Institute of Hospital Engineering, Australia  
Medical Industry Association of Australia  
Metal Trades Industry Association of Australia  
Public Works Department, N.S.W.  
Royal Australasian College of Surgeons  
South Australian Department of Housing and Construction  
South Australian Health Commission

---

*Review of Australian Standards.* To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the *Standards Australia Catalogue of Publications*; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

Australian Standard®

---

**Medical gas systems—Installation  
and testing of non-flammable  
medical gas pipeline systems**

---

First published as part of AS CZ9-1956.  
Second edition 1963.  
Revised and redesignated AS 1169-1973.  
Redesignated in part as AS 1169.2-1973.  
Revised and redesignated AS 2896-1986.  
Second edition 1991.

## PREFACE

This Standard was prepared by the Standards Australia Committee on Medical Gases and Pipeline Services to supersede AS 2896—1986.

This Standard differs from the 1986 edition in that guidelines for fixed secondary equipment such as pendants and columns are now included, Appendix A has been modified, Figures 1.1, 1.2 and 1.3 have been amended, Table 4.1 has been altered and the use of UPVC pipes for vacuum has been excluded.

In medical establishments it is vital that high safety standards are maintained and also that there is no risk of failure of supply or plant without adequate warning. Thus particular attention is given in this Standard to the following:

- (a) Design of equipment to ensure non-interchangeability between services.
- (b) Use of correct materials, and cleanness of materials.
- (c) Reserve supplies of gas and reserve plant.
- (d) Warning systems for gas failure.
- (e) Testing and commissioning of pipelines, in particular to detect cross-connections.
- (f) Identification of pipelines.

Requirements in this Standard may be used as a guide for piping systems for other non-flammable medical gases and anaesthetic gas scavenging systems but variations in the requirements may be necessary. This Standard will be revised should such a gas come into general use.

Non-flammable medical gas pipeline systems are installed according to all national and local codes and regulations such as building, electrical and safety codes. It should be noted that for installation of a pipeline, a high quality of workmanship and experience is essential. For certain situations, e.g. hyperbaric conditions, special design and performance criteria for pipelines may be required.

Requirements for suction systems are included in this Standard. At this time there are two techniques widely used, namely pipeline vacuum and venturi ejector suction. Each has its particular advantages. This Standard and AS 2120 specify performance and safety aspects to which both should conform. Requirements for a reasonable reserve performance are incorporated in relevant sections of this Standard; further allowances should not be necessary, unless it is intended to extend the pipeline in question in the future. With regard to anaesthetic gas scavenging, currently available evidence suggests that there is no special hazard associated with venting of waste anaesthetic gases into a central suction system.

Many systems in use do not comply with the intent of Clause 3.5 on terminal units. Because the gas specific component of some terminal units can be removed, these units can become a hazard to patients. To obviate this risk it is recommended that panels with multiple terminal outlets be upgraded within 12 months of publication of this Standard, to the intent of Clause 3.5. It is recognized that replacement of single terminal outlet panels is less urgent because of the smaller risk.

A sleeve indexed fitting is given in Figure 3.3 for surgical tool gas. This connection is recommended as it contains a thread, and therefore by its design has a controlled detachment and reduces the risk of 'hose whip'. The use of adaptors with 'quick connect/disconnect' (Schrader) fittings is not advisable.

In the preparation of this Standard, cognizance was taken of ISO 7396—1987, *Non-flammable medical gas pipeline systems*.

### © Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

## CONTENTS

	<i>Page</i>
FOREWORD ....	5
 SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE ....	6
1.2 APPLICATION ....	6
1.3 REFERENCED DOCUMENTS ....	6
1.4 DEFINITIONS ....	6
 SECTION 2 SOURCE OF SUPPLY	
2.1 GENERAL ....	12
2.2 PROVISION IN CASE OF FAILURE OF SUPPLY ....	12
2.3 CYLINDERS AND CYLINDER VALVES ....	12
2.4 CYLINDER SUPPLY SYSTEM ....	12
2.5 REGULATORS ....	13
2.6 DESIGN OF GAS CONTROL SYSTEMS ....	13
2.7 PRESSURE SAFETY VALVES ....	13
2.8 CRYOGENIC SYSTEMS ....	13
2.9 MEDICAL BREATHING AIR SYSTEM ....	14
2.10 MEDICAL SUCTION SYSTEMS ....	16
2.11 LOCATIONS OF SOURCES OF GAS SUPPLY ....	19
2.12 ENCLOSURES FOR SUPPLY SYSTEMS ....	19
 SECTION 3 GENERAL REQUIREMENTS	
3.1 WARNING SYSTEMS ....	21
3.2 MATERIALS ....	22
3.3 REQUIREMENTS FOR PIPELINES ....	23
3.4 PIPELINE SHUT-OFF VALVES ....	25
3.5 TERMINAL UNITS ....	25
3.6 IDENTIFICATION OF PIPELINES ....	27
3.7 PRESSURE GAUGES ....	28
 SECTION 4 INSTALLATION REQUIREMENTS FOR PIPELINES	
4.1 GENERAL ....	30
4.2 ELECTRICAL SEGREGATION ....	30
4.3 PROTECTION OF PIPELINES ....	30
4.4 MEDICAL GAS RISERS ....	31
4.5 RISERS AND DROPPERS TO TERMINAL UNITS ....	31
4.6 SLEEVES ....	31
4.7 CONTACT WITH CORROSIVE MATERIALS ....	31
4.8 ROUTING ....	31
4.9 CUTTING INTO EXISTING SYSTEM ....	31
4.10 INTERCONNECTION ....	32
4.11 PIPELINE SUPPORTS ....	32
4.12 COPPER PIPELINE JOINTS ....	32
4.13 CONNECTION TO EXISTING SYSTEMS ....	32
4.14 FIXED SECONDARY EQUIPMENT ....	33
 SECTION 5 TESTING AND CERTIFICATION	
5.1 GENERAL ....	37
5.2 TESTING BY RESPONSIBLE AUTHORITIES ....	37
5.3 LABELLING OF TERMINAL UNITS ....	37
5.4 TESTS AND CHECKS ON PIPELINE BEFORE CONCEALMENT ....	37
5.5 TESTS AND COMMISSIONING OF THE COMPLETE PIPELINE SYSTEM	38
5.6 FILLING SYSTEM WITH PROPER GAS AND FINAL COMMISSIONING	39
5.7 CERTIFICATION OF SYSTEMS ....	39
5.8 AS-INSTALLED DRAWINGS ....	40

	<i>Page</i>
SECTION 6 MAINTENANCE	
6.1 GENERAL	41
6.2 SAFETY AND WARNING DEVICES	41
6.3 SOURCE OF SUPPLY	41
6.4 PURITY OF MEDICAL BREATHING AIR	42
6.5 MAINTENANCE OF TERMINAL UNITS	42
6.6 PRESSURE GAUGES AND PRESSURE SWITCHES	42
6.7 SERVICE MANUALS	42
APPENDICES	
A LIST OF REFERENCED DOCUMENTS	43
B GUIDE TO PERFORMANCE OF TYPICAL MEDICAL GAS PIPING SYSTEMS	44
C OPERATING ALARM SYSTEMS	49
D RECOMMENDATIONS FOR MATERIALS AND JOINTING TECHNIQUES	50
E CONVERSION FACTORS FOR UNITS USED IN THE MEASUREMENT OF PRESSURE	51
F OUTLINE FOR DETERMINING PREVIOUS EXPERIENCE	52
G GUIDANCE TO QUALITY OF WORKMANSHIP IN CONSTRUCTION	52
H FLUXLESS BRAZING TECHNIQUE	53
I MEDICAL GAS SYSTEMS—INSPECTION FORM	58
J LOGISTIC DIAGRAM FOR TESTING OF PIPELINE SYSTEM	59
K RELATIONSHIP BETWEEN TEMPERATURE AND CERTAIN PRESSURE RANGES OF A GIVEN MASS OF PERFECT GAS ASSUMING VOLUME OF CONTAINER IS CONSTANT	60
L TEST PRESSURE/TEMPERATURE VARIATION FOR SUCTION	61

## FOREWORD

Gas pipeline systems have some characteristic hazards, usually related to their original construction, modification, or repair rather than to problems arising during their working life. Hazards include plumbing errors; use of materials incompatible with the gases to be delivered; obstruction of flow by material left in the pipelines; gas contamination by residual debris or accumulated foreign matter such as scale and organic contamination; and gas contamination due to chemical interaction between the gases and the pipeline components or foreign matter and condensation in pipelines. A particularly hazardous situation can occur when even small amounts of grease or oil come in contact with oxygen.

For this reason, this Standard requires that the following procedures be taken to avoid gas pipeline hazards:

- (a) Documentation of tests and results from those responsible for the construction shall be provided to the health care facility, and these shall form a permanent record.
- (b) Independent inspection of the system by *the health care facility*, using its own qualified personnel, or an experienced agent which may be an independent outside contractor, to confirm and document the system's satisfactory operation.

The maintenance and servicing of the gas pipeline system is the responsibility of the health care facility but may be delegated.

Components of the medical gas system should be obtained and installed under the supervision of a person familiar with proper practices for their construction, installation and use. Construction and installation of central supply systems require great care and shall only be undertaken by experienced personnel. In order to establish this, the hospital authority should examine closely the previous experience of any constructor or installer proposing to work on or build a pipeline system. The authority should also determine if the constructor or installer is familiar with the contents of this Standard, which should be specified in the construction agreement.

## STANDARDS AUSTRALIA

## Australian Standard

**Medical gas systems—Installation and testing of non-flammable medical gas pipeline systems**

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE** This Standard sets out requirements for safety aspects, construction, testing, operation and maintenance of non-flammable medical gas pipeline systems used for patient care, including therapeutic, diagnostic and prophylactic applications, and for operating surgical tools. Non-flammable medical gas pipeline systems include suction pipeline systems.

The Standard is intended also to apply to suction systems for day-care centres and clinical situations but does not apply to suction systems for laboratories or hospital dental units.

Some requirements are given for the source of supply for the pipeline system as well as those for the pipeline system itself and the terminal units and related warning systems.

The Standard also gives guidelines for operating room pendants, columns and booms.

**1.2 APPLICATION** The Standard applies to systems providing the following services:

- (a) Oxygen.
- (b) Nitrous oxide.
- (c) Medical breathing air.
- (d) Surgical tool gas.
- (e) Mixtures of medical gases (e.g. nominal 50 percent oxygen, 50 percent nitrous oxide).
- (f) Carbon dioxide.
- (g) Medical suction.

NOTE: The preferred term 'suction' in Australia corresponds with the internationally known term 'vacuum'.

**1.3 REFERENCED DOCUMENTS** A list of the documents referred to in this Standard is given in Appendix A.

**1.4 DEFINITIONS** For the purposes of this Standard, the definitions below apply.

**1.4.1 Boom**—a wall-mounted equipment module having a combination of integrally fitted terminal outlets for gas, mains electricity, communications, monitoring and extra-low voltage services.

**1.4.2 Central bulk gas supply (central supply)**—this consists of—

- (a) a supply which is either a bank of gas cylinders (Figure 1.1) or a cryogenic liquid supply (Figure 1.2); or
- (b) a system using compressors with or without a bank of gas cylinders (Figure 1.3); or
- (c) a system using suction pumps.

**1.4.3 Column**—a floor-mounted equipment module extending to, and attached to, the ceiling having a combination of integrally fitted terminal outlets for gas, mains electricity, communications, monitoring and extra-low voltage services.

**1.4.4 Control equipment**—items such as pressure control regulators, relief valves, alarm initiators, manual and automatic valves, necessary to maintain gas supplies at a set pressure within the pipeline distribution system.

**1.4.5 Cryogenic liquid system**—a system incorporating a liquid supply, the storage pressure of which is thermally controlled. It consists of a primary and secondary supply which is liquid, and an emergency supply which is gaseous. The secondary supply is usually the residual cryogenic liquid below a predetermined level. This is commonly referred to as a vacuum-insulated evaporator (VIE).

**1.4.6 Design flow rate**—the free flow rate which is calculated from a knowledge of the number of terminal units to be supplied and from a knowledge of the expected equipment that will be connected, from a knowledge of the nursing/medical procedures and from a knowledge of the diversity of use factor agreed between the designer and the hospital's accredited representative for the project.

**1.4.7 Emergency gas supply**—a gas supply source which is available when primary and secondary supplies have been exhausted.

**1.4.8 Emergency power supply**—a no-break (uninterrupted power supply) electrical energy source normally provided from batteries.