

Australian Standard[®]

Test pumping of water wells

This Australian Standard was prepared by Committee CE/28, Test pumping water wells. It was approved on behalf of the Council of Standards Australia on 9 April 1990 and published on 17 September 1990.

The following interests are represented on Committee CE/28:

Association of Consulting Engineers Australia
Australian Drilling Industry Association
CSIRO, Division of Water Resources
Department of Mines and Energy, South Australia
Department of Water Resources, New South Wales
Department of Water Resources, Victoria
Geological Survey, Western Australia
Hunter District Water Board
Institution of Engineers Australia
Rural Water Commission, Victoria
University of New South Wales
Water Authority of Western Australia
Water Resources Commission, Queensland

Review of Australian Standards. *To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.*

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 89112.

AS 2368—1990

Australian Standard[®]

Test pumping of water wells

First published as AS 2368—1990.

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 6289 7

PREFACE

This Standard was prepared by the Standards Australia Committee on Test Pumping Water Wells. In preparing this Standard, the committee considered BS 6316:1983, *Code of practice for test pumping water wells*.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
FOREWORD	4
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	5
1.2 REFERENCED DOCUMENTS	5
1.3 DEFINITIONS	5
SECTION 2 HYDROGEOLOGICAL CONSIDERATIONS	9
SECTION 3 PRETEST PLANNING	
3.1 STATUTORY REQUIREMENTS	10
3.2 SITE FACILITIES AND ORGANIZATION	10
3.3 DESIGN OF THE TEST	11
SECTION 4 PRETEST MEASUREMENTS	
4.1 GENERAL CONSIDERATIONS	17
4.2 SURFACE WATERS	17
4.3 GROUNDWATER	17
4.4 METEOROLOGICAL PARAMETERS	17
4.5 ABSTRACTIONS AND DISCHARGES	17
SECTION 5 TEST PROCEDURES	
5.1 GENERAL	18
5.2 FREQUENCY OF OBSERVATIONS	18
5.3 TESTS FOR NON-FLOWING WELLS	18
5.4 TESTS FOR FLOWING WELLS	21
5.5 MULTIPLE AQUIFER TESTS	24
5.6 WATER QUALITY SAMPLING	25
5.7 INTERRUPTIONS	25
5.8 MEASUREMENT OF AQUIFER RESPONSE DURING TEST	25
SECTION 6 SPECIAL TESTS	
6.1 GENERAL	27
6.2 RAPID DISPLACEMENT TESTS	27
6.3 CONVENTIONAL SLUG TEST	27
6.4 PNEUMATIC DISPLACEMENT TEST	28
6.5 AUGER HOLE TEST	29
6.6 PIEZOMETER TEST	29
SECTION 7 POST-TEST OBSERVATIONS	
7.1 GENERAL	30
7.2 DRAWDOWN AND DISCHARGE MONITORING	30
7.3 WATER QUALITY	30
SECTION 8 PRESENTATION OF INFORMATION	
8.1 GENERAL	31
8.2 PRESENTATION	31
APPENDICES	
A TYPES OF DRAWDOWN TREND EXHIBITED BY FIELD DATA	32
B SELECTION OF PUMPING EQUIPMENT	36
C EXAMPLES OF FORMS FOR DATA COLLECTION	37

FOREWORD

A pumping test is a means of obtaining quantitative information about groundwater systems and the wells which obtain water from them. The test is based on a period of pumping and recovery during which the pumping rate, water level in the well, and elapsed time, are measured.

The test can be used to —

- (a) assess the hydraulic behaviour of a well and so determine its usefulness as a source of water, predict its performance under different pumping regimes, and enable determination of the most suitable pump and optimum intake depth; and
- (b) determine the hydraulic properties of the groundwater system penetrated by the well, i.e. the transmissivity, storativity, and the presence, type, and distance of any hydraulic boundaries.

A pumping test also provides an opportunity to obtain information on water quality and its variation with time and perhaps with discharge rate.

When water is pumped from a well, the head in the well is lowered, creating a drawdown and setting up a localized hydraulic gradient which causes water to flow to the well from the surrounding aquifer. The head in the aquifer is also reduced and the effect spreads outwards from the well. A cone of depression of the potentiometric surface is thus formed around the well, and the shape and the manner of expansion of this cone depends on the pumping rate and on the hydraulic properties of the aquifer. By recording the changes in the potentiometric head in observation wells located around the pumping well, it is possible to monitor the growth of the cone of depression and determine these hydraulic characteristics. Immediately around the well, the form of the cone of depression will generally be modified because additional head losses are incurred as the water crosses the well face. The drawdown in the well (head loss) may be considered to consist of the following two components:

- (i) Head loss through the aquifer.
- (ii) Head loss at the well.

Consequently there are two test objectives, viz an understanding of the characteristics of the well and of those of the aquifer.

A test may be performed to serve one or both of the main objectives. If both are satisfied it may be said that the hydraulic regime of the well and aquifer has been evaluated. It needs to be understood, however, that to predict the long-term effects of abstraction, other information will be required, particularly about factors affecting recharge to the groundwater system.

There are inherent difficulties involved in carrying out a pumping test, for example, wells drilled to investigate the hydraulic regime of an aquifer may disturb that regime by providing vertical connection between aquifers with different hydraulic head conditions. A second difficulty involves sampling. Only rarely will a cone of depression be circular and symmetrical; the relatively few observation wells which are usually available provide, in effect, a limited number of sampling points with which to determine the form of the cone. It is important that these limitations and difficulties are kept clearly in mind when designing and analyzing a pumping test and, in particular, when using the results.

A pumping test provides a basis from which quantitative information on aquifer properties can be obtained and proper decisions can be made for equipping and using a well as the source for a water supply. Wrong decisions can lead to the selection of incorrect pumps, less than optimum pumping schedules, and in the extreme, failure of the well to provide the expected quantity of water. Many well owners tend to save costs by skimping on the pumping test, or even deciding not to have one. This is a risky course of action. Expenditure on the pump test will usually be a small proportion of the cost of construction and equipment of the well, and will be small compared with the cost of failure to deliver at the expected rate after it has been put into production. Well owners are encouraged to allocate sufficient funds for a comprehensive pumping test which can be used as a reliable basis for prediction of future performance.

STANDARDS AUSTRALIA

Australian Standard

Test pumping of water wells

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE. This Standard describes the factors which need to be considered and the measurements which need to be made when designing and performing a pumping test. It deals with the types of pumping tests carried out for water supply purposes, or aquifer parameter determinations in which water is abstracted from the entire screened, perforated, or unlined interval(s) of a well. Some guidance is also provided on slug tests and packer tests. Other specialized tests, such as drill-stem tests, and tests of strata for engineering purposes, are not considered in detail.

Interpretation of the data collected during a pumping test is referred to in this Standard only in a general way. For full details of the analysis and interpretation of test data, reference should be made to specialized texts.

1.2 REFERENCED DOCUMENTS. The following documents are referred to in this Standard:

ISO

1438/1 Water flow measurement in open channels using weirs and Venturi flumes
Part 1: Thin-plate weirs

5167 Measurement of fluid flow by means of orifice plates, nozzles and Venturi tubes inserted in circular cross-section conduits running full

BS

5930 Code of practice for site investigations

1.3 DEFINITIONS. For the purpose of this Standard, the definitions below apply (see also Figure 1.1).

1.3.1 Abstraction-removal of water from a well or aquifer.

1.3.2 Access tube—a pipe inserted into a well to permit installation of instruments, and to safeguard them from touching or becoming entangled with the pump or other equipment in the well.

1.3.3 Anisotropic—having some physical property that varies with direction.

1.3.4 Annulus—the space between the rising main and the casing, or between the casing and the wall of the well.

1.3.5 Aquiclude—a geologic formation, group of formations, or part of a formation through which virtually no water moves.

1.3.6 Aquifer—geologic formation, group of formations, or part of a formation capable of transmitting and yielding significant quantities of water.

1.3.7 Aquifer loss (formation loss)—the head loss at a pumped or flowing well associated with groundwater flow through the aquifer to the well face.

1.3.8 Aquifer properties—the characteristics of an aquifer that determine its hydraulic behaviour and its response to abstraction.

1.3.9 Aquitard—a saturated, but relatively poorly permeable bed, formation, or group of formations that does not transmit or yield water freely.

1.3.10 Boundary—a lateral discontinuity or change in the aquifer resulting in a significant change in hydraulic conductivity, storativity, or recharge.

1.3.11 Casing—a tube used as temporary or permanent lining for a well.

1.3.12 Confined aquifer—a completely saturated aquifer in which the upper and lower boundaries are relatively impermeable layers (aquitards or aquicludes). The groundwater is contained under sufficient pressure to cause it to rise above the aquifer if the top impermeable layer is breached.

1.3.13 Confining bed—a layer of relatively impermeable material underlying, overlying, or adjacent to one or more aquifers.