980 REFERENCE COPY Replacement uppy 11 march 1992. AS 3100-1990 **INFORMATION CENTRE** - 19.97. H . October 1 5 - September Superseded by AS3100-1994 **STANDARDS AUSTRALIA** 1993

Australian Standard®

J

Approval and test specification— General requirements for electrical equipment



This Australian Standard was prepared by Committee EL/2, Electrical Approvals Standards. It was approved on behalf of the Council of Standards Australia on 19 March 1990 and published on 16 July 1990.

The following interests are represented on Committee EL/2: Australian Consumers Association Australian Electrical and Electronic Manufacturers Association Confederation of Australian Industry Consumer Electronics Suppliers Association

Electrical Apparatus Approvals Authorities Electrical Supply Association of Australia

Electrical Testing Laboratories

Institution of Engineers Australia

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up-to-date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

AS 3100/Amdt 6/1994-07-18

- 3 AUG 1994

STANDARDS AUSTRALIA

SYDNEY INFO. CENTRE

STANDARDS AUSTRALIA

Amendment No. 6 to AS 3100—1990 Approval and test specification—General requirements for electrical equipment

REVISED TEXT

The 1990 edition of AS 3100 is amended as follows; the amendments should be inserted in the appropriate place.

. SUMMARY: This Amendment applies to Contents, Table 5.7, Section 6, Table 8.15.9 and Appendix B.

Published on 18 July 1994.

AS 3100/Amdt -

STANDARDS AUSTRALIA

Amendment No. 4 to AS 3100-1990

Approval and test specification-General requirements for electrical equipment

REVISED TEXT

The 1990 edition of AS 3100 is amended as follows; the amendments should be inserted in the appropriate place. SUMMARY: This Amendment applies to Clauses 3.1; 3.8.5, 3.10.1 and 8.12. Published on 12 October 1992.

AS 3100/Amdt 1/1990-10-15

STANDARDS AUSTRALIA

Amendment No 1 to AS 3100—1990 Approval and test specification— General requirements for electrical equipment

REVISED TEXT

The 1990 edition of AS 3100 is amended as follows; the amendment(s) should be inserted in the appropriate place. SUMMARY: This Amendment applies to Clauses 3.10, 6.1.1.3, 6.1.2 and 7.1. Published on 15 October 1990.

٠

57

AS 3100/Amdt 5/1993-09-13

STANDARDS AUSTRALIA

Amendment No. 5 to AS 3100—1990 Approval and test specification— General requirements for electrical equipment

CORRECTION

The 1990 edition of AS 3100 is amended as follows; the amendments should be inserted in the appropriate place.

SUMMARY: This Amendment applies to Clauses 4.5.5, 5.4.9 and 8.4.5.

Published on 13 September 1993.

•

· ·

AS 3100/Amdt 3/1992-03-16

STANDARDS AUSTRALIA

Amendment No. 3 to AS 3100-1990 Approval and test specification-General requirements for electrical equipment

REVISED TEXT

The 1990 edition of AS 3100 is amended as follows; the amendments should be inserted in the appropriate place.

SUMMARY: This Amendment applies to Clauses 2.10A, 2.16, 2.31, 2.34A, 2.36, 4.1.3, 4.3.9, 5.8, 7.4, 8.3.2, 8.10, 8.12, 8.15.1, 8.15.5 and 8.15.7 and Table 5.8.

Published on 16 March 1992.

٠

AS 3100/Amdt 2/1991-01-25

STANDARDS AUSTRALIA

Amendment No 2 to AS 3100—1990 Approval and test specification—General requirements for electrical equipment

REVISED TEXT

The 1990 edition of AS 3100, which was amended in October 1990, is further amended as follows; the amendment(s) should be inserted in the appropriate place.

SUMMARY: This Amendment applies to Clause 2.53.

Published on 25 January 1991.

æ

AS 3100-1990

Australian Standard®

Approval and test specification— General requirements for electrical equipment

First published as AS C100—1937. Second edition 1940. Third edition 1953. Fourth edition 1964. Fifth edition 1971. Sixth edition 1972. Revised and redesignated as AS 3100-1982. Second edition 1985. Third edition 1990.

0

PUBLISHED BY STANDARDS AUSTRALIA (STANDARDS ASSOCIATION OF AUSTRALIA) STANDARDS HOUSE, 80 ARTHUR ST, NORTH SYDNEY NSW

ISBN 0 7262 6246 3

PREFACE

This Specification was prepared by Standards Australia Committee on Electrical Approvals Standards to supersede AS 3100-1985 from the date of publication.

This general Specification is the parent Specification of a series of Approval and Test Specifications. As outlined in the Foreword, these Specifications are intended to prescribe the essential safety requirements for materials and equipment to be used in electrical installations complying with AS 3000. This edition was published to incorporate into the Specification Amendments No 1 to 7 to

AS 3100-1985 and to effect changes to the following:

- a. GENERAL. Title changed. The word 'equipment' has been used throughout the Specification where the requirements apply to all devices. The terms 'basic' and 'supplementary' are now used in regard to insulation.
- b. SECTION 0. This Section has been removed but all the information contained therein has been included in a new Foreword or Section 1.
- c. SECTION 2. A number of definitions have been added. Also some unused terms have been deleted.
- d. Table 5.7 replaced.
- e. Clause 7.5. Dimensions for Class II symbol added.
- f. Clause 8.3.2 replaced.
- g. Clause 8.5 replaced.
- h. Clause 8.8 added.
- i. Clause 8.15 added.
- j. Appendix B replaced.
- k. Appendix C replaced.

The Association desires to call attention to the fact that this Standard does not purport to include all the necessary provisions of a contract.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the Head Office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

÷

CONTENTS

		2												Page
FOREW	/ORD		•••	••••		••••	••••	••••			••••	••••		6
SECTIC	ON 1. SCOPE A	ND GI	ENE	RAL										
1.1	SCOPE			••••				••••				••••		7
1.2	APPLICATION			••••									••••	7
1.3	REFERENCED	DOCU	MEN	VTS										7
1.4	ACCEPTANCE													7
OF OT IC														
SECTIC	DN 2. DEFINIT	IONS												_
2.1	GENERAL	••••	•••	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	8
2.2	ACCESSORY	•••••	•••	••••	••••	••••		••••	••••	••••	••••	••••	••••	8
2.3	ACTIVE (OR AC	CTIVE	CON	IDUC	TOR)	•••••	••••	••••	••••	••••	••••	••••	••••	8
2.4	APPLIANCE	••••	•••	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	8
2.5	CABLE	•••••	•••	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	8
2.6	CABLE CORE	•••••	•••	••••	••••	••••	••••	••••	••••		••••	••••	••••	8
2.7	CABLE, FLEXI	BLE .	•••	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	8
2.8	CIRCUIT-BREA	KER .	•••	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	8
2.9	CLASS I EQUIP	MENT	••••	••••	••••	••••	••••	••••	••••	••••		••••	••••	8
2.10	CLASS II EQUI	PMEN	Т	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	8
2.11	CLASS III EQU	IPMEN	JT	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	8
2.12	CLEARANCE		•••	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	9
2.13	CONDUCTOR		•••	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	9
2.14	CONDUCTOR,	BARE	••••	••••		••••	••••	••••	••••	••••	••••	••••	••••	9
2.15	CORD, FLEXIB	LE .	•••	••••	••••	••••	••••	••••	••••	••••	••••		••••	9
2.16	CORD, POWER	SUPP	LY	••••	••••	••••	••••	••••	••••	••••	••••	••••	••••	9
2.17	CREEPAGE DIS	STANC	E	••••	••••	••••	••••	••••	••••		••••			9
2.18	DISRUPTIVE DI	ISCHA	RGE		·	•••••		••••	••••	••••	••••	••••	••••	9
2.19	EARTHED		•••	••••		••••	••••	••••	••••	••••	••••	••••	••••	9
2.20	EARTHING CO	NDUC	TOR	L		••••		••••		••••		••••		9
2.21	EQUIPMENT		•••	••••		••••	••••	••••		••••			••••	9
2.22	EQUIPMENT W	IRING				••••		••••			••••			9
2.23	EXPOSED MET	`AL.			••••	••••		••••				••••	••••	9
2.24	FAULT-CURRE	NT LI	MIT	ĒR	••••	••••		••••		••••	••••			10
2.25	FIXED EQUIPM	IENT		••••		••••	••••	••••				••••	••••	10
2.26	FUSE (FUSIBLE	CUTO	UT)	••••		••••			••••			· ••••		10
2.27	HEATING ELEN	MENT	••••	••••	••••	••••		••••						10 -
2.28	INSULATED			••••					••••					10
2.29	INSULATION S	YSTEN	Л	••••					••••					10
2.30	LAMP HOLDER	R, ALL	INS	SULA	TED	••••	••••	••••	••••	••••		••••	••••	• 10
2.31	LIVE (ALIVE)			••••		••••		••••				••••		10
2.32	LUMINAIRE (L	IGHTI	NG	FITT	ING)	••••		••••	••••			••••		10
2.33	NEUTRAL (NE	UTRAL	. CC	ONDL	јсто	r or	R MID)-WIR	lE)	••••		••••		- 11
2.34	NON-HYGROSC	OPIC				••••		••••		••••				11
2.35	POLYPHASE (N	AULTI	PH	ASE)		••••		••••	••••	••••		••••		11
2.36	PORTABLE EC	QUIPM	ENI			••••			••••					11
2.37	SAFEGUARDEI) (GUA	ARD	ED)				••••	••••	••••	••••			11
2.38	SAFETY EXTRA	-LOW	VO	LTAC	E SU	PPLY	7	••••			••••			11
2.39	SAFETY ISOLA	TING	TRA	NSF	ORM	ER	••••				••••			11
2.40	STATIONARY I	EQUIP	MEI	NT		••••	••••		••••	,		•••• .		11
2.41	SCREWLESS TH	ERMIN	AL	•••••	••••	••••	••••			*		••••		11
2.42	SWITCH-CAT	EGORY	Y 1	••••		••••		····			••••			- 11
2.43	SWITCH-CAT	EGOR	Y 2									••••		11
2.44	SWITCH-CAT	EGOR	X 3			••••		••••	•••••			••••		11
													(con	tinued)

.

.

•

					Page
2.45	SWITCH, SINGLE-POLE	••••			11
2.46	SWITCH, MULTI-POLE	••••	••••	••••	11
2.47	TEMPERATURE LIMITER	••••	••••	••••	11
2.48	THERMAL CUTOUT			••••	11
2.49	THERMAL CUTOUT, NON-SELF-RESETTING	••••	••••	••••	11
2.50	THERMAL CUTOUT, SELF-RESETTING	••••	••••	••••	11
2.51	THERMOSTAT	••••	••••	••••	11
2.52	TOOL	••••	••••	••••	11
2.53	TRIP-FREE	••••	••••		12
2.54	VOLTAGE ¹	••••	••••	••••	12
SECTION	ON 3. DESIGN AND CONSTRUCTION				
3.1	GENERAL				13
3.2	EQUIPMENT TO BE SUITABLE FOR CONDITIONS OF USE				13
3.3	SELECTION OF MATERIALS, PARTS, ETC		•••••		13
3.4	SELECTION OF COMPONENTS				13
3.5	WORKMANSHIP		••••		13
3.6	FUSES		••••		13
3.7	IDENTIFICATION OF WIRING		••••		14
3.8	REGULATING DEVICES AND SWITCHES	••••	••••	••••	14
3.9	SOCKET-OUTLETS	••••		••••	15
3.10	EQUIPMENT INTENDED TO BE SUPPORTED BY CONTACT	'S OF	SOCK	ET-	
		••••	••••	••••	15
3.11	D C COMPONENT EDOM A C FOUNDMENT	••••	••••	••••	15
3.12	D.C. COMPONENT FROM A.C. EQUIPMENT	••••	••••	••••	15
3.13	STABILITY	••••	••••	••••	10
5.14	EQUIPMENT CONNECTED TO SUPPLY BY A PLUG				10
SECTIO	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT	RICA	L FAI	LURE	E
SECTIO 4.1	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA	L FAI	LURE	E 17
SECTIO 4.1 4.2	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAR	RICA BLES	L FAI	LURE	17 18
SECTIO 4.1 4.2 4.3	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAR TERMINALS AND CONNECTING FACILITIES FOR SUPPLY	RICA BLES CONE	L FAI	LURE	17 17 18 18
SECTIO 4.1 4.2 4.3 4.4	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAR TERMINALS AND CONNECTING FACILITIES FOR SUPPLY FLEXIBLE CORD AND CONNECTING PLUG	RICA BLES CONE	L FAI	LURE DRS 	17 18 18 18 22
SECTIO 4.1 4.2 4.3 4.4 4.5	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAR TERMINALS AND CONNECTING FACILITIES FOR SUPPLY FLEXIBLE CORD AND CONNECTING PLUG SUPPLY CONNECTION AND EXTERNAL FLEXIBLE CABLE	RICA BLES CONE S ANI	L FAI	LURE	17 18 18 22 22
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAR TERMINALS AND CONNECTING FACILITIES FOR SUPPLY FLEXIBLE CORD AND CONNECTING PLUG SUPPLY CONNECTION AND EXTERNAL FLEXIBLE CABLE JOINTS AND CONNECTIONS	RICA BLES CONE S ANI	L FAI	LURE DRS RDS 	17 18 18 22 22 24
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAR TERMINALS AND CONNECTING FACILITIES FOR SUPPLY FLEXIBLE CORD AND CONNECTING PLUG SUPPLY CONNECTION AND EXTERNAL FLEXIBLE CABLE JOINTS AND CONNECTIONS STRENGTH OF SCREW THREADS AND FIXINGS	RICA BLES CONE S ANI 	L FAI DUCTO D COI	LURE DRS RDS 	17 18 18 22 22 24 24 24
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAR TERMINALS AND CONNECTING FACILITIES FOR SUPPLY FLEXIBLE CORD AND CONNECTING PLUG SUPPLY CONNECTION AND EXTERNAL FLEXIBLE CABLE JOINTS AND CONNECTIONS	RICA BLES CONE S ANI 	L FAI DUCTO D COI 	LURE DRS RDS 	17 18 18 22 22 24 24 24 24
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI	L FAI DUCTO D COI 	LURE DRS XDS 	17 18 18 22 22 24 24 24 24 25
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAE TERMINALS AND CONNECTING FACILITIES FOR SUPPLY OF FLEXIBLE CORD AND CONNECTING PLUG SUPPLY CONNECTION AND EXTERNAL FLEXIBLE CABLE JOINTS AND CONNECTIONS STRENGTH OF SCREW THREADS AND FIXINGS SPACE-THREADED AND THREAD-CUTTING SCREWS DIRECT CONNECTION TO FIXED WIRING	RICA BLES CONE S ANI 	L FAI DUCTO D COI 	LURE DRS RDS 	17 18 18 22 22 24 24 24 24 25 25
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAR TERMINALS AND CONNECTING FACILITIES FOR SUPPLY OF FLEXIBLE CORD AND CONNECTING PLUG	RICA BLES CONE S ANI 	L FAI DUCTO D COI 	LURE DRS XDS 	17 18 18 22 24 24 24 24 25 25
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAR TERMINALS AND CONNECTING FACILITIES FOR SUPPLY OF FLEXIBLE CORD AND CONNECTING PLUG	RICA BLES CONE S ANI 	L FAI	LURE	17 18 18 22 22 24 24 24 24 25 25 25
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI 	L FAI	LURE	17 18 18 22 22 24 24 24 24 25 25 26 26
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING MECHANICAL PROTECTION OF CONDUCTORS AND CAE TERMINALS AND CONNECTING FACILITIES FOR SUPPLY OF FLEXIBLE CORD AND CONNECTING PLUG	RICA BLES CONE S ANI 	L FAI DUCTO D COI 	LURE DRS 2DS 	2 17 18 18 22 24 24 24 25 25 26 26 27
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI 	L FAI DUCTO D COI 	LURE DRS RDS 	2 17 18 18 22 24 24 24 24 25 25 26 26 27 28
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI 	L FAI DUCTO D COI 	LURE DRS 2DS 	E 17 18 18 22 24 24 24 24 25 25 26 26 27 28 29
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5 5.6	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI 	L FAI DUCTO D COI 	LURE DRS 2DS 	E 17 18 18 22 24 24 24 24 24 25 25 26 26 27 28 29 29 29
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5 5.6 5.7	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI 	L FAI	LURE DRS 2DS 	17 18 18 22 24 24 24 24 24 25 25 26 26 27 28 29 29 20
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI 	L FAI DUCTO D COI 	LURE DRS 2DS 	2 17 18 18 22 24 24 24 24 25 25 26 26 27 28 29 29 30 32
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8 5.9	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI 	L FAI DUCTO D COI D COI 	LURE DRS 2DS 	2 17 18 18 22 24 24 24 24 25 25 26 26 27 28 29 29 30 32 32
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8 5.9 5.10	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI 	L FAI DUCTO D COI D COI 	LURE DRS 2DS 2DS 	2 17 18 18 22 24 24 24 24 24 25 25 26 26 27 28 29 30 32 32 32
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8 5.9 5.10	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI S ANI S ANI S ANI 	L FAI DUCTO D COI D COI 	LURE DRS 2DS 2DS 	E 17 18 18 22 24 24 24 24 24 25 25 26 26 27 28 29 29 30 32 32 32
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8 5.9 5.10 SECTIO	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI S ANI S ANI 	L FAI DUCTO D COI 	LURE DRS RDS RDS 	E 17 18 18 22 24 24 24 25 25 26 26 26 27 28 29 29 30 32 32 32
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8 5.9 5.10 SECTIO 6.1	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI 	L FAI DUCTO D COI D COI 	LURE DRS 2DS 2DS 	E 17 18 18 22 24 24 24 24 24 25 25 26 26 26 26 27 28 29 29 30 32 32 32 32 32
SECTIO 4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 SECTIO 5.1 5.2 5.3 5.4 5.5 5.6 5.7 5.8 5.9 5.10 SECTIO 6.1 2 6.2	ON 4. PROTECTION AGAINST MECHANICAL AND ELECT PREVENTION OF SHORT-CIRCUIT AND ARCING	RICA BLES CONE S ANI S ANI 	L FAI DUCTO D COI D COI 	LURE DRS 2DSS 2DSS	2 17 18 18 22 24 24 24 24 25 25 26 26 27 28 29 29 30 32 32 32 34 35

.

(continued)

•

iπ.

•

. . .

.

SECTI	ON 7. MARKING	Page
7.1	INFORMATION TO BE MARKED	
7.2	METHOD OF MARKING	37
7.3	DOUBLE MARKING	37
7.4	MARKING OF FARTH CONNECTIONS	38
7.5	MARKING OF CLASS IL FOLIDMENT	38
7.6	MARKING OF LIVE SUDDI V CONNECTIONS	38
7.7	ADDITIONAL MARKING OF MULTI PATED FOURMENT	38
7.8	FOUIPMENT WITH TYPE M. VAND 7 ATTACHMENT	38
7.9	LEGIBILITY OF MARKING	39
7.10	INSTRUCTIONS FOR INSTALLATION AND USE	39
	INSTRUCTIONS FOR INSTALLATION AND USE	39
SECTION	ON 8. TESTS	•
8.1	TESTING—GENERAL	40
8.2	VOID	40
8.3	INSULATION RESISTANCE AND LEAKAGE CURRENT	40
8.4	HIGH VOLTAGE (ELECTRIC STRENGTH) TEST	40
8.5	TEST OF EARTHING CONNECTION	44
8.6	CORD ANCHORAGE	4J 45
8.7	TEST FOR SCREW THREADS AND FIXINGS (SEE CLAUSE 4 7)	45
8.8	MECHANICAL STRENGTH TEST	40
8.9	STANDARD ELECTRODES FOR ELECTRIC STRENGTH TESTS	40
8.10	STANDARD TEST FINGER	47
8.11	TEMPERATURE MEASUREMENTS	47
8.12	TEMPERATURE AND FIRE RISK TEST	50
8.13	TEST OF MARKING	51
8.14	STABILITY TEST	51
8.15 ·	ABNORMAL OPERATION	51
APPEN	DICES	51
	EASUREMENT OF CREEPAGE DISTANCES AND CLEARANCES	55
	KE HAZARD TESTING OF ELECTRICAL EQUIPMENT SEE AMENDMENT (59
	FORMATION ON THE SAFETY PRINCIPLES OF DESIGN AND TESTING OF	
EN	ICASED CLASS IL CONSTRUCTION	
D CH	RCUIT FOR MEASURING LEAKAGE CURRENTS	61
E LIS	ST OF REFERENCED DOCUMENTS	67
		68

AMDT No. 6 JULY	Page 4 Contents Delete existing SECTION 6 and substitute the following: SECTION 6 RESISTANCE TO HEAT, FIRE AND TRACKING							
	This Amendment forms part of the Specification 2 years from publication.							
AMDT No. 6 JULY 1994	Page 5 Contents							
	Delete existing Appendix B and substitute the following:							

.

This Amendment forms part of the Specification 2 years from publication.

.

.

.

.

FOREWORD

1 HISTORICAL DEVELOPMENT. In the first edition of the SAA Wiring Rules, published in 1931, safety requirements concerning the design and construction of electrical materials and equipment were included among rules dealing with wiring methods. In the first revised edition, published in 1934, the rules were grouped in two parts, Part I (later Part 1) containing requirements concerning wiring methods, and Part II (later Part 2) containing requirements concerning materials and equipment. In the 1940 revision, this subdivision was carried a stage further, Part I being published as one complete book and Part II taking the form of a collection of specifications.

The purpose of the Specifications which constituted Part 2 of the SAA Wiring Rules was to outline conditions which electrical equipment had to meet to be used in electrical installations in Australia. These Specifications were prepared, up until the early 1970s, by the Association's Electrical Approvals Standards Committee. However, owing to the rapid expansion in the number and complexity of these specifications, this system has been abandoned and a number of committees now prepare Approval and Test Specifications and other Specifications containing safety requirements.

In the 1981 edition of AS 3000, the concept of Parts 1 and 2 to the SAA Wiring Rules was abandoned, with the former Part 1 now being titled 'SAA Wiring Rules' and all applicable Approval and Test Specifications and other applicable Standards being called up by means of Clause 1.3.1 of AS 3000.

2 TYPES OF SPECIFICATIONS. There are two different types of Approval and Test Specifications, as follows:

- (a) General Specifications.
 - (i) AS 3100, Approval and Test Specification for General Requirements for Electrical Equipment.
 - (ii) AS 3200, Approval and Test Specification for Electromedical Equipment—General Requirements.
 - (iii) AS 3300, Approval and Test Specification for General Requirements for Household and Similar Electrical Appliances.
- (b) *Particular Specifications*. These are particular Specifications that are related to AS 3100, AS 3200 or AS 3300.

AS 3100 includes general requirements applicable to all electrical equipment and the related particular Specifications contain additional requirements for particular types of equipment. AS 3100 may be satisfactorily used as a Specification for equipment which is not covered by a related particular Specification.

AS 3200, which is to be read in conjunction with AS 3100, includes general requirements applicable to all electromedical equipment, and the related particular specifications contain additional requirements for particular types of equipment. AS 3200 may be satisfactorily used as a Specification for equipment which is not covered by a related particular Specification.

AS 3300 contains a wide range of requirements, all of which may not necessarily be applicable to a particular appliance. A particular Specification converts AS 3300 into the Specification for the type of appliance being considered; it does this by indicating, clause by clause, whether or not the requirements and test methods are applicable in whole or in part, or whether they should be replaced, modified or supplemented. Whereas AS 3100 may be satisfactorily used as a Specification for equipment for which there is no particular Specification related to AS 3100, it is not practicable to use AS 3300 in a similar manner; it may, however, be used as a guide by taking into account particular Specifications related to AS 3300 for a similar appliance.

3 RATIONALE. Approval and Test Specifications are intended to prevent injury to persons and damage to property by establishing essential requirements and safety Standards for materials and for the design and construction of equipment used in or in connection with or intended for use in or in connection with any electrical installation.

STANDARDS AUSTRALIA

Australian Standard

Approval and test specification—

General requirements for electrical equipment

SECTION 1. SCOPE AND GENERAL

1.1 SCOPE. This Specification specifies the general safety requirements for, or with respect to, equipment (including fittings, accessories, appliances and apparatus) of classes and types which are used, or intended for use in or in connection with electrical installations in buildings, structures, and premises.

Guidelines covering design and testing of electrical equipment to ensure safety and protection against electric shock including the principles and application of double insulation are contained in Appendix C. Guidelines covering fire hazard testing of electrical equipment are contained in Appendix B. Users may find it helpful to study these appendices before reading the main body of this Specification.

1.2 APPLICATION. As and when an individual Approval and Test Specification dealing with specific features of the design and construction and the testing of any particular class or type of equipment is issued, it shall supersede those general requirements of this Specification which are specifically dealt with in such individual Specification.

Any material, fitting, cable, accessory, appliance or apparatus used in or in connection with an electrical installation shall comply with the appropriate particular Approval and Test Specification or with the appropriate Australian Standard. In the absence of any such Specification or Standard, the appropriate provisions of this Specification shall apply.

Should any requirement of an individual Specification differ from any of the general requirements of this Specification, the requirement of the individual Specification shall prevail.

1.3 REFERENCED DOCUMENTS. A list with titles of the documents referred to in this Specification is given in Appendix E.

1.4 ACCEPTANCE.

1.4.1 Declared type or class. In every State and Territory of Australia, legislation has been enacted which requires that electrical equipment of a declared type or class shall not be marketed unless approved by the relevant Regulatory Authority in that State or Territory. In accordance with reciprocal arrangements, an approval given in any one State or Territory is automatically accepted by the remaining States or Territories. The submission for approval is made in the 'home' State or Territory, i.e. the State or Territory of manufacture, or of import for overseas equipment. In general, the basis of approval for the purposes of the legislation is the series of Approval and Test Specifications listed in Paragraph A2 of AS 3000.

The certificate issued by the Regulatory Authority is known as a 'Certificate of Approval'.

1.4.2 Non-declared type or class. Equipment of a type or class which is not declared in any State or Territory may be submitted voluntarily to a Regulatory Authority for an opinion as to its compliance with the applicable Approval and Test Specification or the appropriate safety requirements of an Australian standard.

The certificate issued by the Regulatory Authority is known as a 'Certificate of Suitability'.

1.4.3 In terms of AS 3000. In terms of Clause 1.3.2 of AS 3000, the Inspecting Authority may require proof that any material or equipment, before it is used in or in connection with an electrical installation, has been accepted as complying with the relevant requirements of the appropriate Approval and Test Specification or other appropriate Australian Standard.

NOTE: See Clause 1.3 and Appendix A of AS 3000 for further details.

1.4.4 Enquiries. Enquiries concerning approval of equipment may be made to the following regulatory authorities:

Australian Capital Territory Electricity & Water Authority Department of Minerals and Energy, New South Wales Electricity Trust of South Australia Hydro-Electric Commission of Tasmania Queensland Electricity Commission State Electricity Commission of Victoria State Energy Commission of Western Australia