

**ASME B73.3-2022**  
(Revision of ASME B73.3-2015)

# **Specification for Sealless Horizontal End Suction Centrifugal Pumps for Chemical Process**

---

**AN AMERICAN NATIONAL STANDARD**



**The American Society of  
Mechanical Engineers**

**ASME B73.3-2022**  
(Revision of ASME B73.3-2015)

# **Specification for Sealless Horizontal End Suction Centrifugal Pumps for Chemical Process**

---

**AN AMERICAN NATIONAL STANDARD**



**The American Society of  
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: June 30, 2023

This Standard will be revised when the Society approves the issuance of a new edition.

This standard was developed under procedures accredited as meeting the criteria for American National Standards. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark

“ASME” and the above symbol are registered trademarks of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form,  
in an electronic retrieval system or otherwise,  
without the prior written permission of the publisher.

The American Society of Mechanical Engineers  
Two Park Avenue, New York, NY 10016-5990

Copyright © 2023 by  
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS  
All rights reserved

# CONTENTS

Foreword .....		v
Committee Roster .....		vi
Correspondence With the B73 Committee .....		vii
<b>1</b>	<b>Scope .....</b>	<b>1</b>
<b>2</b>	<b>References .....</b>	<b>1</b>
<b>3</b>	<b>Alternative Designs .....</b>	<b>3</b>
<b>4</b>	<b>Nomenclature and Definitions .....</b>	<b>3</b>
<b>5</b>	<b>Design and Construction Features .....</b>	<b>22</b>
<b>6</b>	<b>General Information .....</b>	<b>40</b>
<b>7</b>	<b>Documentation .....</b>	<b>45</b>
 <b>Mandatory Appendix</b>		
I	ASME Sealless Centrifugal Pump Data Sheet .....	51
 <b>Nonmandatory Appendix</b>		
A	Electronic Data Exchange .....	59
 <b>Figures</b>		
5.3.7.1-1	Cooling and Heating Piping Plans .....	24
5.4.2-1	Impeller Dimensions to Determine Single-Plane or Two-Plane Balance .....	25
5.5.5.5-1	Plan 114 Modified .....	27
5.17.4-1	CMP Vibration Measurement Locations .....	40
7.3.1-1	Pump and Driver Outline Drawing for MDP .....	46
7.3.1-2	Pump and Driver Outline Drawing for CMP .....	47
 <b>Tables</b>		
1-1	Pump Dimensions for Flexibly Coupled Magnetic Drive Pumps (U.S. Customary) .....	4
1-1M	Pump Dimensions for Flexibly Coupled Magnetic Drive Pumps (SI) .....	6
1-2	Baseplate Dimensions for Flexibly Coupled Magnetic Drive Pumps (U.S. Customary) .....	8
1-2M	Baseplate Dimensions for Flexibly Coupled Magnetic Drive Pumps (SI) .....	10
1-3	Baseplate Dimensions for Close-Coupled Magnetic Drive Pumps (U.S. Customary) .....	12
1-3M	Baseplate Dimensions for Close-Coupled Magnetic Drive Pumps (SI) .....	13
1-4	Pump Dimensions for Canned Motor Pumps (U.S. Customary) .....	14
1-4M	Pump Dimensions for Canned Motor Pumps (SI) .....	16
1-5	Baseplate Dimensions for Canned Motor Pumps (U.S. Customary) .....	18
1-5M	Baseplate Dimensions for Canned Motor Pumps (SI) .....	20
5.10.1.2-1	Magnetic Drive and Canned Motor Pump Material Classification Codes .....	31
5.10.1.2-2	Magnetic Drive Pump Example: MDP-316-B-A-A-C-T-V-S .....	33

5.10.1.2-3	Canned Motor Pump Example: CMP-316-B-H-C-C-T-K .....	33
5.10.1.3-1	ASTM Material Specifications .....	34
5.11.1-1	Minimum Requirements for Auxiliary Piping Materials .....	35
5.15.1-1	Welding Requirements .....	36
6.1.8.1.1-1	Published Performance Curve Rated Speeds .....	41
6.2.2.3-1	Specified Nondestructive Testing Levels .....	44
7.3.1-1	Tapped Opening Markings .....	48
 <b>Forms</b>		
I-1	Sealless Centrifugal Pump Data Sheet (U.S. Customary) .....	52
I-1M	Sealless Centrifugal Pump Data Sheet (SI) .....	55

# FOREWORD

In 1991, ASME Standards Committee B73, Chemical Standard Pumps, formed a sealless pump working group to develop a standard for sealless pumps that would correspond to ASME B73.1M, Specification for Horizontal End Suction Centrifugal Pumps for Chemical Process.

Though these pumps are sealless (i.e., they do not use a dynamic seal to prevent leakage around the drive shaft), leakage can result from certain types of wear or misoperation. The user must take appropriate supplemental safety precautions when operating these pumps.

The first edition of this Standard was approved as an American National Standard by the American National Standards Institute (ANSI) on August 7, 1997.

In the following years, the sealless working group developed a revision of ASME B73.3M to reflect changes made in ASME B73.1M. In the 2003 revision of ASME B73.3, the presentation of units was changed to reflect that U. S. Customary units are the primary units of measurement. Some paragraphs were simplified and clarified and the sections on flanges and flange loading were revised, as were sound and vibration requirements. Information concerning “Operating Region” and “NPSH Margin” was added; auxiliary connection symbols and additional pump sizes were also added. Table 3 was revised to reflect changes in Frame 1 pump dimensions; Table 7 was added; and Form 1 was revised to reflect additional required values.

The 2015 revision of the Standard included several changes to reduce redundancy in ASME B73 standards and to better align with Hydraulic Institute standards (HI). Revisions were also made to further improve the reliability of ASME B73.3 pumps. Reference is now made to the HI standard for fluid circulation piping plans and a material classification code was added to ASME B73.3. The table for ASTM material specifications was expanded; a table for minimum requirements for auxiliary piping materials added; requirements for the bearing frame revised to assure more robust pumps; and plastic-lined magnetic drive pumps added to the scope of the standard. Close-coupled pumps were also added as an option and close-coupled pump baseplates shortened accordingly. The default performance test acceptance grade was revised to reflect the new HI/ISO performance test standard. More detail was added to the required drawings, curve, and documentation included with the pump and a new data sheet was developed and added to the standard. ASME B73.3 endorses the Electronic Data Exchange standard developed by HI and the FIATECH Automating Equipment Information Exchange (AEX) project.

Many of the modifications to the 2022 edition of this Standard align the requirements of ASME B73.3 with the 2020 revision of ASME B73.1. Revisions to ASME B73.3 include

- (a) modified canned motor pump stator liner material, rotor liner material, and construction requirements
- (b) new functional life requirement for canned motor pump (CMP) secondary control systems
- (c) modified external bearing design requirements and clarified external bearing life requirements
- (d) new and clarified requirements for greased for life external bearings
- (e) modified magnetic drive pump (MDP) and CMP material classification codes including adding new materials such as Alloy C22 as well as many new wetted bearing materials
- (f) new requirements for auxiliary piping
- (g) new corrosion allowances
- (h) new welding requirements including details on autogenous welding
- (i) revised safety guard and coupling guard requirements
- (j) additional baseplate options and requirements including nonmetallic baseplates and free-standing baseplates
- (k) close-coupled motor adaptor requirements for MDPs
- (l) modified requirements for vibration to reference HI standards
- (m) published performance curve rated speeds for MDPs and CMPs
- (n) details on hydrostatic test requirements along with adding thermoset polymer material pumps
- (o) modified pump performance requirements, including the acceptance test grade to ANSI/HI 14.6-2016 Grade 1B
- (p) modified connection welds and casting test requirements
- (q) modified nameplate requirements for MDP and CMP
- (r) details regarding document requirements, including details for Certified Mill Test Report and Statement of Compliance

ASME B73.3-2022 was approved by ANSI as an American National Standard on July 25, 2022.

# ASME B73 COMMITTEE

## Chemical Standard Pumps

(The following is the roster of the Committee at the time of approval of this Standard.)

### STANDARDS COMMITTEE OFFICERS

**R. W. Estep**, *Chair*  
**D. W. Wood**, *Vice Chair*  
**R. Ryan**, *Secretary*

### STANDARDS COMMITTEE PERSONNEL

**M. Basue**, John Crane  
**K. R. Burkhardt**, Consultant  
**S. Camara**, Cargill, Inc.  
**D. Clark**, HMD Sealless Pumps, Ltd.  
**R. W. Estep**, The Dow Chemical Co.  
**E. Eylat**, Flowserve Corp.  
**F. Hernandez**, Lewa-Nikkiso America, Inc.  
**J. Hubbard**, Goulds Pumps  
**M. B. Huebner**, Flowserve Corp.  
**I. S. James**, DXP Pumps and Pumpworks  
**R. McKillips**, IFF Nutrition and Biosciences

**B. S. Myers**, Bayer Crop Science  
**R. Ryan**, The American Society of Mechanical Engineers  
**C. Sakhalkar**, Teikoku USA  
**D. W. Wood**, The Chemours Co.  
**G. R. Frantz**, *Alternate*, The Chemours Co.  
**B. Wells**, *Alternate*, Flowserve Corp.  
**A. Wilson**, *Alternate*, The Dow Chemical Co.  
**P. J. Yehl**, *Alternate*, ITT Goulds Pumps  
**P. F. Gaydon**, *Contributing Member*, Hydraulics Institute  
**J. S. Simmons III**, *Contributing Member*, Occidental Oil and Gas Corp.

### SUBCOMMITTEE 3 — HORIZONTAL SEALLESS END SUCTION PUMPS FOR CHEMICAL PROCESS

**D. W. Wood**, *Chair*, The Chemours Co.  
**D. Clark**, HMD Sealless Pumps, Ltd.  
**R. W. Estep**, The Dow Chemical Co.  
**G. R. Frantz**, The Chemours Co.  
**F. Hernandez**, Lewa-Nikkiso America, Inc.  
**M. Huebner**, Flowserve Corp.  
**I. S. James**, DXP Pumps and Pumpworks

**R. McKillips**, IFF Nutrition and Biosciences  
**B. S. Myers**, Bayer Crop Science  
**C. Sakhalkar**, Teikoku USA  
**A. Wilson**, The Dow Chemical Co.  
**P. Wilson**, Flowserve Corp.  
**P. J. Yehl**, ITT Goulds Pumps

## CORRESPONDENCE WITH THE B73 COMMITTEE

**General.** ASME codes and standards are developed and maintained by committees with the intent to represent the consensus of concerned interests. Users of ASME codes and standards may correspond with the committees to propose revisions or cases, report errata, or request interpretations. Correspondence for this Standard should be sent to the staff secretary noted on the committee's web page, accessible at <https://go.asme.org/B73committee>.

**Revisions and Errata.** The committee processes revisions to this Standard on a periodic basis to incorporate changes that appear necessary or desirable as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published in the next edition of the Standard.

In addition, the committee may post errata on the committee web page. Errata become effective on the date posted. Users can register on the committee web page to receive e-mail notifications of posted errata.

This Standard is always open for comment, and the Committee welcomes proposals for revisions. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent background information and supporting documentation.

### Cases

(a) The most common applications for cases are

(1) to permit early implementation of a revision based on an urgent need

(2) to provide alternative requirements

(3) to allow users to gain experience with alternative or potential additional requirements prior to incorporation directly into the Standard.

(4) to permit the use of a new material or process

(b) Users are cautioned that not all jurisdictions or owners automatically accept cases. Cases are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Standard.

(c) A proposed case shall be written as a question and reply in the same format as existing cases. The proposal shall also include the following information:

(1) a statement of need and background information

(2) the urgency of the case (e.g., the case concerns a project that is underway or imminent)

(3) the Standard and the paragraph, figure, or table number(s)

(4) the edition(s) of the Standard to which the proposed case applies

(d) A case is effective for use when the public review process has been completed and it is approved by the cognizant supervisory board. Approved cases are posted on the committee web page.

**Interpretations.** The committee does not issue interpretations for this Standard.

**Committee Meetings.** The B73 Standards Committee regularly holds meetings that are open to the public. Persons wishing to attend any meeting should contact the secretary of the committee. Information on future committee meetings can be found on the committee web page at <https://go.asme.org/B73committee>.



INTENTIONALLY LEFT BLANK

# SPECIFICATION FOR SEALLESS HORIZONTAL END SUCTION CENTRIFUGAL PUMPS FOR CHEMICAL PROCESS

## 1 SCOPE

(a) This Standard is a design and specification standard that covers metallic and plastic-lined sealless centrifugal pumps of horizontal, end-suction single-stage, centerline discharge design. This Standard includes dimensional interchangeability requirements and certain design features to facilitate installation and maintenance and enhance reliability and safety of ASME B73.3 pumps. It is the intent of this Standard that pumps of the same standard dimension designation from all sources of supply shall be interchangeable with respect to mounting dimensions, size, and location of suction and discharge nozzles, input shafts, baseplates, and foundation bolt holes [see [Tables 1-1](#) through [1-5](#) ([Tables 1-1M](#) through [1-5M](#))]. Maintenance and operation requirements are not included in this Standard.

(b) This Standard has been revised to broaden the scope to include specialty designs developed for ASME B73.3 product line platforms. These specialty designs have many components in common with the ASME B73.3 models and meet the intent of the standard but not the standard's dimensional requirements. These specialty designs include pump models referred to as self-primer and single-stage low flow pumps.

## 2 REFERENCES

The following is a list of publications referenced in this Standard. Unless otherwise specified, the latest edition shall apply.

- ANSI B11.19. Performance Requirements for Risk Reduction Measures: Safeguarding and other Means of Reducing Risk. American National Standards Institute.
- ANSI/ABMA 9. Load Ratings and Fatigue Life for Ball Bearings. American Bearing Manufacturers Association.
- ANSI/ABMA 11. Load Ratings and Fatigue Life for Roller Bearings. American Bearing Manufacturers Association.
- ANSI/AWS D1.1. Structural Welding Code — Steel. American Welding Society.
- ANSI/HI 1.3. Rotodynamic Centrifugal Pumps for Design and Applications. Hydraulic Institute.
- ANSI/HI 1.4. Rotodynamic Centrifugal Pumps for Manuals Describing Installation, Operation, and Maintenance. Hydraulic Institute.
- ANSI/HI 5.1–5.6. Sealless Rotodynamic Pumps for Nomenclature, Definitions, Applications, Operation, and Test. Hydraulic Institute.
- ANSI/HI 9.1–9.5. Pumps — General Guidelines for Materials, Sound Testing, and Decontamination. Hydraulic Institute.
- ANSI/HI 9.6.1. Rotodynamic Pumps — Guideline for NPSH Margin. Hydraulic Institute.
- ANSI/HI 9.6.2-2021. Rotodynamic Pumps for Assessment of Applied Nozzle Loads. Hydraulic Institute.
- ANSI/HI 9.6.4. Rotodynamic Pumps for Vibration Measurements and Allowable Values. Hydraulic Institute.
- ANSI/HI 9.6.8. Rotodynamic Pumps — Guidelines for Dynamics of Pumping Machinery. Hydraulic Institute.
- ANSI/HI 14.3. Rotodynamic Pumps for Design and Application. Hydraulic Institute.
- ANSI/HI 14.6. Rotodynamic Pumps for Hydraulic Performance Acceptance Tests. Hydraulic Institute.
- ANSI/HI 50.7. Electronic Data Exchange for Pumping Equipment. Hydraulic Institute.
- ASME B16.5. Pipe Flanges and Flanged Fittings: NPS ½ through NPS 24 Metric/Inch Standard. The American Society of Mechanical Engineers.
- ASME B16.11. Forged Fittings, Socket-Welding and Threaded. The American Society of Mechanical Engineers.
- ASME B16.42. Ductile Iron Pipe Flanges and Flanged Fittings, Classes 150 and 300. The American Society of Mechanical Engineers.
- ASME B31.3. Process Piping. The American Society of Mechanical Engineers.
- ASME Boiler and Pressure Vessel Code, Section II. Materials — Part D, Properties [(Customary) or (Metric)]. The American Society of Mechanical Engineers.
- ASME Boiler and Pressure Vessel Code, Section III. Rules for Construction of Nuclear Facility Components — Division 1, Subsection NCD, Class 2 and Class 3 Components. The American Society of Mechanical Engineers.