

Australian Standard[®]

**The storage and handling of
non-flammable cryogenic and
refrigerated liquids**

This Australian Standard was prepared by Committee CH/9, Safe Handling of Chemicals. It was approved on behalf of the Council of Standards Australia on 18 July 1997 and published on 5 November 1997.

The following interests are represented on Committee CH/9:

Air Conditioning and Refrigeration Wholesalers Association
Australasian Railway Association
Australian Chemical Specialties Manufacturers Association
Australian Conservation Foundation
Australian Council of Trade Unions
Australian Fire Authorities Council
Australian Institute of Petroleum
Australian Paint Manufacturers Federation
Department for Industrial Affairs, S.A.
Department of Defence, Australia
Department of Minerals and Energy, W.A.
Environment Protection Authority of N.S.W.
Institution of Engineers, Australia
Melbourne Water
National Occupational Health and Safety Commission, Australia
Plastics and Chemicals Industry Association, Australia
Victorian WorkCover Authority
Work Health Authority N.T.
WorkCover New South Wales
Workplace Standards Authority, Tasmania

Additional interests participating in preparation of Standard:

Manufacturers, distributors and industrial users of cryogenic and refrigerated liquids

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This Standard was issued in draft form for comment as DR 96189.

STANDARDS AUSTRALIA

RECONFIRMATION

OF

AS 1894—1997

The storage and handling of non-flammable cryogenic and refrigerated liquids

RECONFIRMATION NOTICE

Technical Committee CH-009 has reviewed the content of this publication and in accordance with Standards Australia procedures for reconfirmation, it has been determined that the publication is still valid and does not require change.

Certain documents referenced in the publication may have been amended since the original date of publication. Users are advised to ensure that they are using the latest versions of such documents as appropriate, unless advised otherwise in this Reconfirmation Notice.

Approved for reconfirmation in accordance with Standards Australia procedures for reconfirmation on 04 January 2021.

The following are represented on Technical Committee CH-009:

Accord Australasia Ltd

Australasian Fire and Emergency Service Authorities Council

Australasian Institute of Dangerous Goods Consultants

Australian Institute of Petroleum

Australian Logistics Council

Australian Paint Manufacturers Federation

Better Regulation Division

Chemistry Australia

ComCare (Commonwealth Government)

Department of Mines, Industry Regulation and Safety WA

Engineers Australia

Institution of Chemical Engineers

SafeWork SA

WorkSafe New Zealand

NOTES

Australian Standard[®]

**The storage and handling of
non-flammable cryogenic and
refrigerated liquids**

Originated as AS 1894—1976.
Second edition 1997.

Incorporating:
Amdt 1—1999

PREFACE

This Standard was prepared by the Standards Australia/Standards New Zealand Committee CH/9, Safe Handling of Chemicals, to supersede AS 1894—1976, *Code of practice for the safe handling of cryogenic fluids*.

This Standard deals with non-flammable cryogenic and refrigerated liquids of Class 2.2 (with or without Subsidiary Risk of 5.1), as classified in the UN *Recommendations on the Transport of Dangerous Goods* and listed in the ADG Code.

The Standard has been revised in order to ensure its technical information is in accordance with international best practices, and the opportunity has been taken to arrange the document into a format consistent with other Australian Standards for the storage and handling of dangerous goods.

The revision process has led to some major changes in this new edition, which are as follows:

- (a) Separation distances have been comprehensively reviewed. Particular attention has been paid to the separation of potential sources of leakage, such as valves and connections, and to the properties of the cryogenic and refrigerated liquids being stored.
- (b) The Sections addressing operational and personnel safety, emergency management, fire protection and disposal have been aligned with the requirements specified in other Australian Standards for the storage and handling of dangerous goods.
- (c) A Section dealing with the storage and handling of non-flammable cryogenic or refrigerated liquids in portable dewars and portable pressure flasks has been developed.
- (d) The title has been changed to better reflect the contents of the Standard and align it with the range of other Australian Standards for the storage and handling of dangerous goods.

The series covering the storage and handling of dangerous goods presently comprises the following Standards:

AS

- 1940 The storage and handling of flammable and combustible liquids
- 2022 Anhydrous ammonia—Storage and handling (known as the SAA Anhydrous Ammonia Code)
- 2507 The storage and handling of pesticides
- 2714 The storage and handling of hazardous chemical materials—Class 5.2 substances (organic peroxides)
- 2927 The storage and handling of liquefied chlorine gas
- 3780 The storage and handling of corrosive substances
- 3961 Liquefied natural gas—Storage and handling
- 4081 The storage, handling and transport of liquid and liquefied polyfunctional isocyanates
- 4326 The storage and handling of oxidizing agents
- 4332 The storage and handling of gases in cylinders

AS/NZS

- 1596 Storage and handling of LP Gas
- 4452 The storage and handling of toxic substances

This Standard is a result of a consensus amongst Australian and New Zealand representatives on the Joint Committee that it be produced as an Australian Standard.

The terms 'normative' and 'informative' have been used in this Standard to define the application of appendices to which they apply. A 'normative' appendix is an integral part of the Standard, whereas an 'informative' appendix is for information and guidance only.

Statements expressed in mandatory terms in notes to tables are deemed to be requirements of this Standard.

Notes that appear in the main text of this Standard are intended to provide information only.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE	7
1.2 APPLICATION	7
1.3 NEW DESIGNS AND INNOVATIONS	8
1.4 REFERENCED DOCUMENTS	8
1.5 DEFINITIONS	8
1.6 SECURITY OF STORAGE AREAS	10
SECTION 2 PORTABLE DEWARS AND PORTABLE PRESSURE FLASKS	
2.1 SCOPE OF SECTION	11
2.2 PRECAUTIONS FOR THE STORAGE AND HANDLING OF PORTABLE DEWARS AND PORTABLE PRESSURE FLASKS	11
SECTION 3 STORAGE VESSELS AND ANCILLARY EQUIPMENT	
3.1 SCOPE OF SECTION	12
3.2 APPLICATION	12
3.3 DESIGN REQUIREMENTS FOR BULK STORAGE VESSELS	12
3.4 TANK FOUNDATIONS AND SUPPORTS	12
3.5 LOCATION OF VESSELS	12
3.6 IDENTIFICATION OF PRODUCT AND EQUIPMENT	14
3.7 VALVES	14
3.8 RELIEF VALVES AND VENTS	14
3.9 TRANSFER AREA	15
3.10 PIPES, HOSES AND COUPLINGS	16
3.11 INSTRUMENTS AND VALVES	16
3.12 COMMISSIONING AND INSTALLATION	16
3.13 IN-SERVICE INSPECTION AND MAINTENANCE	16
3.14 DECOMMISSIONING	16
3.15 RE-EVALUATION	16
SECTION 4 SPECIAL REQUIREMENTS FOR LIQUID OXYGEN AND LIQUEFIED NITROUS OXIDE	
4.1 SCOPE OF SECTION	17
4.2 HAZARDS	17
4.3 LOCATION OF BULK LIQUID OXYGEN AND LIQUEFIED NITROUS OXIDE VESSELS	17
4.4 TRANSFER AREA	17
4.5 PERSONAL PROTECTION	17a
4.6 TOOLS	18
4.7 EQUIPMENT	18
4.8 CLEANING	18
4.9 MATERIALS	18
4.10 ELECTRICAL EQUIPMENT	18
4.11 LUBRICANTS	18

*Page*SECTION 5 SPECIAL REQUIREMENTS FOR NITROGEN, ARGON,
HELIUM AND CARBON DIOXIDE

5.1	SCOPE OF SECTION	23
5.2	GENERAL	23
5.3	OXYGEN ENRICHMENT	23
5.4	LOCATION OF BULK VESSELS	23
5.5	SPECIAL PRECAUTIONS FOR HELIUM	23
5.6	SPECIAL PRECAUTIONS FOR CARBON DIOXIDE	23

SECTION 6 OPERATIONAL AND PERSONNEL SAFETY

6.1	SCOPE OF SECTION	26
6.2	APPLICATION OF SECTION	26
6.3	GENERAL PRECAUTIONS	26
6.4	TRANSFER OPERATIONS	27
6.5	FILLING OPERATIONS	27
6.6	PERIODIC INSPECTION	27
6.7	SAFETY PROCEDURES FOR INSTALLATIONS AND THEIR MAINTENANCE	27
6.8	OPERATION OF THE INSTALLATION	28
6.9	PERSONNEL TRAINING	29
6.10	PERSONAL PROTECTIVE EQUIPMENT	30
6.11	FIRST AID	30

SECTION SECTION 7 EMERGENCY MANAGEMENT

7.1	SCOPE OF SECTION	31
7.2	PLANNING FOR EMERGENCIES	31
7.3	MANIFEST	32
7.4	PLACARDING	32
7.5	MANAGEMENT OF LEAKS AND SPILLS	33

SECTION 8 FIRE PROTECTION

8.1	SCOPE OF SECTION	34
8.2	GENERAL CONSIDERATIONS	34
8.3	FIRE PROTECTION MEASURES	34
8.4	FIRE PROTECTION REQUIREMENTS	35
8.5	WATER SUPPLY AND FIRE WATER RETENTION	36
8.6	ACTION IN THE EVENT OF FIRE	36

SECTION 9 DISPOSAL OF CRYOGENIC AND REFRIGERATED LIQUIDS

9.1	SCOPE OF SECTION	37
9.2	DISPOSAL	37

APPENDICES

A	PHYSICAL PROPERTIES OF LOW-TEMPERATURE LIQUEFIABLE GASES	38
B	HAZARDS ASSOCIATED WITH THE HANDLING OF CRYOGENIC OR REFRIGERATED LIQUIDS	39
C	REFERENCED AND RELATED DOCUMENTS	41
D	PROTECTION AGAINST VEHICULAR DAMAGE	44
E	VENTILATION	46
F	EMERGENCY INFORMATION PLACARD	47
G	MEDICAL TREATMENT	50
H	SAFETY PRECAUTIONS FOR ENTRY INTO STORAGE VESSELS	53
I	INFORMATION TO BE PROVIDED IN THE WORK PERMIT	54
J	EMERGENCY PROCEDURES	55
K	BIBLIOGRAPHY OF DOCUMENTS PROVIDING GUIDELINES ON THE PREPARATION OF EMERGENCY PLANS	57
L	INFORMATION TO BE MADE AVAILABLE TO EMERGENCY SERVICES	58
M	FIRE PROTECTION	59

STANDARDS AUSTRALIA

Australian Standard

**The storage and handling of non-flammable
cryogenic and refrigerated liquids**

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE This Standard sets out requirements and recommendations for the storage and handling of non-flammable cryogenic liquids at temperatures below -90°C and refrigerated liquids at or below -15°C , of Class 2.2, in quantities of at least 50 L water capacity and 50 kPa (gauge) working pressure, up to and including 200 000 L water capacity. It also provides guidelines for temporary installations.

Although carbon dioxide and nitrous oxide are not true cryogenic liquids, they are covered by this Standard. Refrigerant gases that have a halogenated hydrocarbon component are not intended to be covered by this Standard.

NOTES: The properties of low-temperature liquefiable gases covered by this Standard are outlined in Appendix A.

This Standard does not address the detailed design of vessels or equipment used for the production, transport and storage of cryogenic and refrigerated liquids, nor the precautions and equipment that might be necessary in large-scale production and processing plants.

NOTES:

- 1 Advice supplementary to that provided in this Standard might need to be sought from the supplier of the goods.
- 2 A discussion of the hazards presented by cryogenic and refrigerated liquids is provided in Appendix B.

The transport of cryogenic and refrigerated liquids is covered by the ADG Code. Requirements for road tankers for cryogenic liquids are addressed in AS 2809.6.

1.2 APPLICATION This Standard applies to the storage of non-flammable cryogenic and refrigerated liquids in pressure vessels that conform to AS 1210 or equivalent Standards. It also applies to the ancillary equipment associated with the installation.

This Standard applies in locations that are generally industrial or commercial in nature. In laboratories, the provisions of this Standard apply in addition to those of AS/NZS 2243.2 and AS 2243.10. In hospitals, the provisions of this Standard are in addition to those of AS 2896.

NOTES:

- 1 An installation can come under the regulatory control of several authorities having differing areas of responsibility, and an approval from one authority does not necessarily constitute an approval from the others.
- 2 Cognizance of the relevant requirements of the *Building Code of Australia* (BCA) is necessary for all matters relating to building works.

This Standard does not apply to home therapy, or to vessels of less than 50 L water capacity and less than 50 kPa (gauge); however, the safety precautions given in this Standard should be considered.