

CODE CASES

2023

ASME Boiler and
Pressure Vessel Code
An International Code

Nuclear Components

Markings such as “ASME,” “ASME Standard,” or any other marking including “ASME,” ASME logos, or the ASME Single Certification Mark shall not be used on any item that is not constructed in accordance with all of the applicable requirements of the Code or Standard. Use of the ASME Single Certification Mark requires formal ASME certification; if no certification program is available, such ASME markings may not be used. (For Certification and Accreditation Programs, see <https://www.asme.org/certification-accreditation>.)

Items produced by parties not formally possessing an ASME Certificate may not be described, either explicitly or implicitly, as ASME certified or approved in any code forms or other document.

AN INTERNATIONAL CODE

2023 ASME Boiler & Pressure Vessel Code

2023 Edition

July 1, 2023

CODE CASES

Nuclear Components



The American Society of
Mechanical Engineers

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: July 1, 2023

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark



ASME Single Certification Mark

“ASME” and the above ASME symbols are registered trademarks of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Library of Congress Catalog Card Number: 56-3934

Adopted by the Council of The American Society of Mechanical Engineers, 1914; latest edition 2023.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2023 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

TABLE OF CONTENTS

List of Sections	iv
Correspondence With the Committee	v
Summary of Changes	vii
Cross-Referencing in the ASME BPVC	ix
Notes to Numeric Index	x
Numeric Index	xi
Subject Index	xvii
Index of Material Specifications Referred to in Cases	xxiii
Applicability Index for Section XI Cases	xxvii
Guideline for Cross-Referencing Section XI Cases	xlvii

(23)

LIST OF SECTIONS

SECTIONS

- I Rules for Construction of Power Boilers

- II Materials
 - Part A — Ferrous Material Specifications
 - Part B — Nonferrous Material Specifications
 - Part C — Specifications for Welding Rods, Electrodes, and Filler Metals
 - Part D — Properties (Customary)
 - Part D — Properties (Metric)

- III Rules for Construction of Nuclear Facility Components
 - Subsection NCA — General Requirements for Division 1 and Division 2
 - Appendices
 - Division 1
 - Subsection NB — Class 1 Components
 - Subsection NCD — Class 2 and Class 3 Components
 - Subsection NE — Class MC Components
 - Subsection NF — Supports
 - Subsection NG — Core Support Structures
 - Division 2 — Code for Concrete Containments
 - Division 3 — Containment Systems for Transportation and Storage of Spent Nuclear Fuel and High-Level Radioactive Material
 - Division 4 — Fusion Energy Devices
 - Division 5 — High Temperature Reactors

- IV Rules for Construction of Heating Boilers

- V Nondestructive Examination

- VI Recommended Rules for the Care and Operation of Heating Boilers

- VII Recommended Guidelines for the Care of Power Boilers

- VIII Rules for Construction of Pressure Vessels
 - Division 1
 - Division 2 — Alternative Rules
 - Division 3 — Alternative Rules for Construction of High Pressure Vessels

- IX Welding, Brazing, and Fusing Qualifications

- X Fiber-Reinforced Plastic Pressure Vessels

- XI Rules for Inservice Inspection of Nuclear Reactor Facility Components
 - Division 1 — Rules for Inspection and Testing of Components of Light-Water-Cooled Plants
 - Division 2 — Requirements for Reliability and Integrity Management (RIM) Programs for Nuclear Reactor Facilities

- XII Rules for Construction and Continued Service of Transport Tanks

- XIII Rules for Overpressure Protection

CORRESPONDENCE WITH THE COMMITTEE

(23)

General

ASME codes and standards are developed and maintained by committees with the intent to represent the consensus of concerned interests. Users of ASME codes and standards may correspond with the committees to propose revisions or cases, report errata, or request interpretations. Correspondence for this Section of the ASME Boiler and Pressure Vessel Code (BPVC) should be sent to the staff secretary noted on the Section's committee web page, accessible at <https://go.asme.org/CSCcommittees>.

NOTE: See ASME BPVC Section II, Part D for guidelines on requesting approval of new materials. See Section II, Part C for guidelines on requesting approval of new welding and brazing materials ("consumables").

Revisions and Errata

The committee processes revisions to this Code on a continuous basis to incorporate changes that appear necessary or desirable as demonstrated by the experience gained from the application of the Code. Approved revisions will be published in the next edition of the Code.

In addition, the committee may post errata and Special Notices at <http://go.asme.org/BPVCerrata>. Errata and Special Notices become effective on the date posted. Users can register on the committee web page to receive e-mail notifications of posted errata and Special Notices.

This Code is always open for comment, and the committee welcomes proposals for revisions. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent background information and supporting documentation.

Cases

(a) The most common applications for cases are

(1) to permit early implementation of a revision based on an urgent need

(2) to provide alternative requirements

(3) to allow users to gain experience with alternative or potential additional requirements prior to incorporation directly into the Code

(4) to permit use of a new material or process

(b) Users are cautioned that not all jurisdictions or owners automatically accept cases. Cases are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Code.

(c) The committee will consider proposed cases concerning the following topics only:

(1) equipment to be marked with the ASME Single Certification Mark, or

(2) equipment to be constructed as a repair/replacement activity under the requirements of Section XI

(d) A proposed case shall be written as a question and reply in the same format as existing cases. The proposal shall also include the following information:

(1) a statement of need and background information

(2) the urgency of the case (e.g., the case concerns a project that is underway or imminent)

(3) the Code Section and the paragraph, figure, or table number(s) to which the proposed case applies

(4) the edition(s) of the Code to which the proposed case applies

(e) A case is effective for use when the public review process has been completed and it is approved by the cognizant supervisory board. Cases that have been approved will appear in the next edition or supplement of the Code Cases books, "Boilers and Pressure Vessels" or "Nuclear Components." Each Code Cases book is updated with seven Supplements. Supplements will be sent or made available automatically to the purchasers of the Code Cases books until the next edition of the Code. Annulments of Code Cases become effective six months after the first announcement of the

annulment in a Code Case Supplement or Edition of the appropriate Code Case book. The status of any case is available at <http://go.asme.org/BPVCCDatabase>. An index of the complete list of Boiler and Pressure Vessel Code Cases and Nuclear Code Cases is available at <http://go.asme.org/BPVCC>.

Interpretations

(a) Interpretations clarify existing Code requirements and are written as a question and reply. Interpretations do not introduce new requirements. If a revision to resolve conflicting or incorrect wording is required to support the interpretation, the committee will issue an intent interpretation in parallel with a revision to the Code.

(b) Upon request, the committee will render an interpretation of any requirement of the Code. An interpretation can be rendered only in response to a request submitted through the online Interpretation Submittal Form at <http://go.asme.org/InterpretationRequest>. Upon submitting the form, the inquirer will receive an automatic e-mail confirming receipt.

(c) ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Code requirements. If, based on the information submitted, it is the opinion of the committee that the inquirer should seek assistance, the request will be returned with the recommendation that such assistance be obtained. Inquirers may track the status of their requests at <http://go.asme.org/Interpretations>.

(d) ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

(e) Interpretations are published in the ASME Interpretations Database at <http://go.asme.org/Interpretations> as they are issued.

Committee Meetings

The ASME BPVC committees regularly hold meetings that are open to the public. Persons wishing to attend any meeting should contact the secretary of the applicable committee. Information on future committee meetings can be found at <http://go.asme.org/BCW>.

SUMMARY OF CHANGES

The 2023 Edition of the Code Cases includes Code Case actions published through Supplement 7 to the 2021 Edition.

Changes listed below are identified on the pages by a margin note, **(23)**, placed next to the affected area. Errata, if any, are identified by a margin note, **(E)**, placed next to the affected area.

<i>Page</i>	<i>Location</i>	<i>Change</i>
iv	List of Sections	(1) Under Section III, Division 4 added (2) Title of Section XI and subtitle of Section XI, Division 2 revised (3) Information on interpretations and Code cases moved to “Correspondence With the Committee”
v	Correspondence With the Committee	Added
ix	Cross-Referencing in the ASME BPVC	Updated
x	Notes to Numeric Index	Updated
xi	Numeric Index	Updated
xvii	Subject Index	Updated
xxiii	Index of Material Specifications Referred to in Cases	Updated
xxvii	Applicability Index for Section XI Cases	Updated
xlvii	Guideline for Cross-Referencing Section XI Cases	(1) In Table 1, first column heading revised from “E17” to “E17-E21” (2) In Table 1, General Notes (a), (d), and (f) revised
1 (N-504-4)	N-504-4	Annulled
1 (N-532-6)	N-532-6	Revised
1 (N-666-3)	N-666-3	Revised
1 (N-778-1)	N-778-1	Revised
1 (N-801-4)	N-801-4	Revised
1 (N-830-1)	N-830-1	In eq. (5c), “ $-\Delta J_{IC(US)}$ ” inserted at end of equation by errata
1 (N-888-1)	N-888-1	Revised
1 (N-892-1)	N-892-1	Revised
1 (N-898-1)	N-898-1	Revised
1 (N-909-1)	N-909-1	Revised
1 (N-924)	N-924	(1) In I-8, six instances of “ ε_c ” corrected to “ ε_v ” by errata (2) In I-8, two instances of “ ε ” corrected to “ ε_v ” by errata

<i>Page</i>	<i>Location</i>	<i>Change</i>
1 (N-928)	N-928	Added
1 (N-929)	N-929	Added
1 (N-930)	N-930	Added
1 (N-931)	N-931	Added

CROSS-REFERENCING IN THE ASME BPVC

(23)

Paragraphs within the ASME BPVC may include subparagraph breakdowns, i.e., nested lists. The following is a guide to the designation and cross-referencing of subparagraph breakdowns:

(a) Hierarchy of Subparagraph Breakdowns

- (1) First-level breakdowns are designated as (a), (b), (c), etc.
- (2) Second-level breakdowns are designated as (1), (2), (3), etc.
- (3) Third-level breakdowns are designated as (-a), (-b), (-c), etc.
- (4) Fourth-level breakdowns are designated as (-1), (-2), (-3), etc.
- (5) Fifth-level breakdowns are designated as (+a), (+b), (+c), etc.
- (6) Sixth-level breakdowns are designated as (+1), (+2), etc.

(b) Cross-References to Subparagraph Breakdowns. Cross-references within an alphanumerically designated paragraph (e.g., PG-1, UIG-56.1, NCD-3223) do not include the alphanumeric designator of that paragraph. The cross-references to subparagraph breakdowns follow the hierarchy of the designators under which the breakdown appears. The following examples show the format:

- (1) If X.1(c)(1)(-a) is referenced in X.1(c)(1), it will be referenced as (-a).
- (2) If X.1(c)(1)(-a) is referenced in X.1(c)(2), it will be referenced as (1)(-a).
- (3) If X.1(c)(1)(-a) is referenced in X.1(e)(1), it will be referenced as (c)(1)(-a).
- (4) If X.1(c)(1)(-a) is referenced in X.2(c)(2), it will be referenced as X.1(c)(1)(-a).

NOTES TO NUMERIC INDEX

- All Code Cases remain available for use until annulled by the ASME Boiler and Pressure Vessel Standards Committees. Code Cases will be reviewed routinely for possible incorporation into the body of the ASME Boiler and Pressure Vessel Code.
- Supplement 7 is the last supplement published for the 2021 edition. Supplement 8 is incorporated into the 2023 edition.
- Cases may be used beginning with the date of approval shown on the Case.
- Annulled Cases will remain in the Numeric Index and Subject Index until the next Edition, at which time they will be deleted.
- Newly revised cases supersede previous versions. Previous code case number will be added in the "Annulled Date/Supersedes" column next to the newly revised code case.
- The digit following a Case Number is used to indicate the number of times a Case has been revised.
- The Cases are arranged in numerical order, and each page of a Case is identified at the top with the appropriate Case Number.

Legend of Abbreviations

Supp. = Supplement

R = Reinstated

NUMERIC INDEX

(23)

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
2996-1	7-15-2020
N-4-13	2-12-2008
N-60-6	12-6-2011
N-62-7	5-11-1994
N-71-21	1-11-2021
N-131-1	12-11-1981
N-133-3	7-18-1985
N-154-1	12-5-1985
N-155-3	2-11-2016
N-205	7-13-1981
N-213-1	2-11-2016
	3-6-1978(ACI)
N-249-17	4-10-2018
N-258-2	7-30-1986
	3-17-1978(ACI)
N-284-4	10-8-2012
N-290-3	10-6-2019
N-312	5-25-1983
	9-26-1983(ACI)
N-315	2-14-1983
N-319-3	1-17-2000
N-351-1	10-13-2021
N-369	2-14-1983
N-373-3	10-8-2004
N-405-1	7-24-1989
N-432-1	3-28-2001
N-452	3-8-1989
N-453-3	12-12-1995
N-454-1	4-30-1992
N-455-1	4-30-1992
N-460	7-27-1988
N-469-1	6-14-2000
N-494-4	1-12-2005
N-500-4	10-14-2011
N-504-4	7-14-2006	7-1-2023
N-505	7-27-1992
N-508-5	7-6-2022
N-511	2-12-1993
N-513-6	10-28-2021
N-516-5	4-25-2016
N-517-1	7-30-1998
N-519-1	R1-16-2019
N-520-6	12-11-2012
N-525	12-9-1993
N-526	8-9-1996
N-528-1	5-7-1999
N-530	12-12-1994
N-532-6	10-14-2022	N-532-5
N-537	3-14-1995
N-539-1	8-16-2016
N-548	3-19-1996
N-552-1	6-22-2012
N-560-2	3-28-2000
N-561-4	10-9-2020
N-562-4	10-9-2020
N-564-2	1-17-2000
N-565	12-31-1996
N-566-2	3-28-2001

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
N-570-3	1-11-2021
N-575	8-14-1997
N-576-2	3-16-2012
N-577-1	3-28-2000
N-578-1	3-28-2000
N-579	8-14-1997
N-580-2	1-4-2008
N-586-1	5-4-2004
N-589-1	7-23-2002
N-593-2	11-8-2011
N-594-1	10-14-2011
N-597-5	10-9-2020
N-600	9-18-2001
N-606-2	6-21-2013
N-609-1	9-17-2010
N-610	7-30-1998
N-613-2	12-20-2010
N-619	2-15-1999
N-620	2-26-1999
N-621-1	10-8-2004
N-624	5-7-1999
N-625-1	3-28-2001
N-631	9-24-1999
N-632	12-3-1999
N-633	6-14-2002
	6-14-2002(ACI)
N-635-1	2-14-2003
N-636	9-24-1999
N-637-2	1-12-2022
N-638-11	8-2-2019
N-639-1	9-13-2021
N-641	1-17-2000
N-642	3-28-2000
N-643-2	5-4-2004
N-644-1	2-14-2003
N-648-2	9-4-2014
N-649	3-28-2001
N-650	3-28-2001
N-651	8-14-2001
N-652-2	9-3-2010
N-653-2	6-23-2015
N-654	4-17-2002
N-655-2	9-27-2010
N-658	4-4-2002
N-659-3	10-12-2017
N-660	7-23-2002
N-661-5	10-9-2020
N-662-1	6-25-2011
N-663-1	9-28-2021
N-664	8-20-2002
N-665	2-28-2003
N-666-3	1-10-2023	N-666-2
N-673	8-7-2003
N-683	2-14-2003
N-685	5-9-2003
N-686-1	1-10-2007
N-691-1	4-17-2020
N-692-1	5-9-2016
N-694-2	1-16-2013
N-695-1	12-31-2014
N-696-1	5-7-2014

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/Supersedes
N-698	11-18-2003
N-699	1-5-2006
N-702-1	4-18-2019
N-703	5-4-2004
N-705-1	6-30-2017
N-706-1	1-10-2007
N-707-2	1-11-2021
N-708	9-21-2007
N-710	5-5-2004
N-711-2	5-13-2020
N-712	5-12-2004
N-716-3	1-21-2020
N-721-1	10-20-2016
N-722-2	9-8-2011
N-725	1-12-2005
N-727	2-24-2006
N-729-10	7-27-2022
N-730-1	7-16-2012
N-731	2-22-2005
N-733-1	4-17-2020
N-735	10-12-2006
N-736	1-5-2006
N-738	7-1-2005
N-739-1	1-21-2007
N-740-2	11-10-2008
N-741	10-11-2005
N-746	1-5-2006
N-747	1-13-2006
N-748	9-9-2008
N-749	3-16-2012
N-751	8-3-2006
N-752-1	4-12-2021
N-753	7-14-2006
N-754-2	10-9-2020
N-756	1-21-2007
N-757-1	9-21-2007
N-759-2	1-4-2008
N-760-2	10-10-2008
N-761	9-20-2010
N-762-1	10-21-2013
N-763	8-28-2008
	3-19-2010(ACI)
N-765	1-26-2009
N-766-4	10-9-2020
N-767	1-4-2008
N-768	10-16-2018
N-769-2	7-16-2012
N-770-7	12-4-2020
N-771	9-8-2011
N-773	1-26-2009
N-774	9-3-2008
N-775	6-24-2010
N-776	4-9-2010
N-777	10-10-2008
N-778-1	10-14-2022	N-778
N-779	1-26-2009
N-780-1	4-12-2021
N-782	1-30-2009
N-784	4-9-2010
N-785	10-12-2009
N-786-4	10-9-2020

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
N-788-1	3-6-2017
N-789-5	6-15-2021
N-791	9-20-2010
	10-23-2010(ACI)
N-792-1	8-12-2012
N-793	9-20-2010
	10-23-2010(ACI)
N-794	9-20-2010
	10-23-2010(ACI)
N-795	9-17-2010
N-796	10-18-2010
	10-23-2010(ACI)
N-798	12-20-2010
N-799	12-20-2010
N-800	12-20-2010
N-801-4	1-4-2023	N-801-3
N-803	2-25-2011
N-804	10-14-2011
N-805	2-25-2011
N-806-1	12-15-2015
N-807	4-20-2011
	9-6-2011(ACI)
N-809-1	10-9-2020
N-811	8-5-2011
	9-6-2011(ACI)
N-812-1	1-10-2013
N-813-1	12-4-2020
N-815	12-6-2011
N-816	12-6-2011
N-817	12-6-2011
N-818-1	8-20-2014
N-819	12-6-2011
N-820	12-29-2011
	1-25-2012(ACI)
N-822-4	8-2-2016
N-823-1	1-23-2014
N-824	10-16-2012
N-825	10-2-2013
N-826	7-16-2012
N-829	12-28-2012
N-830-1	9-13-2021	2023
N-831-1	7-25-2018
N-833	1-2-2013
	1-23-2013(ACI)
N-834	10-22-2013
N-836	10-22-2013
N-837	10-22-2013
N-838	8-3-2015
N-839	9-4-2014
N-840	1-23-2014
N-841	1-6-2014
N-842	1-28-2014
N-843	1-23-2014
N-844	2-9-2014
N-845-1	4-25-2016
N-846	7-25-2014
N-847-1	10-9-2020
N-848-1	11-7-2016
N-849	9-4-2014
N-850	10-20-2014
	8-1-2014(ACI)

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/Supersedes
N-851	11-5-2014
N-852	2-9-2015
N-853-1	11-20-2020
N-854	4-15-2015
N-855	7-8-2015
N-856	7-16-2015
N-858	6-28-2017
N-859	1-20-2016
N-860	7-6-2020
N-861-2	7-20-2022
N-862-2	7-20-2022
N-863-1	2-16-2017
N-864	7-28-2017
N-865-2	10-9-2020
N-866	11-14-2016
N-867	11-7-2016
N-868	10-20-2016
N-869	7-5-2018
N-870-1	11-2-2017
N-871-1	10-9-2020
N-872	10-20-2016
N-873	5-10-2017
N-874	8-1-2018
N-875	5-11-2017
N-876	6-12-2017
N-877-1	2-10-2020
N-878	4-18-2017
N-879	5-10-2017
N-880-1	11-20-2020
N-881	12-4-2017
N-882-1	10-9-2020
N-883	1-29-2018
N-884	10-23-2018
N-885-1	9-13-2021
N-886	5-2-2018
N-887	5-2-2018
N-888-1	10-13-2022	N-888
N-889	7-12-2018
N-890	10-16-2018
N-891	12-17-2018
N-892-1	10-14-2022	N-892
N-893	12-21-2019
N-896	8-2-2019
N-897	12-30-2020
N-898-1	11-29-2022	N-898
N-899	7-23-2019
N-900	7-29-2019
N-901	12-21-2019
N-902	2-20-2020
N-903	4-28-2020
N-904	5-27-2020
N-905	5-27-2020
N-906	7-20-2020
N-907	8-14-2020
N-908	9-2-2020
N-909-1	11-21-2022	N-909
N-910	9-2-2020
N-911	12-4-2020
N-912	12-4-2020
N-913	12-4-2020
N-915	5-7-2021

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/Supersedes
N-916	5-7-2021
N-917	6-15-2021
N-919	8-23-2021
N-920	8-10-2021
N-921	9-28-2021
N-922	10-28-2021
N-923	2-11-2022
N-924	1-12-2022	2023
N-925	2-16-2022
N-926	7-27-2022
N-928	12-6-2022
N-929	12-6-2022
	5-26-2023(ACI)
N-930	1-2-2023
N-931	12-19-2022

SUBJECT INDEX

(23)

Subject	Case
Section III — Division 1	
Rules for Construction of Nuclear Facility Components	
Additional Materials for Subsection NF, Class 1, 2, 3, and MC Supports Fabricated by Welding	N-71
Additional Materials for Subsection NF, Class 1, 2, 3, and MC Supports Fabricated Without Welding	N-249
Air Cooling of SA-182 Grades F304, F304L, F316, F316L Forgings Instead of Liquid Quenching After Solution Heat Treatment, Classes 1, 2, and 3	N-548
Alternate Design Fatigue Curves to Those Given in For Section III Appendices, Mandatory Appendix I, Figures I-9.1 and I-9.1M	N-905
Alternate Procedure for Evaluation of Stresses in Butt Welding Elbows in Class 1 Piping	N-319
Alternative Fatigue Design Curves for Ferritic Steels With Ultimate Tensile Strengths (UTS) ≤ 80 ksi (552 MPa) and Austenitic Steels	N-920
Alternative Fatigue Evaluation Method to Consider Environmental Effects on Class 1 Components	N-919
Alternative Materials for Construction of Section III, Class 2 Vessels	N-866
Alternative Methods of Nozzle Attachment for Class 1 Vessels	N-565
Alternative Preheat Temperature for Austenitic Welds in P-No. 1 Material Without PWHT	N-804
Alternative PWHT Time at Temperature for P-No. 5A or P-No. 5B Group 1 Material, Classes 1, 2, and 3	N-373
Alternative Reference Stress Intensity Factor (K_{IR}) Curve for Class Components	N-610
Alternative Requirements to Appendix XXVI, XXVI-2400, XXVI-4130, and XXVI-4131 for Inspection and Repair of Indentations for Polyethylene Pipe and Piping Components	N-891
Alternative Rules for Acceptability for Class 1 Valves, NPS 1 (DN 25) and Smaller With Nonwelded End Connections Other Than Flanges	N-756
Alternative Rules for Acceptability for Class 2 and 3 Valves, NPS 1 (DN 25) and Smaller With Welded and Nonwelded End Connections Other Than Flanges	N-757
Alternative Rules for Determining Allowable External Pressure and Compressive Stresses for Cylinders, Cones, Spheres, and Formed Heads, Class 1, 2, and 3	N-759
Alternative Rules for Level D Service Limits of Class 1, 2, and 3 Piping Systems	N-900
Alternative Rules for Linear Piping and Linear Standard Supports for Classes 1, 2, 3, and MC	N-570
Alternative Rules for Linear Piping Supports	N-721
Alternative Rules for Progressive Liquid Penetrant Examination of Groove Welds in P-No. 8 Materials $\frac{3}{16}$ in. (5 mm) Thick and Less Made by Autogenous Machine or Automatic Welding	N-642
Alternative Rules for Renewal of Active or Expired Certificates for Plants Not in Active Construction	N-520
Alternative Rules for Simplified Elastic-Plastic Analysis	N-904
Alternative Rules for Simplified Elastic-Plastic Analysis Class 1.	N-779
Alternative Rules for Standard Supports for Classes 1, 2, 3, and MC	N-500

Subject	Case
Section III — Division 1	
Rules for Construction of Nuclear Facility Components (Cont'd)	
Alternative Rules for the Examination of Butt Welds Used as Closure Welds for Electrical Penetration Assemblies in Containment Structures	N-505
Alternative to the Registered Professional Engineer Requirements	N-837
Alternatives to the Requirements of NB-4250(c)	N-844
Alternatives to the Requirements of NB-4424.2(a), Figure NB- 4250-2, and Figure NB-4250-3	N-887
Application of the ASME Certification Mark	N-822
Application of the ASME NPT Stamp	N-852
ASTM A988/A988M-11 UNS S31603, Subsection NB, Class 1 Components	N-834
Boron Containing Powder Metallurgy Aluminum Alloy for Storage and Transportation of Spent Nuclear Fuel	N-673
Calibration of C_v Impact Test Machines	N-777
Certificate Holder Ability to Supply Polyethylene Material	N-846
Construction of ASME B16.9 Wrought Butt Welding Fittings and ASME B16.11 Forged Fittings Made From SB-366 UNS N04400 Material for Section III, Class 3 Construction	N-859
Construction of Items Prior to the Establishment of a Section III, Division 1 Owner	N-883
Design Stress Intensities and Yield Strength Values for UNS N06690 With a Minimum Specified Yield Strength of 30 ksi, Class 1 Components	N-525
Design Stress Intensities and Yield Strength Values for UNS N06690 With a Minimum Specified Yield Strength of 35 ksi (240 MPa), Class 1 Components	N-698
Design Stress Values for UNS N06690 With a Minimum Specified Yield Strength of 35 ksi (240 MPa), Classes 2 and 3 Components	N-725
Design Temperatures for Atmospheric and 0–15 psi Storage Tanks	N-511
Dissimilar Welding Using Continuous Drive Friction Welding for Reactor Vessel CRDM/CEDM Nozzle to Flange/Adapter Welds, Class 1	N-727
Exempting SA-508 Grade 1A From PWHT Based on Measurement of Residual Stress in Class 1 Applications	N-881
Exemptions to Mandatory PWHT of SA-738 Grade B for Class MC Applications	N-841
Extension of Internal Audit and Supplier Audit Due Dates in Exigent Conditions	N-915
Extension of Joining Personnel's Qualification Continuity	2996
Fatigue Design Curves for Light Water Reactor (LWR) Environments	N-761
Fatigue Evaluations Including Environmental Effects	N-792
Fiberglass Reinforced Thermosetting Resin Pipe	N-155
Heat Exchanger Tube Mechanical Plugging, Class 1	N-836
Internal and External Valve Items, Classes 1, 2, and 3	N-62
Martensitic Stainless Steel for Classes 1, 2, and 3 Components	N-469
Material for Core Support Structures	N-60
Material for Internal Pressure Retaining Items for Pressure Relief Valves, Classes 1, 2, and 3	N-131

Subject	Case
Section III — Division 1	
Rules for Construction of Nuclear Facility Components (Cont'd)	
Metal Containment Shell Buckling Design Methods, Class MC, TC, and SC Construction	N-284
NDE of Full Penetration Butt Welds in Class 2 Supports	N-738
Ni-Cr-Mo Alloy (UNS N06022) Welded Construction to 800°F	N-621
Ni-Cr-Mo Alloy (UNS N06059) Welded Construction to 800°F	N-625
Nickel-Chromium-Molybdenum-Copper Stainless Steel (UNS N08925 and N08926) for Class 2 and 3 Construction	N-453
Nickel-Chromium-Molybdenum-Copper Stainless Steels (UNS N08925 and N08926) Forged Flanges and Fittings for Class 2 and 3 Construction	N-455
Nickel-Chromium-Molybdenum-Copper Stainless Steels (UNS N08925 and N08926) Wrought Fittings for Class 2 and 3 Construction	N-454
Performance and Qualification Criteria for Mitigation of Stress Corrosion Cracking by Surface Stress Improvement	N-931
Postweld Heat Treatment (PWHT) of Valve Seal Welds for P4 and P5A Materials	N-863
Procedure to Determine Strain Rate for Use With the Environmental Fatigue Design Curve Method and the Environmental Fatigue Correction Factor, F_{en} , Method as Part of an Environmental Fatigue Evaluation for Components Analyzed per the NB-3200 Rules	N-884
Projection Resistance Welding of Valve Seats, Classes 1, 2, and 3 Provisions for Establishing Allowable Axial Compressive Membrane Stresses in the Cylindrical Walls of 0-15 psi Storage Tanks, Classes 2 and 3	N-530
Remote Verification and Witness of Activities	N-916
Repair of Bellows	N-315
Repairs to P-4 and P-5A Castings Without Postweld Heat Treatment Class 1, 2, and 3 Construction	N-594
Resistance Welding of Bellows	N-369
Rules for Class 1 Type M Pumps	N-620
Rules for Performing Preservice Inspection (PSI) During Construction	N-907
Rules for Repair of N-Stamped Class 1, 2, 3, and MC Components	N-801
Rules for the Elimination of External Surface Defects on Class 1, 2, and 3 Piping, Pumps, or Valves After Component Stamping and Prior to Completion of the N-3 Data Report	N-870
SA-494 Grade CW-12MW (UNS N30002) Nickel Alloy Castings for Construction of NPS 2½ and Smaller Flanged Valves for Class 3 Construction	N-856
SB-148 C95800 Valves for Class 3 Construction	N-855
Socket Welds	N-405
Special Type 403 Modified Forgings or Bars, Class 1 and CS	N-4
Specialized Subcontracted Welding Process (Electron Beam Welding)	N-452
Thickness and Gradient Factors for Piping Fatigue Analyses	N-902
UNS J93380, Alloy CD3MWCuN, Classes 2 and 3 Construction	N-564
UNS N08367 in Class 2 and 3 Valves	N-539
Use of 13Cr-4Ni (Alloy UNS S41500) Grade F6NM Forgings Weighing in Excess of 10,000 lb (4 540 kg) and Otherwise Conforming to the Requirements of SA-336/SA-336M for Class 1, 2 and 3 Construction	N-774
Use of 18Cr-13Ni-3Mo (Alloy UNS S31703), 19Cr-15Ni-4Mo (Alloy UNS S31725), and 18.5Cr-15.5Ni-4.5Mo-N (Alloy UNS S31726) Forgings, Seamless Tubing, Plate, Welded Tubing, Welded and Seamless Pipe, Welded Pipe With Addition of Filler Metal and Fittings, Classes 2 and 3	N-636

Subject	Case
Section III — Division 1	
Rules for Construction of Nuclear Facility Components (Cont'd)	
Use of 21Cr-6Ni-9Mn (Alloy UNS S21904) Grade FXM-11 (Conforming to SA-182/SA-182M and SA-336/SA-336M), Grade TPXM-11 (Conforming to SA-312/SA-312M) and Type XM-11 (Conforming to SA-666) Material, for Class 1 Construction	N-767
Use of 22Cr-5Ni-3Mo-N (Alloy UNS S31803) Forgings, Plate, Bar, Welded and Seamless Pipe, and/or Tube, Fittings, and Fusion Welded Pipe With Addition of Filler Metal, Classes 1, 2, and 3	N-635
Use of 22Cr-5Ni-3Mo-N (Alloy UNS S32205 Austenitic/Ferritic Duplex Stainless Steel) Forgings, Plate, Welded and Seamless Pipe and Tubing, and Fittings to SA-182, SA-240, SA-789, A 790-04a, SA-815, Classes 2 and 3	N-741
Use of 25Cr-7Ni-4Mo-N (Alloy UNS S32750 Austenitic/Ferritic Duplex Stainless Steel) Forgings, Plate, and Welded and Seamless Pipe and Tubing Conforming to SA-182, SA-240, SA-789, or SA-790	N-910
Use of 44Fe-25Ni-21Cr-Mo (Alloy UNS N08904) Plate, Bar, Fittings, Welded Pipe, and Welded Tube, Classes 2 and 3	N-637
Use of 46Fe-24Ni-21Cr-6Mo-Cu-N (UNS N08367) Bolting Materials for Class 2 and 3 Components	N-746
Use of 6061-T6 and 6061-T651 Aluminum for Class 1 Nuclear Components	N-519
Use of Alloy 600 With Columbium Added	N-580
Use of Alloy Steel Bar and Mechanical Tubing in Class 2 and 3 Patented Mechanical Joints and Fittings	N-893
Use of ASME SA-494 Grade M35-1 for Line Valve Bodies and Bonnets, and Bodies, Bonnets, and Yokes of Pressure Relief Valves for Class 2 and 3 Construction	N-901
Use of ASTM A508/A508M in Lieu of SA-508	N-928
Use of Code Editions, Addenda, and Cases	N-782
Use of Die Forgings, SB-247, UNS A96061, Class T6, With Thickness ≤4.000 in. Material, Class 2 Construction (1989 Edition With the 1991 Addenda or Earlier)	N-819
Use of Die Forgings, SB-247, UNS A96061, Class T6, With Thickness ≤4.000 in. Material, Class 2 Construction (1992 Edition or Later)	N-817
Use of Ductile Iron SA-395, Class 3	N-205
Use of Ferritic/Austenitic Wrought WPS32750/CRS32750 Fittings of Seamless or Welded Construction Conforming to SA-815, Class 3	N-908
Use of Fracture Toughness Test Data to Establish Reference Temperature for Pressure Retaining Materials Other Than Bolting for Class 1 Vessels	N-631
Use of JIS G4303, Grades SUS304, SUS304L, SUS316, and SUS316L	N-708
Use of Micro-Alloyed Carbon Steel Bar in Patented Mechanical Joints and Fittings, Classes 1, 2, and 3	N-879
Use of NDE and Fracture Mechanics for Acceptance of Full Penetration Butt Welds in Lieu of Weld Repair, Class 1 and 2	N-818
Use of Nonstandard Nuts, Class 1, 2, and 3, MC, CS Components and Supports Construction	N-579
Use of Polyethylene Pipe for Class 3	N-886
Use of SA-358/SA-358M Grades Fabricated as Class 3 or Class 4 Welded Pipe, Class CS Core Support Construction	N-815
Use of SA-479/SA-479M, UNS S41500 for Class 1, Welded Construction	N-785
Use of SA-537, Class 2 Plate Material in Non-pressure Boundary Application Service 700°F to 850°F, Class 1 or CS	N-650
Use of SA-738, Grade B, for Metal Containment Vessels, Class MC	N-655
Use of SB-148 Alloys 952 and 954, Class 3	N-133

<u>Subject</u>	<u>Case</u>
Section III — Division 1	
Rules for Construction of Nuclear Facility Components (Cont'd)	
Use of Standard Subsize Charpy V-Notch Impact Specimens . . .	N-351
Use of Standard Welding Procedures	N-692
Use of Strain Hardened Austenitic Material at Lower Design Stress Values for Class 1 Valves	N-703
Use of Temper Bead Weld Repair Rules Adopted in 2010 Edition and Earlier Editions	N-816
Use of Titanium Grade 2 (UNS R50400) Tube and Bar, and Grade 1 (UNS R50250) Plate and Sheet for Class 1 Construction . . .	N-699
Use of Ultrasonic Examination in Lieu of Radiography for Weld Examination	N-659
Use of UNS S32050 Welded and Seamless Pipe and Tubing, Forgings, and Plates Conforming to SA-249/SA-249M, SA-479/ SA-479M, and SA-240/SA-240M, and Grade CK35MN Castings Conforming to ASTM A743-03 for Construction of Class 1, 2, and 3 Components	N-736
Use of Zirconium Alloy UNS R60702, Bars, Forgings, Plate, Seamless and Welded Fittings, Seamless and Welded Tubing, and Seamless and Welded Pipe, for Class 3 Construction . . .	N-710
Weld Procedure Qualification for Procedures Exempt From PWHT in Classes 1, 2, and 3 Construction	N-644
Welding of Globe Valve Disks to Valve Stem Retainers, Classes 1, 2, and 3	N-760
Section III — Division 2	
Code For Concrete Containments	
Alternative Qualification Requirements for Concrete Level III Inspection Personnel	N-811
Alternative to the Registered Professional Engineer Requirements	N-837
Anchor Head Assembly and Wedge Blocks	N-929
Application of the ASME Certification Mark	N-822
Application of the ASME NPT Stamp	N-852
ASTM A709-06, Grade HPS 70W (HPS 485W) Plate Material Without Postweld Heat Treatment as Containment Liner Material or Structural Attachments to the Containment Liner, Subsection CC	N-763
Calibration of C _v Impact Test Machines	N-777
Design of Interaction Zones for Concrete Containments	N-258
Equivalent Rectangular Compressive Stress Block for Concrete Containment	N-850
Extension of Internal Audit and Supplier Audit Due Dates in Exigent Conditions	N-915
Extension of Joining Personnel's Qualification Continuity	2996
Extruded Steel Sleeves With Parallel Threaded Ends	N-793
Minimum Nonprestressed Reinforcement in the Containment Base Mat or Slab Required for Concrete Crack Control	N-833
Remote Verification and Witness of Activities	N-916
Shear Screw and Sleeve Splice	N-791
Swaged Splice With Threaded Ends	N-794
Threaded Sleeves With Parallel Threads Cut on Upsized Bar Ends	N-796
Twisting of Horizontal Prestressing Tendons	N-820
Use of ASTM A572, Grades 50 and 65 for Structural Attachments to Class CC Containment Liners	N-632
Use of Grades 75 and 80 Reinforcement in Concrete Containments	N-807
Use of SA-533/SA-533M, Type B, Class 2, Plate for Structural Attachments to Class CC Containment Liners	N-633
Use of Standard Subsize Charpy V-Notch Impact Specimens . . .	N-351

<u>Subject</u>	<u>Case</u>
Section III — Division 2	
Code For Concrete Containments (Cont'd)	
Use of Stud Welds to Anchor Section III, Division 1, Class MC Vessels to Section III, Division 2, Class CC Concrete Containment Structures	N-312
Welded Radial Shear Bar Assemblies	N-213
Section III — Division 3	
Containments for Transportation and Storage of Spent Nuclear Fuel and High Level Radioactive Material and Waste	
Alternative to the Registered Professional Engineer Requirements	N-837
Application of the ASME Certification Mark	N-822
Application of the ASME NPT Stamp	N-852
Calibration of C _v Impact Test Machines	N-777
Extension of Internal Audit and Supplier Audit Due Dates in Exigent Conditions	N-915
Extension of Joining Personnel's Qualification Continuity	2996
Metal Containment Shell Buckling Design Methods, Class MC, TC, and SC Construction	N-284
Performance and Qualification Criteria for Mitigation of Stress Corrosion Cracking by Surface Stress Improvement	N-931
Remote Verification and Witness of Activities	N-916
Use of Eddy Current Examination in Lieu of Liquid Penetrant Examination	N-748
Use of SA-537, Class 1 Plate Material for Class ISS Components in Non-Pressure Retaining Applications Above 700°F (370°C) . .	N-707
Use of Standard Subsize Charpy V-Notch Impact Specimens . . .	N-351
Use of Ultrasonic Examination in Lieu of Radiography for Weld Examination	N-659
Section III — Division 5	
High Temperature Reactors	
Alternate Creep-Fatigue Damage Envelope for 9Cr-1Mo-V Steel . .	N-812
Alternative Failure Probability Calculation for a Graphite Core Component	N-903
Alternative to the Registered Professional Engineer Requirements	N-837
Application of the ASME Certification Mark	N-822
Application of the ASME NPT Stamp	N-852
Calculation of Creep-Fatigue for Division 5 Class A Components at Elevated Temperature Service Using Elastic-Perfectly Plastic Analysis	N-862
Design Rules and Limits for Load-Controlled Stresses for Class A Components at Elevated Temperature Service Using Elastic-Perfectly Plastic and Simplified Inelastic Analyses . . .	N-924
Expansion Joints in Class A, Liquid Metal Piping	N-290
Extension of Internal Audit and Supplier Audit Due Dates in Exigent Conditions	N-915
Extension of Joining Personnel's Qualification Continuity	2996
Remote Verification and Witness of Activities	N-916
Satisfaction of Strain Limits for Division 5 Class A Components at Elevated Temperature Service Using Elastic-Perfectly Plastic Analysis	N-861
Use of 52Ni-22Cr-13Co-9Mo Alloy 617 (UNS N06617) for Low Temperature Service Construction	N-872
Use of Alloy 617 (UNS N06617) for Class A Elevated Temperature Service Construction	N-898
Section XI, Division 1	
Rules for Inservice Inspection of Nuclear Power Plant Components	
Acceptance Criteria for Flaws in Ferritic Steel Components 4 in. and Greater in Thickness	N-654
Alternative 12-yr Inspection Interval Duration	N-921

<u>Subject</u>	<u>Case</u>
Section XI, Division 1	
Rules for Inservice Inspection of Nuclear Power Plant Components (Cont'd)	
Alternative Acceptance Criteria for Flaws in Ferritic Steel Components Operating in the Upper Shelf Temperature Range	N-749
Alternative Additional Examination Requirements for Classes 1, 2, and 3 Piping, Components, and Supports	N-586
Alternative Calibration Block Material	N-639
Alternative Characterization Rules for Multiple Radially Oriented Planar Flaws	N-877
Alternative Characterization Rules for Quasi-Laminar Flaws	N-848
Alternative Class 1 System Leakage Test Pressure Requirements	N-731
Alternative Classification and Examination Requirements	N-716
Alternative Examination Coverage for Class 1 and Class 2 Welds	N-460
Alternative Examination Coverage Requirements for Examination Category B-F, B-J, C-F-1, C-F-2, and R-A Piping Welds	N-711
Alternative Examination Requirements and Acceptance Standards for Class 1 PWR Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082 or UNS W86182 Weld Filler Material With or Without Application of Listed Mitigation Activities	N-770
Alternative Examination Requirements for Class 1 Pressure-Retaining Welds in Control Rod Drive Housings	N-913
Alternative Examination Requirements for Class 1, Category B-J Piping Welds	N-560
Alternative Examination Requirements for Full Penetration Nozzle-to-Vessel Welds in Reactor Vessels With Set-On Type Nozzles	N-575
Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	N-729
Alternative Examination Requirements for Unbonded Post-Tensioning Systems of Class CC Components	N-926
Alternative Examination Requirements of Table IWB-2500-1 and Table IWC-2500-1 for PWR Stainless Steel Residual and Regenerative Heat Exchangers	N-706
Alternative Experience Requirements for Nondestructive Examination Personnel for Ultrasonic Examination	N-930
Alternative Inspection Program for Longer Fuel Cycles	N-842
Alternative Method for Establishing the Reference Temperature for Pressure Retaining Materials	N-851
Alternative Methods — Qualification for Nozzle Inside Radius Section From the Outside Surface	N-552
Alternative Pressure Testing Requirements Following Repair/Replacement Activities for Class 1 Piping Between the First and Second Injection Isolation Valves	N-843
Alternative Pressure Testing Requirements for Class 1 Piping Between the First and Second Injection Valves	N-800
Alternative Pressure Testing Requirements for Class 1 Piping Between the First and Second Vent, Drain, and Test Isolation Devices	N-798
Alternative Pressure Testing Requirements for Class 2 and 3 Components Connected to the Class 1 Boundary	N-854
Alternative Pressure-Temperature Relationship and Low Temperature Overpressure Protection System Requirements	N-641
Alternative Qualification Criteria for Eddy Current Examinations of Piping Inside Surfaces	N-773
Alternative Qualification Requirements for Personnel Performing Class CC Concrete and Post-Tensioning System Visual Examinations	N-739

<u>Subject</u>	<u>Case</u>
Section XI, Division 1	
Rules for Inservice Inspection of Nuclear Power Plant Components (Cont'd)	
Alternative Repair/Replacement Requirements for Items Classified in Accordance With Risk-Informed Processes	N-662
Alternative Requirement for Form OAR-1, Owner's Activity Report, or Inservice Inspection Summary Report Completion Time	N-892
Alternative Requirements for Additional Examinations of Class 2 or 3 Items	N-771
Alternative Requirements for Application of Structural Factors to Secondary Stresses for Analytical Evaluation of Flaws in Piping in Accordance With IWB-3644, IWC-3644, or IWD-3644	N-922
Alternative Requirements for Attaching Nonstructural Electrical Connections to Class 2 and 3 Components	N-882
Alternative Requirements for Beam Angle Measurements Using Refracted Longitudinal Wave Search Units	N-665
Alternative Requirements for Boiling Water Reactor (BWR) Nozzle Inner Radius and Nozzle-to-Shell Welds	N-702
Alternative Requirements for Bolting Affected by Borated Water Leakage	N-775
Alternative Requirements for BWR Class 1 System Leakage Test Pressure Following Repair/Replacement Activities	N-795
Alternative Requirements for Classes 1 and 2 Surface Examinations	N-663
Alternative Requirements for Examination of Control Rod Drive Housing Welds	N-825
Alternative Requirements for Inner Radius Examinations of Class 1 Reactor Vessel Nozzles	N-648
Alternative Requirements for IWE-5240 Visual Examination	N-649
Alternative Requirements for Nozzle Inner Radius Inspections for Class 1 Pressurizer and Steam Generator Nozzles	N-619
Alternative Requirements for Pad Reinforcement of Class 2 and 3 Atmospheric, and 0 psi to 15 psi (0 kPa to 100 kPa), Storage Tanks	N-865
Alternative Requirements for Pad Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping for Raw Water Service	N-789
Alternative Requirements for Preparation and Submittal of Plans, Schedules, and Preservice and Inservice Inspection Summary Reports	N-778
Alternative Requirements for Preservice Volumetric and Surface Examination	N-813
Alternative Requirements for Qualification of Material Suppliers and Acceptance of Materials	N-912
Alternative Requirements for Sleeve Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping	N-786
Alternative Requirements for Successive Inspections of Class 1 and 2 Vessels	N-526
Alternative Requirements for Table IWB-2500-1, Examination Category B-N-1, Interior of Reactor Vessel, Category B-N-2, Welded Core Support Structures and Interior Attachments to Reactor Vessels, Category B-N-3, Removable Core Support Structures	N-885
Alternative Requirements for Upgrade, Substitution, or Reconfiguration of Examination Equipment When Using Appendix VIII Qualified Ultrasonic Examination Systems	N-780
Alternative Requirements for Visual Examinations, VT-1, VT-2, and VT-3	N-686
Alternative Requirements for Wall Thickness Restoration of Class 2 and 3 Carbon Steel Piping for Raw Water Service	N-661
Alternative Requirements for Wall Thickness Restoration of Class 2 and High Energy Class 3 Carbon Steel Piping	N-561

Subject	Case
Section XI, Division 1	
Rules for Inservice Inspection of Nuclear Power Plant Components (Cont'd)	
Alternative Requirements for Wall Thickness Restoration of Class 3 Moderate Energy Carbon Steel Piping	N-562
Alternative Requirements to Categories B-G-1, B-G-2, and C-D Bolting Examination Methods and Selection Criteria	N-652
Alternative Requirements to Stress-Based Selection Criteria for Category B-J Welds	N-609
Alternative Rules for Repair of Classes 1, 2, and 3 Austenitic Stainless Steel Piping	N-504
Alternative to Class 1 Extended Boundary End of Interval or Class 2 System Leakage Testing of the Reactor Vessel Head Flange O-Ring Leak-Detection System	N-805
Alternative to Inspection Interval Scheduling Requirements of IWA-2430	N-765
Alternative to IWA-5244 Requirements for Buried Piping	N-776
Alternative to Procurement Requirements of IWA-4143 for Nonstandard Welded Fittings	N-880
Alternative to QA Program Requirements of IWA-4142	N-878
Alternative Volumetric Coverage Requirements for Ultrasonic Examination of Class 1 and 2 Pressure Vessel Weld Joints Greater Than 2 in. (50 mm) in Thickness	N-768
Alternative Volumetric Coverage Requirements for Ultrasonic Examination of Class 1 Nozzle-to-Vessel Welds	N-858
Analytical Evaluation of Metal Loss in Class 2 and 3 Metallic Piping Buried in a Back-Filled Trench	N-806
Analytical Evaluation Procedures for Axial Flaws in Partial-Penetration Nozzle Welds	N-897
Application of Risk-Informed Insights to Increase the Inspection Interval for Pressurized Water Reactor Vessels	N-691
Austenitic Stainless Steel Cladding and Nickel Base Cladding Using Ambient Temperature Automatic or Machine Dry Underwater Laser Beam Welding (ULBW) Temper Bead Technique	N-876
Austenitic Stainless Steel Cladding and Nickel Base Cladding Using Ambient Temperature Machine GTAW Temper Bead Technique	N-829
Cladding Repair by Underwater Electrochemical Deposition in Class 1 and 2 Applications	N-840
Clarification of NDE Practical Examination Requirements	N-867
Class 1 Socket Weld Examinations	N-712
Class 3 Nonmetallic Cured-In-Place Piping	N-589
Corrective Action for Leakage Identified at Bolted Connections. Direct Use of Fracture Toughness for Flaw Evaluations of Pressure Boundary Materials in Class 1 Ferritic Steel Components	N-830
Dissimilar Metal Welds Joining Vessel Nozzles to Components ..	N-799
Evaluation Criteria for Temporary Acceptance of Degradation in Moderate Energy Class 2 or 3 Vessels and Tanks	N-705
Evaluation Criteria for Temporary Acceptance of Flaws in Class 2 or 3 Piping	N-869
Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping and Gate Valves	N-513
Evaluation of Pipe Wall Thinning	N-597
Evaluation Procedure and Acceptance Criteria for PWR Reactor Vessel Head Penetration Nozzles	N-694
Examination Requirements for Steam Generator Nozzle-to-Vessel Welds	N-593
Examination Requirements for the Core Makeup Tanks	N-873
Experience Credit for Ultrasonic Examiner Certification	N-784
Extension of Joining Personnel's Qualification Continuity	2996

Subject	Case
Section XI, Division 1	
Rules for Inservice Inspection of Nuclear Power Plant Components (Cont'd)	
Fatigue Crack Growth Rate Curves for Ferritic Steels in Boiling Water Reactor (BWR) Environments	N-917
Fatigue Crack Growth Rate Curves for Ferritic Steels in PWR Water Environment	N-643
Ferritic and Dissimilar Metal Welding Using SMAW Temper Bead Technique Without Removing the Weld Bead Crown for the First Layer	N-651
Flaw Evaluation Procedure for Cast Austenitic Stainless Steel Piping and Adjacent Fittings	N-906
Flaw Tolerance Evaluation of Cast Austenitic Stainless Steel Piping	N-838
Full Structural Dissimilar Metal Weld Overlay for Repair or Mitigation of Class 1, 2, and 3 Items	N-740
In Situ VT-3 Examination of Removable Core Support Structure Without Removal	N-849
Inspection Requirements and Evaluation Standards for Spent Nuclear Fuel Storage and Transportation Containment Systems	N-860
Lighting Requirements for Surface Examination	N-685
Location of Ultrasonic Depth-Sizing Flaws	N-537
Materials Exempted From G-2110(b) Requirement	N-890
Mechanical Piping Joints	N-923
Method for Determining Maximum Allowable False Calls When Performing Single-Sided Access Performance Demonstration in Accordance With, Appendix VIII, Supplements 4 and 6 ...	N-683
Mitigation of Flaws in NPS 3 (DN 80) and Smaller Nozzles and Nozzle Partial Penetration Welds in Vessels and Piping by Use of a Mechanical Connection Modification	N-733
Nickel Alloy Reactor Coolant Inlay and Onlay for Mitigation of PWR Full Penetration Circumferential Nickel Alloy Dissimilar Metal Welds in Class 1 Items	N-766
Optimized Structural Dissimilar Metal Weld Overlay for Mitigation of PWR Class 1 Items	N-754
Partial Excavation and Deposition of Weld Metal for Mitigation of Class 1 Items	N-847
Performance Demonstration Requirements for Examination of Unclad Reactor Pressure Vessel Welds, Excluding Flange Welds	N-664
Pipe Specific Evaluation Procedures and Acceptance Criteria for Flaws in Piping that Exceed the Acceptance Standards	N-494
Pressure Testing of Class 2 and 3 Items Following Repair or Replacement Activities	N-925
Pressure Testing of Containment Penetration Piping	N-751
Purchase, Exchange, or Transfer of Material Between Nuclear Owners	N-911
Purchase, Exchange, or Transfer of Material Between Nuclear Plant Sites	N-528
PWR Class 1 Primary Piping Alloy 600 Full Penetration Branch Connection Weld Metal Buildup for Material Susceptible to Primary Water Stress Corrosion Cracking	N-853
Qualification Requirements for Bolts and Studs	N-845
Qualification Requirements for Dissimilar Metal Piping Welds ..	N-695
Qualification Requirements for Full Structural Overlaid Wrought Austenitic Piping Welds	N-653
Qualification Requirements for Mandatory Appendix VIII Piping Examinations Conducted From the Inside Surface	N-696
Qualification Requirements for Ultrasonic Examination of Wrought Austenitic Piping Welds	N-658
Quality Assurance Program Requirements for Owners	N-517

Subject	Case
Section XI, Division 1	
Rules for Inservice Inspection of Nuclear Power Plant Components (Cont'd)	
Reactor Vessel Head-to-Flange Weld Examinations	N-747
Reactor Vessel Threads in Flange Examinations	N-864
Reference Crack Growth Rate Curves for Stress Corrosion Cracking of Low Alloy Steels in Boiling Water Reactor Environments	N-896
Reference Fatigue Crack Growth Rate Curves for Austenitic Stainless Steels in Pressurized Water Reactor Environments	N-809
Reference Primary Water Stress Corrosion Crack Growth Rate Curves for Alloy 690 Materials and Associated Weld Materials Alloys 52, 152, and Variant Welds Exposed to Pressurized Water Reactor Environments	N-909
Reference Stress Corrosion Crack Growth Rate Curves for Irradiated Austenitic Stainless Steels in Light Water Reactor Environments	N-889
Repair of Buried Class 2 and 3 Piping Using Carbon Fiber-Reinforced Polymer Composite	N-871
Repair of Classes 1 and 2 SB-163, UNS N06600 Steam Generator Tubing	N-576
Repair Welding Using Automatic or Machine Gas Tungsten-Arc Welding (GTAW) Temper Bead Technique	N-432
Repair/Replacement Activity Documentation Requirements and Inservice Inspection Summary Report Preparation and Submission	N-532
Risk-Informed Categorization and Treatment for Repair/Replacement Activities in Class 2 and 3 Systems	N-752
Risk-Informed Requirements for Class 1, 2, or 3 Piping, Method A	N-577
Risk-Informed Requirements for Class 1, 2, or 3 Piping, Method B	N-578
Risk-Informed Safety Classification for Use in Risk-Informed Repair/Replacement Activities	N-660
Roll Expansion of Class 1 Control Rod Drive Bottom Head Penetrations in BWRs	N-730
Roll Expansion of Class 1 In-Core Housing Bottom Head Penetrations in BWRs	N-769
Rotation of Snubbers and Pressure Retaining Items for the Purpose of Testing or Preventive Maintenance	N-508
Similar and Dissimilar Metal Welding Using Ambient Temperature Automatic or Machine Dry Underwater Laser Beam Welding (ULBW) Temper Bead Technique	N-803
Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	N-638
Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique for BWR CRD Housing/Stub Tube Repairs	N-606

Subject	Case
Section XI, Division 1	
Rules for Inservice Inspection of Nuclear Power Plant Components (Cont'd)	
Similar and Dissimilar Metal Welding Using Ambient Temperature SMAW or Machine GTAW Temper Bead Technique	N-888
Similar and Dissimilar Metal Welding Using Ambient Temperature SMAW Temper Bead Technique	N-839
Successive Inspections	N-624
Successive Inspections of Class 1 and 2 Piping Welds	N-735
Temper Bead Procedure Qualification Requirements for Repair/Replacement Activities Without Postweld Heat Treatment	N-762
Temporary Acceptance of Leakage Through Brazed Joints of Class 3 Copper, Copper-Nickel, and Nickel-Copper Moderate Energy Piping	N-874
Third Party NDE Certification Organizations	N-788
Third-Party NDE Certification for Non-U.S. Plant Sites	N-868
Transfer of Welder, Welding Operator, Brazer, and Brazing Operator Qualifications Between Owners	N-600
Ultrasonic Examination in Lieu of Radiography for Welds in Ferritic or Austenitic Pipe	N-831
Ultrasonic Examination of Cast Austenitic Piping Welds From the Outside Surface	N-824
Ultrasonic Examination of Full Penetration Nozzles in Vessels, Examination Category B-D, Reactor Nozzle-To-Vessel Welds and Nozzle Inside Radius Section, Figures IWB-2500-7(a), (b), (c), and (d)	N-613
Ultrasonic Examination of Full Penetration Vessel Weld Joints in Figures IWB-2500-1 Through IWB-2500-6	N-826
Underwater Welding	N-516
Vision Tests	N-753
Visual Examination	N-823
Visual Examinations for PWR Pressure Retaining Welds in Class 1 Components Fabricated With Alloy 600/82/182 Materials	N-722
Weld Overlay of Class 1, 2, and 3 Socket Welded Connections	N-666
Weld Residual Stress Distributions for Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082, UNS W86182, UNS N06052, or UNS W86152 Weld Filler Material	N-899
Section XI, Division 2	
Requirements for Reliability and Integrity Management (RIM) Programs for Nuclear Power Plants	
Inspection Requirements and Evaluation Standards for Spent Nuclear Fuel Storage and Transportation Containment Systems	N-860
Section XI, Division 3	
Rules for Inspection and Testing of Components of Liquid-Metal-Cooled Plants	
Alternative Inservice Inspection Requirements for Liquid-Metal Reactor Passive Components	N-875

INDEX OF MATERIAL SPECIFICATIONS REFERRED TO IN CASES (23)

Materials	Case	Materials	Case
ASME Specifications		ASME Specifications (Cont'd)	
SA-6	N-71	SA-533 Class 1 Grade B	N-830, 888
SA-20/SA-20M	N-655	SA-533 Class 1 Grade C	N-888
SA-29/SA-29M	N-893	SA-533 Class 2 Grade A	N-888
SA-36	N-71, 249	SA-533 Class 2 Grade B	N-888
SA-106	N-900	SA-533 Class 2 Grade C	N-888
SA-182	N-60, 635, 636, 741, 767, 910	SA-533 Type A, Class 2	N-890
SA-182 Grades F304, F304L, F316, F316L	N-548	SA-533 Type B Class 1	N-610, 847, 888, 896
SA-193	N-60, 71, 249	SA-533 Type B Class 2	N-633, 847, 888, 890
SA-194	N-60, 71, 249, 579	SA-537	N-650
SA-212	N-636	SA-537 Class 1	N-707
SA-213	N-636	SA-537 Grade B	N-888
SA-217 Grade C12	N-249	SA-540 Grades B21, B22, B23, B24	N-249
SA-234	N-900	SA-541 Class 1	N-888
SA-240	N-635, 636, 637, 736, 741, 834, 910	SA-542 Classes 1, 2, 3, 4	N-71
SA-240 Type XM-17	N-249	SA-563	N-71, 249
SA-249	N-636, 637, 736	SA-564 Grade 630 Types XM-12, XM-13 ..	N-249
SA-276 Type 403	N-4	SA-572 Grades 42, 50	N-71
SA-302 Grade B	N-638, 839	SA-574	N-249
SA-307 Grade A	N-249	SA-638 Grade 660	N-60
SA-312	N-636, 637, 767, 900	SA-666	N-767
SA-320	N-249, 754	SA-675	N-879
SA-325 Type 1	N-249	SA-675 Grades 65, 70	N-71
SA-335 Grade P22	N-774	SA-693	N-249
SA-336	N-767	SA-738	N-655, 841
SA-351	N-539	SA-789	N-635, 741, 910
SA-352 Grade LC1	N-847, 888	SA-790	N-635, 741, 910
SA-352 Grade LCB	N-847, 888	SA-813	N-636
SA-354 Grades BC, BD	N-249	SA-815	N-635, 741, 908
SA-358	N-636	SA-928	N-635
SA-358/SA-358M	N-815	SA-995	N-564
SA-370	N-351, 516, 606, 638, 651, 762, 766, 791, 793, 794, 796, 803, 807, 839, 888	SB-148	N-855
SA-376	N-636, 900	SB-148 Alloys 952, 954	N-133
SA-395	N-205	SB-150	N-855
SA-403	N-636, 637, 900	SB-150 Alloys 614, 630	N-133, 249
SA-449	N-249	SB-150 Alloy C64200	N-249
SA-453 Grade 660	N-60, 249, 733	SB-150 Alloys C61400, C63000	N-249
SA-479	N-60, 635, 636, 637, 736	SB-163	N-576, 722
SA-479 Type 316	N-703	SB-166	N-525, 580, 722, 836, 872, 898
SA-479 Type XM-30	N-62	SB-167	N-525, 580, 698, 722, 725, 872, 898
SA-487	N-71	SB-168	N-525, 580, 722, 872, 898
SA-487 Grade 2Q	N-847, 888	SB-169 Alloy C61400	N-249
SA-494	N-856	SB-209	N-519, 866
SA-494 Grade M35-1	N-901	SB-210	N-519
SA-508	N-928	SB-221	N-519, 673
SA-508 Class 1	N-888	SB-241/SB-241M	N-519
SA-508 Class 2	N-888, 896	SB-247	N-519, 817, 819
SA-508 Class 3	N-888	SB-265	N-699
SA-508 Grade 1A	N-881	SB-271 Alloy C95400	N-249
SA-508 Grade 2, Class 1	N-610, 830	SB-338 Grade 2	N-699
SA-508 Grade 2, Class 2	N-830, 890	SB-348 Grade 2	N-699
SA-508 Grade 3, Class 1	N-610, 830	SB-366	N-621, 625, 859
SA-508 Grade 3, Class 2	N-830, 890	SB-493	N-710
		SB-523	N-710
		SB-550	N-710

Materials	Case
ASME Specifications (Cont'd)	
SB-551	N-710
SB-564	N-539, 580, 621, 625, 725, 872, 898
SB-574	N-621, 625
SB-575	N-621, 625
SB-584 Alloy C93700	N-249
SB-619	N-621, 625
SB-622	N-621, 625
SB-626	N-621, 625
SB-637	N-60
SB-658	N-710
SB-688	N-539
SB-691	N-746
SFA-5.1	N-651
SFA-5.4	N-516
SFA-5.5	N-651
SFA-5.11	N-453, 454, 455, 766, 770
SFA-5.14	N-453, 454, 455, 766, 770, 898
ASTM Specifications	
A48	N-500
A108-99	N-71, 249
A108 Grade 1030-1045	N-793
A126	N-500
A148-93b	N-71, 249
A182-75 Grade F6	N-62
A217-75 Grade CA15	N-62
A228-93	N-249
A240-75 Grades 410, 410S	N-62
A262	N-834
A268-74a Grade TP410	N-62
A276	N-570
A276-73 Type 403	N-131
A276-75 Types 316, 403, 410, 420, 440C	N-62
A276-98b Types 420, 440C	N-249
A302, Grade B	N-896
A314-75 Grades 403, 410, 416, 416Se	N-62
A322 Grade 4130-4145	N-793
A322-91 Grade 4150	N-249
A322-13	N-893
A331-74 Grades 4140, 4340	N-62
A331-95 Grade 8620CW	N-71
A395	N-500
A416	N-820
A434-90a Classes BB, BC, BD	N-249
A453-75 Grade 660	N-62
A458-71 Grade 651	N-131
A471-94 Classes 2 through 6	N-249
A473	N-469
A477-41 Grade 651	N-131
A479-75 Grade 410	N-62, 131
A490-97	N-249
A508/A508M-18	N-928
A508/A508M Grades 2 and 3	N-830
A511-08	N-60
A513-98	N-249, 793, 796
A514-94a	N-71
A519-96	N-249, 793, 796
A519/A519M-17	N-893
A521-96 Class CG	N-249
A533 Grade B Classes 1 and 2	N-830
A536	N-500
A546-82	N-249
A554-08a	N-60

Materials	Case
ASTM Specifications (Cont'd)	
A564 Type XM-13	N-249
A564-74 Grades 630, XM-25	N-131
A565-74 Grades 615, 616	N-62, 131
A567-74 Grade 1	N-62
A572 Grades 50, 65	N-632
A572 Grades 60, 65	N-213
A576 Grade 1008-1030	N-793
A579-99 Grade 12a	N-249
A580-83 Grades 302, 304, 316, 317 Class B	N-249
A580-98 Grades 302, 304, 316, 317 Class B	N-249
A581-80	N-249
A582-75 Grades 416, 416Se	N-62
A582-95b Grades 303, 303Se, 416, 416Se	N-249
A611-97 Grades A,B,C	N-71
A615	N-807
A633 Grade E	N-213
A638-70 Grade 660	N-62
A653-99	N-249
A668-96e1 Classes B,C,D,F,K,L	N-71
A668-96e1 Classes B,C,D,F,K,L,M,N	N-249
A693-84 Grade 630	N-249
A703	N-564
A706	N-213, 807
A709-06	N-763
A743-03	N-736
A790-04a	N-741
A890	N-564
A988/A988M-11	N-834
A1011-15 Grades 33, 36, 45	N-71
B16-92 Alloy C36000, Class H102	N-249
B124-99 Alloy C37700, Class M30	N-249
B243	N-673
B311	N-673
B366	N-454
B462	N-455
B464	N-453
B625	N-453, 454
B637 Grade 688 Type II, 718	N-62
B649	N-453, 454, 455
B653	N-710
B670-95	N-249
B673	N-453
C581	N-871
D149	N-871
D570	N-871
D638	N-589, 871
D696	N-589
D698	N-806
D790	N-589
D903	N-589
D1141	N-871
D2105	N-589
D2240	N-871
D2247	N-871
D2344	N-871
D2369	N-871
D2487	N-806
D2488	N-806
D2583	N-589, 871
D2590	N-589
D2990	N-589, 871
D3035	N-886
D3039	N-871

Materials	Case
ASTM Specifications (Cont'd)	
D3045	N-871
D3171	N-871
D3418	N-871
D3479	N-871
D3983	N-589
D4018	N-871
D4253	N-806
D4354	N-806
D4541	N-871
D4787	N-589
D5162	N-589
D5868	N-871
D7290	N-871
D7616	N-871
E38	N-840
E39	N-840
E76	N-840
E185-82	N-519
E354	N-840
E384-16	N-881
E354-93	N-576
E813	N-871
E831	N-871
E1640	N-871
E1820	N-830
E1921	N-830

Materials	Case
ASTM Specifications (Cont'd)	
E1921-97	N-631
E2160	N-871
E2546-15	N-881
F714-08	N-886
F1216	N-589
F2880	N-891
AWS Specifications	
A4.3	N-763
A5.1	N-807
A5.5	N-807
A5.18	N-807
A5.20	N-807
A5.28	N-807
A5.29	N-807
D1.1	N-793, 794, 796
D3.6M-99	N-803
International Specifications	
JIS G4303	N-708
JIS G 0595	N-860
CHARTS FOR VESSELS UNDER EXTERNAL PRESSURE	
Figure 1 Chart for Determining Shell	
Thickness of Cylindrical and Spherical	
Shell Under External Pressure When	
Constructed of High Alloy UNS S32760	
and UNS J93380	N-564

APPLICABILITY INDEX FOR SECTION XI CASES

(23)

This Index provides the range of Section XI Editions and Addenda applicable to each Section XI Case.

Code Case No.	Title	Applicability	
		From	Up to and Including
N-34	Inservice Inspection of Welds on Nuclear Components	1970 Edition	1971 Edition with the Summer 1973 Addenda
N-72	Partial Postponement of Category B-C Examinations for Class 1 Components	1974 Edition	1977 Edition with the Winter 1977 Addenda
N-73	Partial Postponement of Category B-D Examinations for Class 1 Components	1974 Edition	1977 Edition with the Winter 1977 Addenda
N-98	Ultrasonic Examination — Calibration Block Tolerances [Note (1)]:		
	(a) For Division 1	1974 Edition	1977 Edition with the Summer 1978 Addenda
	(b) For Division 2	1974 Edition with the Winter 1975 Addenda	Not applicable
N-112	Acceptance Standards Class 2 and 3 Components	1974 Edition	1974 Edition with the Winter 1975 Addenda
N-113	Basic Calibration Block for Ultrasonic Examination of Welds 10 in. to 13 in. Thick	1971 Edition with the Summer 1973 Addenda	1974 Edition with the Summer 1976 Addenda
N-113-1	Basic Calibration Block for Ultrasonic Examination of Welds 10 in. to 14 in. Thick	1971 Edition with the Summer 1973 Addenda	2001 Edition
N-118	Examination — Acceptance Standards for Surface Indications in Cladding	1974 Edition with the Summer 1974 Addenda	1974 Edition with the Winter 1975 Addenda
N-166	Reference by Section XI to N626.1-1975 for Qualification and Duties of Authorized Nuclear Inservice Inspection	1974 Edition	1977 Edition
N-167	Minimum Section Thickness Requirements for Repair of Nozzles	1974 Edition	1977 Edition with the Winter 1977 Addenda
N-198	Exemption From Examination for ASME Class 2 Piping Located at Containment Penetrations	1974 Edition with the Summer 1976 Addenda	1977 Edition with the Winter 1977 Addenda
N-198-1	Exemption From Examination for ASME Class 1 and 2 Piping Located at Containment Penetrations	1974 Edition with the Summer 1976 Addenda	1992 Edition with the 1993 Addenda
N-209	Conditional Acceptance of Identifiable Isolated or Random Rounded Indications		
	(a) For Class 1 Systems	1974 Edition	1980 Edition with the Winter 1980 Addenda
	(b) For Class 2 Systems	1974 Edition with the Summer 1976 Addenda	1983 Edition
N-210	Exemptions to Hydrostatic Test After Repairs	1974 Edition	1977 Edition with the Winter 1977 Addenda
N-211	Recalibration of Ultrasonic Equipment Upon Change of Personnel		
	(a) To meet requirements of I-4230	1971 Edition with the Summer 1973 Addenda	1974 Edition with the Summer 1976 Addenda
	(b) To meet requirements of III-3330	1977 Edition	1980 Edition
N-216	Alternative Rules for Reactor Vessel Closure Stud Examination	1977 Edition	1977 Edition with the Winter 1977 Addenda
N-234	Time Between Ultrasonic Calibration Checks		
	(a) To meet requirements of I-4230	1971 Edition with the Summer 1973 Addenda	1974 Edition with the Summer 1976 Addenda
	(b) To meet requirements of III-3330	1977 Edition	1980 Edition
N-235	Ultrasonic Calibration Checks per Section V	1974 Edition with the Winter 1976 Addenda	1977 Edition with the Summer 1979 Addenda
N-236	Repair and Replacement of Class MC Vessels	1974 Edition	1983 Edition with the Winter 1984 Addenda

Code Case No.	Title	Applicability	
		From	Up to and Including
N-236-1	Repair and Replacement of Class MC Vessels	1974 Edition	1989 Edition with the 1990 Addenda
N-252	Low Energy Capacitive Discharge Welding Method for Temporary or Permanent Attachments to Components and Supports	1971 Edition	1980 Edition with the Winter 1980 Addenda
N-278	Alternative Ultrasonic Calibration Block Configuration, I-3131 and T-434.3		
	(a) To meet requirements of I-3131	1974 Edition	1974 Edition with the Summer 1976 Addenda
	(b) To meet requirements of T-434.3	1977 Edition	1983 Edition with the Winter 1984 Addenda
N-288	Hydrostatic Test Requirements for Class 1 and 2 Components	1974 Edition	1980 Edition with the Winter 1980 Addenda
N-306	Calibration Block Material Selection, Appendix I, I-3121 [Note (2)]	1974 Edition with the Summer 1975 Addenda	1974 Edition with the Summer 1976 Addenda
N-307	Revised Ultrasonic Examination Volume for Class 1 Bolting, Examination Category B-G-1, When the Examinations Are Conducted From the Center- Drilled Hole	1974 Edition	1983 Edition with the Winter 1984 Addenda
N-307-1	Revised Ultrasonic Examination Volume for Class 1 Bolting, Table IWB-2500-1, Examination Category B-G-1, When the Examinations Are Conducted From the Center-Drilled Hole	1974 Edition	1998 Edition with the 1999 Addenda
N-307-2	Revised Ultrasonic Examination Volume for Class 1 Bolting, Table IWB-2500-1, Examination Category B-G-1, When the Examinations Are Conducted From the End of the Bolt or Stud or From the Center- Drilled Hole	1974 Edition	1998 Edition with the 1999 Addenda
N-307-3	Ultrasonic Examination of Class 1 Bolting, Table IWB-2500-1, Examination Category B-G-1	1974 Edition	1998 Edition with the 1999 Addenda
N-308	Documentation of Repairs and Replacements of Components in Nuclear Power Plants	1974 Edition	1980 Edition with the Winter 1981 Addenda
N-311	Alternative Examination of Outlet Nozzle on Secondary Side of Steam Generators	1977 Edition with the Winter 1977 Addenda	2004 Edition
N-322	Examination Requirements for Integrally Welded or Forged Attachments to Class 1 Piping at Containment Penetrations	1977 Edition with the Summer 1978 Addenda	1992 Edition with the 1993 Addenda
N-323	Alternative Examinations for Integrally Welded Attachments to Vessels	1974 Edition	1974 Edition with the Winter 1976 Addenda
N-323-1	Alternative Examination for Welded Attachments to Pressure Vessels	1980 Edition with the Winter 1981 Addenda	1995 Edition with the 1996 Addenda
N-334	Examination Requirements for Integrally Welded or Forged Attachments to Class 2 Piping at Containment Penetrations	1977 Edition with the Summer 1978 Addenda	1980 Edition with the Summer 1980 Addenda
N-335	Rules for Ultrasonic Examination of Similar and Dissimilar Metal Piping Welds	1974 Edition	1980 Edition with the Winter 1981 Addenda
N-335-1	Rules for Ultrasonic Examination of Similar and Dissimilar Metal Piping Welds	1974 Edition	1980 Edition with the Winter 1981 Addenda
N-343	Alternative Scope of Examination of Attachment Welds for Examination Categories B-H, B-K-1, and C-C	1974 Edition	1980 Edition with the Winter 1981 Addenda
N-355	Calibration Block for Angle Beam Ultrasonic Examination of Large Fittings in Accordance With Appendix III-3410 [Note (3)]	1974 Edition with the Winter 1975 Addenda	1983 Edition
N-356	Certification Period for Level III NDE Personnel	1977 Edition with the Winter 1977 Addenda	1983 Edition
N-375	Rules for Ultrasonic Examination of Bolts and Studs	1980 Edition	1980 Edition with the Winter 1981 Addenda
N-375-1	Rules for Ultrasonic Examination of Bolts and Studs	1980 Edition	1980 Edition with the Winter 1981 Addenda
N-375-2	Rules for Ultrasonic Examination of Bolts and Studs	1971 Edition	1983 Edition
N-389	Alternative Rules for Repairs, Replacements, or Modifications	1974 Edition with the Summer 1975 Addenda	1986 Edition with the 1987 Addenda
N-389-1	Alternative Rules for Repairs, Replacements, or Modifications	1974 Edition with the Summer 1975 Addenda	1992 Edition with the 1993 Addenda
N-390	Evaluation Criteria for Flaws Located in a Flange or Shell Region Near a Structural Discontinuity	1974 Edition with the Summer 1975 Addenda	1983 Edition with the Summer 1983 Addenda

Code Case No.	Title	Applicability	
		From	Up to and Including
N-401	Eddy Current Examination	1974 Edition with the Summer 1976 Addenda	1989 Edition with the 1989 Addenda
N-401-1	Eddy Current Examination	1974 Edition with the Summer 1974 Addenda	1989 Edition with the 1989 Addenda
N-402	Eddy Current Calibration Standard Material	1980 Edition with the Winter 1980 Addenda	1989 Edition with the 1989 Addenda
N-402-1	Eddy Current Calibration Standards	1980 Edition with the Winter 1980 Addenda	1989 Edition with the 1989 Addenda
N-406	Alternative Rules for Replacement	1977 Edition with the Summer 1978 Addenda	1986 Edition
N-408	Alternative Rules for Examination of Class 2 Piping	1974 Edition	1983 Edition
N-408-1	Alternative Rules for Examination of Class 2 Piping	1974 Edition	1983 Edition
N-408-2	Alternative Rules for Examination of Class 2 Piping	1974 Edition	1989 Edition
N-408-3	Alternative Rules for Examination of Class 2 Piping	1974 Edition	1989 Edition
N-409	Procedure and Personnel Qualification for Ultrasonic Detection and Sizing of Intergranular Stress Corrosion Cracking in Austenitic Piping Welds	1974 Edition	1986 Edition with the 1986 Addenda
N-409-1	Procedure and Personnel Qualification Requirements for Ultrasonic Detection and Sizing of Intergranular Stress Corrosion Cracking in Austenitic Piping Welds	1974 Edition	1986 Edition with the 1987 Addenda
N-409-2	Procedure and Personnel Qualification Requirements for Ultrasonic Detection and Sizing of Intergranular Stress Corrosion Cracking in Austenitic Piping Welds	1974 Edition	1989 Edition
N-409-3	Procedure and Personnel Qualification Requirements for Ultrasonic Detection and Sizing of Intergranular Stress Corrosion Cracking in Austenitic Piping Welds	1974 Edition	1989 Edition
N-415	Alternative Rules for Testing Pressure Relief Devices	1974 Edition	1983 Edition with the Winter 1984 Addenda
N-416	Alternative Rules for Hydrostatic Testing of Repair or Replacement of Class 2 Piping	1974 Edition	1989 Edition with the 1990 Addenda
N-416-1	Alternative Pressure Test Requirement for Welded Repairs or Installation of Replacement Items by Welding Class 1, 2, and 3	1974 Edition	1998 Edition
N-416-2	Alternative Pressure Test Requirement for Welded Repairs, Fabrication Welds for Replacement Parts and Piping Subassemblies, or Installation of Replacement Items by Welding, Class 1, 2, and 3	1977 Edition with the Summer 1978 Addenda	1998 Edition
N-416-3	Alternative Pressure Test Requirement for Welded or Brazed Repairs, Fabrication Welds or Brazed Joints for Replacement Parts and Piping Subassemblies, or Installation of Replacement Items by Welding or Brazing, Classes 1, 2, and 3	1977 Edition with the Summer 1978 Addenda	1998 Edition
N-416-4	Alternative Pressure Test Requirement for Welded or Brazed Repairs, Fabrication Welds or Brazed Joints for Replacement Parts and Piping Subassemblies, or Installation of Replacement Items by Welding or Brazing, Classes 1, 2, and 3	1977 Edition with the Summer 1978 Addenda	2001 Edition with the 2002 Addenda
N-419	Extent of VT-1 Examinations, Category B-G-1 of Table IWB-2500-1	1977 Edition with the Summer 1978 Addenda	1983 Edition with the Winter 1984 Addenda
N-424	Qualification of Visual Examination Personnel	1977 Edition with the Summer 1978 Addenda	1983 Edition
N-426	Extent of VT-1 Examinations, Category B-G-2 of Table IWB-2500-1	1977 Edition with the Summer 1978 Addenda	1983 Edition with the Winter 1984 Addenda
N-427	Code Cases in Inspection Plans	1971 Edition	1986 Edition
N-429	Alternate Rules for Ultrasonic Instrument Calibration	1980 Edition with the Winter 1980 Addenda	1983 Edition with the Winter 1983 Addenda
N-429-1	Alternative Rules for Ultrasonic Instrument Calibration	1980 Edition with the Winter 1980 Addenda	1986 Edition with the 1986 Addenda
N-432	Repair Welding Using Automatic or Machine Gas Tungsten-Arc Welding (GTAW) Temper Bead Technique	1971 Edition with the Summer 1973 Addenda	1989 Edition with the 1990 Addenda
N-432-1	Repair Welding Using Automatic or Machine Gas Tungsten-Arc Welding (GTAW) Temper Bead Technique	1971 Edition with the Summer 1973 Addenda	2021 Edition
N-435	Alternative Examination Requirements for Vessels With Wall Thickness 2 in. or Less	1974 Edition with the Summer 1975 Addenda	1986 Edition

Code Case		Applicability	
No.	Title	From	Up to and Including
N-435-1	Alternative Examination Requirements for Vessels With Wall Thickness 2 in. or Less	1974 Edition with the Summer 1975 Addenda	1995 Edition
N-436	Alternative Methods for Evaluation of Flaws in Austenitic Piping	1983 Edition	1986 Edition
N-436-1	Alternative Methods for Evaluation of Flaws in Austenitic Piping	1983 Edition	1986 Edition
N-437	Use of Digital Readout and Digital Measurement Devices for Performing Pressure Tests	1974 Edition	1986 Edition
N-444	Preparation of Inspection Plans	1974 Edition with the Summer 1975 Addenda	1986 Edition with the 1986 Addenda
N-445	Use of Later Edition of SNT-TC-1A for Qualification of Nondestructive Examination Personnel	1977 Edition with the Summer 1978 Addenda	1986 Edition
N-446	Recertification of Visual Examination Personnel	1977 Edition with the Summer 1978 Addenda	1986 Edition
N-448	Qualification of VT-2 and VT-3 Visual Examination Personnel	1977 Edition with the Summer 1978 Addenda	1986 Edition with the 1987 Addenda
N-449	Qualification of VT-4 Visual Examination Personnel	1977 Edition with the Summer 1978 Addenda	1983 Edition with the Winter 1983 Addenda
N-457	Qualification Specimen Notch Location for Ultrasonic Examination of Bolts and Studs	1983 Edition with the Winter 1983 Addenda	1992 Edition with the 1993 Addenda
N-458	Magnetic Particle Examination of Coated Materials	1980 Edition with the Winter 1981 Addenda	1995 Edition
N-458-1	Magnetic Particle Examination of Coated Materials	1980 Edition with the Winter 1981 Addenda	1995 Edition
N-460	Alternative Examination Coverage for Class 1 and Class 2 Welds	1974 Edition	2007 Edition
N-461	Alternative Rules for Piping Calibration Block Thickness	1974 Edition with the Summer 1975 Addenda	1995 Edition
N-461-1	Alternative Rules for Piping Calibration Block Thickness	1974 Edition with the Summer 1975 Addenda	1995 Edition
N-463	Evaluation Procedures and Acceptance Criteria for Flaws in Class 1 Ferritic Piping That Exceed the Acceptance Standards of IWB-3514.2	1983 Edition with the Winter 1983 Addenda	1989 Edition with the 1989 Addenda
N-463-1	Evaluation Procedures and Acceptance Criteria for Flaws in Class 1 Ferritic Piping That Exceed the Acceptance Standards of IWB-3514.2	1983 Edition with the Winter 1983 Addenda	1989 Edition with the 1989 Addenda
N-465	Alternative Rules for Pump Testing	1974 Edition with the Winter 1975 Addenda	1986 Edition with the 1987 Addenda
N-465-1	Alternative Rules for Pump Testing	1974 Edition with the 1975 Addenda	1995 Edition with the 1995 Addenda
N-471	Acoustic Emissions for Successive Inspections	1974 Edition	1998 Edition with the 1999 Addenda
N-472	Use of Digital Readout and Digital Measurement Devices for Performing Pump Vibration Testing	1974 Edition	1986 Edition with the 1987 Addenda
N-473	Alternate Rules for Valve Testing	1974 Edition with the Summer 1975 Addenda	1986 Edition with the 1987 Addenda
N-473-1	Alternative Rules for Valve Testing	1974 Edition with the 1975 Addenda	1995 Edition with the 1995 Addenda
N-478	Inservice Inspection for Class CC Concrete Components of Light-Water Cooled Power Plants	1974 Edition	1986 Edition with the 1987 Addenda
N-479	Boiling Water Reactor (BWR) Main Steam Hydrostatic Test	1977 Edition with the Winter 1977 Addenda	1989 Edition with the 1989 Addenda
N-479-1	Boiling Water Reactor (BWR) Main Steam Hydrostatic Test	1977 Edition with the Winter 1977 Addenda	1989 Edition with the 1990 Addenda
N-480	Examination Requirements for Pipe Wall Thinning Due to Single Phase Erosion and Corrosion	1974 Edition	1992 Edition with the 1993 Addenda
N-481	Alternative Examination Requirements for Cast Austenitic Pump Casings	1977 Edition with the Summer 1978 Addenda	1998 Edition with the 1999 Addenda
N-485	Eddy Current Examination of Coated Ferritic Surfaces as an Alternative to Surface Examination	1980 Edition with the Winter 1981 Addenda	1989 Edition with the 1990 Addenda
N-485-1	Eddy Current Examination of Coated Ferritic Surfaces as an Alternative to Surface Examination	1980 Edition with the Winter 1981 Addenda	1995 Edition
N-486	Inservice Inspection, Repair, and Replacement Requirements for Class MC and Metallic Liners of Class CC Components	1974 Edition	1989 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-489	Alternative Rules for Level III NDE Qualification Examinations	1974 Edition with the Summer 1975 Addenda	1989 Edition with the 1989 Addenda
N-490	Alternative Vision Test Requirements for Nondestructive Examiners	1974 Edition with the Summer 1975 Addenda	1989 Edition with the 1990 Addenda
N-490-1	Alternative Vision Test Requirements for Nondestructive Examiners	1974 Edition with the Summer 1975 Addenda	1989 Edition with the 1990 Addenda
N-491	Alternative Rules for Examination of Class 1, 2, 3, and MC Component Supports of Light-Water Cooled Power Plants	1977 Edition with the Summer 1978 Addenda	1989 Edition with the 1989 Addenda
N-491-1	Alternative Rules for Examination of Class 1, 2, 3, and MC Component Supports of Light-Water Cooled Power Plants	1977 Edition with the Summer 1978 Addenda	1989 Edition with the 1989 Addenda
N-491-2	Alternative Rules for Examination of Class 1, 2, 3, and MC Component Supports of Light-Water Cooled Power Plants	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1996 Addenda
N-494	Pipe Specific Evaluation Procedures and Acceptance Criteria for Flaws in Class 1 Ferritic Piping that Exceed the Acceptance Standards of IWB-3514.2	1974 Edition with the Winter 1975 Addenda	1995 Edition
N-494-1	Pipe Specific Evaluation Procedures and Acceptance Criteria for Flaws in Class 1 Ferritic Piping that Exceed the Acceptance Standards of IWB-3514.2	1974 Edition with the Winter 1975 Addenda	1995 Edition
N-494-2	Pipe Specific Evaluation Procedures and Acceptance Criteria for Flaws in Class 1 Ferritic Piping that Exceed the Acceptance Standards of IWB-3514.2	1974 Edition with the Winter 1975 Addenda	1995 Edition
N-494-3	Pipe Specific Evaluation Procedures and Acceptance Criteria for Flaws in Class 1 Ferritic Piping that Exceed the Acceptance Standards of IWB-3514.2 and in Class 1 Austenitic Piping that Exceed the Acceptance Standards of IWB-3514.3	1974 Edition with the Winter 1975 Addenda	1995 Edition
N-494-4	Pipe Specific Evaluation Procedures and Acceptance Criteria for Flaws in Piping that Exceed the Acceptance Standards	1983 Edition	2001 Edition
N-495	Hydrostatic Testing of Relief Valves	1977 Edition	1989 Edition with the 1990 Addenda
N-496	Helical-Coil Threaded Inserts	1977 Edition with the Summer 1978 Addenda	1989 Edition with the 1990 Addenda
N-496-1	Helical-Coil Threaded Inserts	1977 Edition with the Summer 1978 Addenda	1995 Edition
N-496-2	Helical-Coil Threaded Inserts	1977 Edition with the Summer 1978 Addenda	1998 Edition
N-498	Alternative Rules for 10-Year Hydrostatic Pressure Testing for Class 1 and 2 Systems	1974 Edition with the Summer 1975 Addenda	1992 Edition with the 1992 Addenda
N-498-1	Alternative Rules for 10-Year System Hydrostatic Testing for Class 1, 2, and 3 Systems	1974 Edition with the Summer 1975 Addenda	1998 Edition with the 2000 Addenda
N-498-2	Alternative Requirements for 10-Year System Hydrostatic Testing for Class 1, 2 and 3 Systems	1974 Edition with the Summer 1975 Addenda	1998 Edition with the 2000 Addenda
N-498-3	Alternative Requirements for 10-Year System Hydrostatic Testing for Class 1, 2 and 3 Systems	1974 Edition with the Summer 1975	1998 Edition with the 2000 Addenda
N-498-4	Alternative Requirements for 10-Year System Hydrostatic Testing for Class 1, 2 and 3 Systems	1974 Edition with the Summer 1975	1998 Edition with the 2000 Addenda
N-503	Limited Certification of Nondestructive Examination Personnel	1977 Edition with the Summer 1978 Addenda	1992 Edition
N-504	Alternative Rules for Repair of Class 1, 2, and 3 Austenitic Stainless Steel Piping	1977 Edition with the Summer 1978 Addenda	1986 Edition with the 1987 Addenda
N-504-1	Alternative Rules for Repair of Class 1, 2, and 3 Austenitic Stainless Steel Piping	1977 Edition with the Summer 1978 Addenda	1995 Edition
N-504-2	Alternative Rules for Repair of Class 1, 2, and 3 Austenitic Stainless Steel Piping	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1995 Addenda
N-504-3	Alternative Rules for Repair of Class 1, 2, and 3 Austenitic Stainless Steel Piping	1977 Edition with the Summer 1978 Addenda	2004 Edition
N-504-4	Alternative Rules for Repair of Class 1, 2, and 3 Austenitic Stainless Steel Piping	1977 Edition with the Summer 1978 Addenda	2004 Edition with the 2006 Addenda
N-508	Rotation of Serviced Snubbers and Pressure Relief Valves for the Purpose of Testing	1977 Edition	1989 Edition with the 1990 Addenda
N-508-1	Rotation of Serviced Snubbers and Pressure Relief Valves for the Purpose of Testing	1977 Edition	1995 Edition with the 1995 Addenda

Code Case No.	Title	Applicability	
		From	Up to and Including
N-508-2	Rotation of Serviced Snubbers and Pressure Relief Valves for the Purpose of Testing	1977 Edition	1998 Edition with the 2000 Addenda
N-508-3	Rotation of Serviced Snubbers and Pressure Relief Valves for the Purpose of Testing	1977 Edition with the Winter 1978 Addenda	2001 Edition with the 2003 Addenda
N-508-4	Rotation of Snubbers and Pressure Retaining Items for the Purpose of Testing or Preventive Maintenance	1989 Edition	2007 Edition with the 2008 Addenda
N-508-5	Rotation of Snubbers and Pressure Retaining Items for the Purpose of Testing or Preventive Maintenance	1989 Edition	2021 Edition
N-509	Alternative Rules for the Selection and Examination of Classes 1, 2, and 3 Integrally Welded Attachments	1977 Edition with the Summer 1978 Addenda	1995 Edition
N-512	Assessment of Reactor Vessels with Low Upper Shelf Charpy Impact Energy Levels	1986 Edition with the 1987 Addenda	1992 Edition with the 1992 Addenda
N-512-1	Assessment of Reactor Vessels with Low Upper Shelf Charpy Impact Energy Levels	1986 Edition with the 1987 Addenda	1995 Edition
N-513	Evaluation Criteria for Temporary Acceptance of Flaws in Class 3 Piping	1977 Edition with the Summer 1978 Addenda	2001 Edition
N-513-1	Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping	1977 Edition with the Summer 1978 Addenda	2001 Edition
N-513-2	Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping	1977 Edition with the Summer 1978 Addenda	2001 Edition with the 2003 Addenda
N-513-3	Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping	1983 Edition with the Winter 1985 Addenda	2007 Edition with the 2008 Addenda
N-513-4	Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping	1995 Edition with the 1996 Addenda	2019 Edition
N-513-5	Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping and Gate Valves	1995 Edition with the 1996 Addenda	2021 Edition
N-513-6	Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping and Gate Valves	1995 Edition with the 1996 Addenda	2021 Edition
N-514	Low Temperature Overpressure Protection	1986 Edition with the 1987 Addenda	1992 Edition with the 1992 Addenda
N-515	Class 1 Mechanical Joint- Pressure Tests	1980 Edition with the Winter 1980 Addenda	1989 Edition with the 1990 Addenda
N-516	Underwater Welding	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1995 Addenda
N-516-1	Underwater Welding	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1995 Addenda
N-516-2	Underwater Welding	1974 Edition with the Summer 1978 Addenda	1995 Edition with the 1996 Addenda
N-516-3	Underwater Welding	1977 Edition with the Summer 1978 Addenda	2013 Edition
N-516-4	Underwater Welding	1995 Edition with the 1996 Addenda	2013 Edition
N-516-5	Underwater Welding	1995 Edition with the 1996 Addenda	2015 Edition
N-517	Quality Assurance Program Requirements for Owners	1977 Edition with the Summer 1978 Addenda	1995 Edition
N-517-1	Quality Assurance Program Requirements for Owners	1977 Edition with the Summer 1978 Addenda	2004 Edition with the 2006 Addenda
N-521	Alternative Rules for Deferral of Inspections of Nozzle-to-Vessel Welds, Inside Radius Sections and Nozzle-to-Safe End Welds of Pressurized Water Reactor (PWR) Vessel	1977 Edition	1995 Edition
N-522	Pressure Testing of Containment Penetration Piping	1974 Edition	1995 Edition with the 1996 Addenda
N-523	Mechanical Clamping Devices for Class 2 and 3 Piping	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1996 Addenda
N-523-1	Mechanical Clamping Devices for Class 2 and 3 Piping	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1996 Addenda
N-523-2	Mechanical Clamping Devices for Class 2 and 3 Piping	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1996 Addenda
N-524	Alternative Examination Requirements for Longitudinal Welds in Class 1 and 2 Piping	1974 Edition with the Summer 1975 Addenda	1995 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-526	Alternative Requirements for Successive Inspections of Class 1 and 2 Vessels	1974 Edition	2010 Edition with the 2011 Addenda
N-528-1	Purchase, Exchange, or Transfer of Material Between Nuclear Plant Sites	1977 Edition with the Summer 1978 Addenda	2004 Edition with the 2005 Addenda
N-532	Alternative Requirements to Repair and Replacement Documentation Requirements and Inservice Summary Report Preparation and Submission as Required by IWA-4000 and IWA-6000	1974 Edition with the Summer 1975 Addenda	1998 Edition with the 2000 Addenda
N-532-1	Alternative Requirements to Repair and Replacement Documentation Requirements and Inservice Summary Report Preparation and Submission	1981 Edition with the Winter 1983 Addenda	1998 Edition with the 2000 Addenda
N-532-2	Alternative Requirements to Repair/Replacement Activity Documentation Requirements and Inservice Summary Report Preparation and Submission	1981 Edition with the Winter 1983 Addenda	2001 Edition with the 2002 Addenda
N-532-3	Alternative Requirements to Repair/Replacement Activity Documentation Requirements and Inservice Summary Report Preparation and Submission	1981 Edition with the Winter 1983 Addenda	2001 Edition with the 2003 Addenda
N-532-4	Repair/Replacement Activity Documentation Requirements and Inservice Summary Report Preparation and Submission	1983 Edition with the Winter 1983 Addenda	2013 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (b)]
N-532-5	Repair/Replacement Activity Documentation Requirements and Inservice Inspection Summary Report Preparation and Submission	1995 Edition with the 1996 Addenda	2013 Edition
N-532-6	Repair/Replacement Activity Documentation Requirements and Inservice Inspection Summary Report Preparation and Submission	1995 Edition with the 1996 Addenda	2013 Edition
N-533	Alternative Requirements for VT-2 Visual Examination of Class 1 Insulated Pressure-Retaining Bolted Connections	1986 Edition	1998 Edition with the 2000 Addenda
N-533-1	Alternative Requirements for VT-2 Visual Examination of Class 1, 2, and 3 Insulated Pressure Retaining Bolted Connections	1989 Edition	1998 Edition with the 2000 Addenda
N-534	Alternative Requirements for Pneumatic Pressure Testing	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1997 Addenda
N-535	Alternative Requirements for Inservice Inspection Intervals	1977 Edition	1995 Edition with the 1995 Addenda
N-537	Location of Ultrasonic Depth-Sizing Flaws	1989 Edition with the 1989 Addenda	2001 Edition
N-538	Alternative Requirements for Length Sizing Performance Demonstrations in Accordance with Appendix VIII, Supplements 2, 3, 10, 11, and 12	1989 Edition with the 1989 Addenda	1995 Edition with the 1995 Addenda
N-541	Alternative Requirements for Performance Demonstration in Accordance with Appendix VIII, Supplements 4 and 6	1992 Edition with the 1993 Addenda	1995 Edition
N-542	Alternative Requirements for Nozzle Inside Radius Section Length Sizing Performance Demonstration	1989 Edition with the 1989 Addenda	1995 Edition
N-543	Alternative to Performing Periodic Calibration Checks	1977 Edition with the Summer 1978 Addenda	1989 Edition
N-544	Repair/Replacement of Small Items	1977 Edition with the Summer 1978 Addenda	1995 Edition
N-545	Alternative Requirements for Conduct of Performance Demonstration Detection Test of Reactor Vessel	1989 Edition	2004 Edition
N-546	Alternative Requirements for Qualification of VT-2 Examination Personnel	1977 Edition	1995 Edition with the 1997 Addenda
N-547	Alternative Examination Requirements for Pressure Retaining Bolting of Control Rod Drive (CRD) Housings	1980 Edition with the Winter 1980 Addenda	1995 Edition
N-552	Alternative Methods — Qualification for Nozzle Inside Radius Section from the Outside Surface	1989 Edition with the 1989 Addenda	2004 Edition
N-552-1	Alternative Methods — Qualification for Nozzle Inside Radius Section from the Outside Surface	2004 Edition	2010 Edition with the 2011 Addenda
N-553	Inservice Eddy Current Surface Examination of Pressure Retaining Pipe Welds and Nozzle-to-Safe End Welds	1977 Edition	1995 Edition with the 1996 Addenda
N-553-1	Eddy Current Surface Examination	1977 Edition	1995 Edition with the 1996 Addenda

Code Case No.		Title	Applicability	
			From	Up to and Including
N-554	Alternative Requirements for Reconciliation of Replacement Items	1977 Edition	1995 Edition with the 1995 Addenda	
N-554-1	Alternative Requirements for Reconciliation of Replacement Items	1977 Edition	1995 Edition with the 1996 Addenda	
N-554-2	Alternative Requirements for Reconciliation of Replacement Items and Addition of New Systems	1977 Edition	1998 Edition	
N-554-3	Alternative Requirements for Reconciliation of Replacement Items and Addition of New Systems	1977 Edition	2001 Edition with the 2002 Addenda	
N-555	Use of Section II, V, and IX Code Cases	1977 Edition with the Summer 1978 Addenda	2001 Edition	
N-556	Alternative Requirements for Verification of Acceptability of Replacements	1977 Edition	1992 Edition with the 1993 Addenda	
N-557	In-Place Dry Annealing of a PWR Nuclear Reactor Vessel	1974 Edition with the Summer 1975 Addenda	1995 Edition	
N-557-1	In-Place Dry Annealing of a PWR Nuclear Reactor Vessel	1974 Edition with the Summer 1975 Addenda	1995 Edition	
N-560	Alternative Examination Requirements for Class 1, Category B-J Piping Welds	1974 Edition	2004 Edition	
N-560-1	Alternative Examination Requirements for Class 1, Category B-J Piping Welds	1974 Edition	2004 Edition	
N-560-2	Alternative Examination Requirements for Class 1, Category B-J Piping Welds	1977 Edition	2004 Edition	
N-561	Alternative Requirements for Wall Thickness Restoration of Class 2 and High Energy Class 3 Carbon Steel Piping	1977 Edition	2004 Edition	
N-561-1	Alternative Requirements for Wall Thickness Restoration of Class 2 and High Energy Class 3 Carbon Steel Piping	1977 Edition	2004 Edition with the 2005 Addenda	
N-561-2	Alternative Requirements for Wall Thickness Restoration of Class 2 and High Energy Class 3 Carbon Steel Piping	1977 Edition	2015 Edition	
N-561-3	Alternative Requirements for Wall Thickness Restoration of Class 2 and High Energy Class 3 Carbon Steel Piping	1977 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]	
N-561-4	Alternative Requirements for Wall Thickness Restoration of Class 2 and High Energy Class 3 Carbon Steel Piping	1977 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]	
N-562	Alternative Requirements for Wall Thickness Restoration of Class 3 Moderate-Energy Carbon Steel Piping	1977 Edition	2004 Edition	
N-562-1	Alternative Requirements for Wall Thickness Restoration of Class 3 Moderate-Energy Carbon Steel Piping	1977 Edition	2004 Edition with the 2005 Addenda	
N-562-2	Alternative Requirements for Wall Thickness Restoration of Class 3 Moderate-Energy Carbon Steel Piping	1977 Edition	2015 Edition	
N-562-3	Alternative Requirements for Wall Thickness Restoration of Class 3 Moderate-Energy Carbon Steel Piping	2013 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]	
N-562-4	Alternative Requirements for Wall Thickness Restoration of Class 3 Moderate-Energy Carbon Steel Piping	2013 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]	
N-563	Grading of Examinations, IWA-2320	1986 Edition with the 1988 Addenda	1992 Edition	
N-566	Corrective Action for Leakage Identified at Bolted Connections	1983 Edition with the Winter 1984 Addenda	2004 Edition	
N-566-1	Corrective Action for Leakage Identified at Bolted Connections	1983 Edition with the Winter 1984 Addenda	2004 Edition	
N-566-2	Corrective Action for Leakage Identified at Bolted Connections	1983 Edition with the Winter 1984 Addenda	2004 Edition with the 2006 Addenda	
N-567	Alternative Requirements for Class 1, 2, and 3 Replacement Components	1977 Edition with the Summer 1978 Addenda	1998 Edition	
N-567-1	Reconciliation Requirements for Class 1, 2, and 3 Replacement Components	1977 Edition with the Summer 1978 Addenda	1998 Edition	
N-568	Alternative Examination Requirements for Welded Attachments	1974 Edition with the Summer 1975 Addenda	1989 Edition with the 1990 Addenda	
N-569	Alternative Rules for Repair by Electrochemical Deposition of Class 1 and 2 Steam Generator Tubing	1977 Edition with the Summer 1978 Addenda	2004 Edition	

Code Case No.		Title	Applicability	
			From	Up to and Including
N-569-1	Alternative Rules for Repair by Electrochemical Deposition of Class 1 and 2 Steam Generator Tubing	1977 Edition with the Summer 1978 Addenda	2019 Edition	
N-573	Transfer of Procedure Qualification Records Between Owners	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1996 Addenda	
N-574	NDE Personnel Recertification Frequency	1974 Edition with the Summer 1975 Addenda	1995 Edition with the 1996 Addenda	
N-575	Alternative Examination Requirements for Full Penetration Nozzle-to-Vessel Welds in Reactor Vessels with Set-On Type Nozzles	1989 Edition	2021 Edition	
N-576	Repair of Class 1 and 2 SB-163, UNS N06600 Steam Generator Tubing	1977 Edition with the Summer 1978 Addenda	1998 Edition with the 2000 Addenda	
N-576-1	Repair of Classes 1 and 2 SB-163, UNS N06600 Steam Generator Tubing	1977 Edition with the Summer 1978 Addenda	2015 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (d)]	
N-576-2	Repair of Classes 1 and 2 SB-163, UNS N06600 Steam Generator Tubing	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (d)]	
N-577	Risk-Informed Requirements for Class 1, 2, and 3 Piping, Method A	1977 Edition	2004 Edition	
N-577-1	Risk-Informed Requirements for Class 1, 2, or 3 Piping, Method A	1977 Edition	2004 Edition	
N-578	Risk-Informed Requirements for Class 1, 2, and 3 Piping, Method B	1977 Edition	2004 Edition	
N-578-1	Risk-Informed Requirements for Class 1, 2, or 3 Piping, Method B	1977 Edition	2004 Edition	
N-583	Annual Training Alternative	1986 Edition with the 1988 Addenda	1998 Edition	
N-586	Alternative Additional Examination Requirements for Class 1, 2, and 3 Piping, Components, and Supports	1977 Edition with the Summer 1978 Addenda	2004 Edition	
N-586-1	Alternative Additional Examination Requirements for Class 1, 2, and 3 Piping, Components, and Supports	1977 Edition with the Summer 1978 Addenda	2007 Edition with the 2008 Addenda	
N-587	Alternative NDE Requirements for Repair/Replacement Activities	1977 Edition with the Summer 1978 Addenda	1995 Edition with the 1997 Addenda	
N-588	Alternative to Reference Flaw Orientation of Appendix G for Circumferential Welds in Reactor Vessels	1986 Edition with the 1987 Addenda	1995 Edition with the 1997 Addenda	
N-589	Class 3 Nonmetallic Cured-In-Place Piping	1977 Edition with the Summer 1978 Addenda	2004 Edition	
N-589-1	Class 3 Nonmetallic Cured-In-Place Piping	1977 Edition with the Summer 1978 Addenda	2021 Edition	
N-590	Alternative to the Requirements of Subsection IWE, Requirements for Class MC and Metallic Liners of Class CC Components of Light-Water Cooled Plants	1992 Edition	1995 Edition with the 1997 Addenda	
N-591	Alternative to the Requirements of Subsection IWL, Requirements for Class CC Concrete Components of Light-Water Cooled Plants	1992 Edition	1995 Edition with the 1996 Addenda	
N-592	ASNT Central Certification Program	1974 Edition	1998 Edition	
N-593	Alternative Examination Requirements for Steam Generator Nozzle-to-Vessel Welds	1974 Edition	2004 Edition	
N-593-1	Examination Requirements for Steam Generator Nozzle-to-Vessel Welds	1974 Edition	2015 Edition	
N-593-2	Examination Requirements for Steam Generator Nozzle-to-Vessel Welds	1974 Edition	2021 Edition	
N-597	Requirements for Analytical Evaluation of Pipe Wall Thinning	1974 Edition	2004 Edition	
N-597-1	Requirements for Analytical Evaluation of Pipe Wall Thinning	1974 Edition	2004 Edition	
N-597-2	Requirements for Analytical Evaluation of Pipe Wall Thinning	1974 Edition	2017 Edition	
N-597-3	Evaluation of Pipe Wall Thinning	1974 Edition	2021 Edition	
N-597-4	Evaluation of Pipe Wall Thinning	1974 Edition	2021 Edition	
N-597-5	Evaluation of Pipe Wall Thinning	1974 Edition	2021 Edition	
N-598	Alternative Requirements to Required Percentages of Examinations	1977 Edition	1995 Edition with the 1997 Addenda	

Code Case No.	Title	Applicability	
		From	Up to and Including
N-599	Alternatives to Qualification of Nondestructive Examination Personnel for Inservice Inspection of Metal (Class MC) and Concrete (Class CC) Containments	1992 Edition with the 1992 Addenda	1995 Edition with the 1997 Addenda
N-600	Transfer of Welder, Welding Operator, Brazer, and Brazing Operator Qualifications Between Owners	1977 Edition with the Summer 1978 Addenda	2010 Edition with the 2011 Addenda
N-601	Extent and Frequency of VT-3 Visual Examination for Inservice Inspection of Metal Containments	1989 Edition	1995 Edition with the 1997 Addenda
N-603	Alternative to the Requirements of IWL-2421, Sites With Two Plants	1989 Edition with the 1991 Addenda	1995 Edition with the 1996 Addenda
N-604	Alternative to Bolt Torque or Tension Test Requirements of Table IWE-2500-1, Category E-G, Item E8.20	1989 Edition	1995 Edition with the 1997 Addenda
N-605	Alternative to the Requirements of IWE-2500(c) for Augmented Examination of Surface Areas	1989 Edition	1995 Edition with the 1997 Addenda
N-606	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1977 Edition with the Summer 1978 Addenda	2004 Edition
N-606-1	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique for BWR CRD Housing/Stub Tube Repairs	1977 Edition with the Summer 1978 Addenda	2017 Edition
N-606-2	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique for BWR CRD Housing/Stub Tube Repairs	1977 Edition with the Summer 1978 Addenda	2021 Edition
N-609	Alternative Requirements to Stress-Based Selection Criteria for Category B-J Welds	1977 Edition	2004 Edition with the 2005 Addenda
N-609-1	Alternative Requirements to Stress-Based Selection Criteria for Category B-J Welds	1977 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (h)]
N-613	Ultrasonic Examination of Full Penetration Nozzles in Vessels, Examination Category B-D, Item No's. B3.10 and B3.90, Reactor Vessel-to-Nozzle Welds, Figures IWB-2500-7(a), (b), and (c)	1989 Edition with the 1989 Addenda	2007 Edition with the 2008 Addenda
N-613-1	Ultrasonic Examination of Full Penetration Nozzles in Vessels, Examination Category B-D, Item No's. B3.10 and B3.90, Reactor Nozzle-to-Vessel Welds, Figures IWB-2500-7(a), (b), and (c)	1989 Edition with the 1989 Addenda	2007 Edition with the 2008 Addenda
N-613-2	Ultrasonic Examination of Full Penetration Nozzles in Vessels, Examination Category B-D, Reactor Nozzle- to-Vessel Welds and Nozzle Inside Radius Section, Figures IWB-2500-7(a), (b), (c), and (d)	1989 Edition	2021 Edition
N-615	Ultrasonic Examination as a Surface Examination Method for Category B-F and B-J Piping Welds	1977 Edition with the Summer 1978 Addenda	1998 Edition with the 2000 Addenda
N-617	Alternative Examination Distribution Requirements for Table IWC-2500-1 Examination Category C-G, Pressure Retaining Welds in Pumps and Valves	1977 Edition with the Summer 1978 Addenda	1998 Edition with the 1999 Addenda
N-618	Use of a Reactor Pressure Vessel as a Transportation Containment System	1983 Edition	2019 Edition
N-619	Alternative Requirements for Nozzle Inner Radius Inspections for Class 1 Pressurizer and Steam Generator Nozzles	1977 Edition with the Summer 1978 Addenda	1998 Edition
N-622	Ultrasonic Examination of RPV and Piping, Bolts, and Studs	1989 Edition with the 1989 Addenda	2001 Edition
N-623	Deferral of Inspections of Shell-to-Flange and Head-to- Flange Welds of a Reactor Vessel	1977 Edition with the Summer 1978 Addenda	1998 Edition
N-624	Successive Inspections	1977 Edition with the Summer 1978 Addenda	2007 Edition
N-627	VT-1 Visual Examination in Lieu of Surface Examination for RPV Closure Nuts	1977 Edition with the 1978 Addenda	1989 Edition
N-630	Alternatives to VT-1C and VT-3C Visual Examination for Inservice Inspection of Concrete and VT-1 Visual Examination for Inservice Inspection of Anchorage Hardware and Surrounding Concrete for Concrete Containments	1992 Edition with the 1992 Addenda	1995 Edition with the 1996 Addenda
N-638	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1977 Edition with the Summer 1978 Addenda	2004 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-638-1	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1977 Edition with the Summer 1978 Addenda	2007 Edition with the 2008 Addenda
N-638-2	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981 Addenda	2004 Edition
N-638-3	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981 Addenda	2004 Edition
N-638-4	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981 Addenda	2010 Edition with the 2011 Addenda [see Guideline for Cross-Referencing Section XI, Table 1, General Note (c)]
N-638-5	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981 Addenda	2010 Edition with the 2011 Addenda [see Guideline for Cross-Referencing Section XI, Table 1, General Note (c)]
N-638-6	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981 Addenda	2010 Edition with the 2011 Addenda [see Guideline for Cross-Referencing Section XI, Table 1, General Note (c)]
N-638-7	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-638-8	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-638-9	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-638-10	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-638-11	Similar and Dissimilar Metal Welding Using Ambient Temperature Machine GTAW Temper Bead Technique	1980 Edition with the Winter 1981	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-639	Alternative Calibration Block Material	1986 Edition with the 1987 Addenda	2021 Edition
N-639-1	Alternative Calibration Block Material	1986 Edition with the 1987 Addenda	2021 Edition
N-640	Alternative Reference Fracture Toughness for Development of P-T Limit Curves	1986 Edition with the 1987 Addenda	1998 Edition
N-641	Alternative Pressure-Temperature Relationship and Low Temperature Overpressure Protection System Requirements	1977 Edition with the Summer 1978 Addenda	2021 Edition
N-643	Fatigue Crack Growth Rate Curves for Ferritic Steels in PWR Water Environment	1977 Edition with the Summer 1978 Addenda	2004 Edition
N-643-1	Fatigue Crack Growth Rate Curves for Ferritic Steels in PWR Water Environment	1977 Edition with the Summer 1978 Addenda	2004 Edition
N-643-2	Fatigue Crack Growth Rate Curves for Ferritic Steels in PWR Water Environment	1977 Edition with the Summer 1978 Addenda	2021 Edition
N-647	Alternative to Augmented Examination Requirements of IWE-2500	1977 Edition with the Summer 1978 Addenda	1998 Edition with the 2000 Addenda
N-648	Alternative Requirements for Inner Radius Examinations of Class 1 Reactor Vessel Nozzles	1977 Edition with the Summer 1978 Addenda	2004 Edition
N-648-1	Alternative Requirements for Inner Radius Examinations of Class 1 Reactor Vessel Nozzles	1977 Edition with the Summer 1978 Addenda	2017 Edition
N-648-2	Alternative Requirements for Inner Radius Examinations of Class 1 Reactor Vessel Nozzles	1983 Edition with the Winter 1983 Addenda	2021 Edition
N-649	Alternative Requirements for IWE-5240 Visual Examination	1989 Edition	1998 Edition with the 2000 Addenda
N-651	Ferritic and Dissimilar Metal Welding Using SMAW Temper Bead Technique Without Removing the Weld Bead Crown of the First Layer	1977 Edition with the Summer 1978 Addenda	2021 Edition
N-652	Alternative Requirements to Categories B-G-1, B-G-2, and C-D Bolting Examination Methods and Selection Criteria	1977 Edition	2001 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-652-1	Alternative Requirements to Categories B-G-1, B-G-2, and C-D Bolting Examination Methods and Selection Criteria	1977 Edition	2001 Edition with the 2003 Addenda
N-652-2	Alternative Requirements to Categories B-G-1, B-G-2, and C-D Bolting Examination Methods and Selection Criteria	1977 Edition	2010 Edition
N-653	Qualification Requirements for Full Structural Overlaid Wrought Austenitic Piping Welds	1989 Edition with the 1989 Addenda	2004 Edition
N-653-1	Qualification Requirements for Full Structural Overlaid Wrought Austenitic Piping Welds	1989 Edition with the 1989 Addenda	2019 Edition
N-653-2	Qualification Requirements for Full Structural Overlaid Wrought Austenitic Piping Welds	1989 Edition with the 1989 Addenda	2021 Edition
N-654	Acceptance Criteria for Flaws in Ferritic Steel Components 4 in. and Greater in Thickness	1974 Edition	2021 Edition
N-658	Qualification Requirements for Ultrasonic Examination of Wrought Austenitic Piping Welds	1989 Edition with the 1989 Addenda	2001 Edition
N-660	Risk-Informed Safety Classification for Use in Risk-Informed Repair/Replacement Activities	1980 Edition with the Winter 1981 Addenda	2021 Edition
N-661	Alternative Requirements for Wall Thickness Restoration of Classes 2 and 3 Carbon Steel Piping for Raw Water Service	1977 Edition	2004 Edition with the 2005 Addenda
N-661-1	Alternative Requirements for Wall Thickness Restoration of Classes 2 and 3 Carbon Steel Piping for Raw Water Service	1977 Edition	2004 Edition with the 2005 Addenda
N-661-2	Alternative Requirements for Wall Thickness Restoration of Classes 2 and 3 Carbon Steel Piping for Raw Water Service	1977 Edition	2015 Edition
N-661-3	Alternative Requirements for Wall Thickness Restoration of Classes 2 and 3 Carbon Steel Piping for Raw Water Service	1977 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-661-4	Alternative Requirements for Wall Thickness Restoration of Classes 2 and 3 Carbon Steel Piping for Raw Water Service	2013 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-661-5	Alternative Requirements for Wall Thickness Restoration of Classes 2 and 3 Carbon Steel Piping for Raw Water Service	2013 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-662	Alternative Repair/Replacement Requirements for Items Classified in Accordance With Risk-Informed Processes	1980 Edition with the Winter 1981 Addenda	2001 Edition with the 2002 Addenda
N-662-1	Alternative Repair/Replacement Requirements for Items Classified in Accordance With Risk-Informed Processes	1995 Edition with the 1996 Addenda	2007 Edition with the 2009 Addenda
N-663	Alternative Requirements for Classes 1 and 2 Surface Examinations	1986 Edition	2010 Edition with the 2011 Addenda
N-663-1	Alternative Requirements for Classes 1 and 2 Surface Examinations	1986 Edition	2010 Edition with the 2011 Addenda
N-664	Performance Demonstration Requirements for Examination of Unclad Reactor Pressure Vessel Welds, Excluding Flange Welds	1989 Edition with the 1989 Addenda	2001 Edition with the 2002 Addenda
N-665	Alternative Requirements for Angle Beam Measurements Using Refracted Longitudinal Wave Search Units	1983 Edition with the Winter 1985 Addenda	2001 Edition with the 2002 Addenda
N-666	Weld Overlay of Class 1, 2, and 3 Socket Welded Connections	1980 Edition with the Winter 1981 Addenda	2015 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (c)]
N-666-1	Weld Overlay of Class 1, 2, and 3 Socket Welded Connections	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (c)]
N-666-2	Weld Overlay of Class 1, 2, and 3 Socket Welded Connections	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (c)]
N-683	Method for Determining Maximum Allowable False Calls When Performing Single-Sided Access Performance Demonstration in Accordance With, Appendix VIII, Supplements 4 and 6	1989 Edition with the 1989 Addenda	2001 Edition with the 2002 Addenda
N-685	Lighting Requirements for Surface Examination	1998 Edition	2001 Edition with the 2003 Addenda
N-686	Alternative Requirements for Visual Examinations, VT-1, VT-2, and VT-3	1989 Edition with the 1990 Addenda	1998 Edition with the 2000 Addenda
N-686-1	Alternative Requirements for Visual Examinations, VT-1, VT-2, and VT-3	1989 Edition with the 1990 Addenda	2004 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-691	Application of Risk-Informed Insights to Increase the Inspection Interval for Pressurized Water Reactor Vessels	1986 Edition	2004 Edition with the 2006 Addenda
N-691-1	Application of Risk-Informed Insights to Increase the Inspection Interval for Pressurized Water Reactor Vessels	1989 Edition	2021 Edition
N-694	Evaluation Procedure and Acceptance Criteria for PWR Reactor Vessel Upper Head Penetration Nozzles	1983 Edition	2001 Edition with the 2003 Addenda
N-694-1	Evaluation Procedure and Acceptance Criteria for PWR Reactor Vessel Head Penetration Nozzles	1983 Edition	2001 Edition with the 2003 Addenda
N-694-2	Evaluation Procedure and Acceptance Criteria for PWR Reactor Vessel Head Penetration Nozzles	1983 Edition	2001 Edition with the 2003 Addenda
N-695	Qualification Requirements for Dissimilar Metal Piping Welds	1989 Edition with the 1989 Addenda	2001 Edition with the 2003 Addenda
N-695-1	Qualification Requirements for Dissimilar Metal Piping Welds	2001 Edition	2013 Edition
N-696	Qualification Requirements for Appendix VIII Piping Examinations Conducted From the Inside Surface	1989 Edition with the 1989 Addenda	2001 Edition with the 2003 Addenda
N-696-1	Qualification Requirements for Mandatory Appendix VIII Piping Examinations Conducted From the Inside Surface	2001 Edition	2021 Edition
N-697	Pressurized Water Reactor (PWR) Examination and Alternative Examination Requirements for Pressure Retaining Welds in Control Rod Drive and Instrument Nozzle Housings	1977 Edition	2001 Edition with the 2003 Addenda
N-700	Alternative Rules for Selection of Classes 1, 2, and 3 Vessel Welded Attachments for Examination	1995 Edition with the 1996 Addenda	2001 Edition with the 2003 Addenda
N-702	Alternative Requirements for Boiling Water Reactor (BWR) Nozzle Inner Radius and Nozzle-to-Shell Welds	1986 Edition	2015 Edition
N-702-1	Alternative Requirements for Boiling Water Reactor (BWR) Nozzle Inner Radius and Nozzle-to-Shell Welds	1986 Edition	2017 Edition
N-705	Evaluation Criteria for Temporary Acceptance of Degradation in Moderate Energy Class 2 or 3 Vessels and Tanks	1983 Edition with the 1985 Addenda	2010 Edition with the 2011 Addenda
N-705-1	Evaluation Criteria for Temporary Acceptance of Degradation in Moderate Energy Class 2 or 3 Vessels and Tanks	1983 Edition with the 1985 Addenda	2021 Edition
N-706	Alternative Examination Requirements to Table IWB-2500-1 and Table IWC-2500-1 for PWR Stainless Steel Residual and Regenerative Heat Exchangers	1977 Edition	2004 Edition with the 2005 Addenda
N-706-1	Alternative Examination Requirements to Table IWB-2500-1 and Table IWC-2500-1 for PWR Stainless Steel Residual and Regenerative Heat Exchangers	1977 Edition	2010 Edition with the 2011 Addenda
N-711	Alternative Examination Coverage Requirements for Examination Category B-F, B-J, C-F-1, C-F-2, and R-A Piping Welds	1989 Edition	2017 Edition
N-711-1	Alternative Examination Coverage Requirements for Examination Category B-F, B-J, C-F-1, C-F-2, and R-A Piping Welds	1989 Edition	2021 Edition
N-711-2	Alternative Examination Coverage Requirements for Examination Category B-F, B-J, C-F-1, C-F-2, and R-A Piping Welds	1989 Edition	2021 Edition
N-712	Class 1 Socket Weld Examinations	1986 Edition	2010 Edition with the 2011 Addenda
N-713	Ultrasonic Examination in Lieu of Radiography	1986 Edition	2019 Edition
N-716	Alternative Piping Classification and Examination Requirements	1989 Edition	2004 Edition with the 2006 Addenda
N-716-1	Alternative Piping Classification and Examination Requirements	1995 Edition	2017 Edition
N-716-2	Alternative Classification and Examination Requirements	1995 Edition	2021 Edition
N-716-3	Alternative Classification and Examination Requirements	1995 Edition	2021 Edition
N-722	Additional Examinations for PWR Pressure Retaining Welds in Class 1 Components Fabricated With Alloy 600/82/182 Materials	1980 Edition	2013 Edition
N-722-1	Additional Examinations for PWR Pressure Retaining Welds in Class 1 Components Fabricated With Alloy 600/82/182 Materials	1980 Edition	2021 Edition
N-722-2	Visual Examinations for PWR Pressure Retaining Welds in Class 1 Components Fabricated With Alloy 600/82/182 Materials	1980 Edition	2021 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-729	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	1980 Edition	2004 Edition
N-729-1	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	1980 Edition	2004 Edition
N-729-2	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	1980 Edition	2004 Edition
N-729-3	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	2004 Edition	2015 Edition
N-729-4	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	2004 Edition	2019 Edition
N-729-5	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	2004 Edition	2019 Edition
N-729-6	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	2004 Edition	2021 Edition
N-729-7	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	2004 Edition	2021 Edition
N-729-8	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	2004 Edition	2021 Edition
N-729-9	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	2004 Edition	2021 Edition
N-729-10	Alternative Examination Requirements for PWR Reactor Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds	2007 Edition	2021 Edition
N-730	Roll Expansion of Class 1 Control Rod Drive Bottom Head Penetrations in BWRs	1989 Edition	2015 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (e)]
N-730-1	Roll Expansion of Class 1 Control Rod Drive Bottom Head Penetrations in BWRs	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (e)]
N-731	Alternative Class 1 System Leakage Test Pressure Requirements	1989 Edition	2015 Edition
N-733	Mitigation of Flaws in NPS 2 (DN 50) and Smaller Nozzles and Nozzle Partial Penetration Welds in Vessels and Piping by Use of a Mechanical Connection Modification	1983 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (f)]
N-733-1	Mitigation of Flaws in NPS 3 (DN 80) and Smaller Nozzles and Nozzle Partial Penetration Welds in Vessels and Piping by Use of a Mechanical Connection Modification	2001 Edition with the 2003 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (f)]
N-735	Successive Inspections of Class 1 and 2 Piping Welds	1995 Edition with the 1996 Addenda	2021 Edition
N-739	Alternative Qualification Requirements for Personnel Performing Class CC Concrete and Post-tensioning System Visual Examinations	1992 Edition with the 1992 Addenda	2004 Edition with the 2006 Addenda
N-739-1	Alternative Qualification Requirements for Personnel Performing Class CC Concrete and Post-tensioning System Visual Examinations	1992 Edition with the 1992 Addenda	2004 Edition with the 2006 Addenda
N-740	Dissimilar Metal Weld Overlay for Repair of Class 1, 2, and 3 Items	1980 Edition with Winter 1981 Addenda	2021 Edition
N-740-1	Dissimilar Metal Weld Overlay for Repair or Mitigation of Class 1, 2, and 3 Items	1980 Edition with Winter 1981 Addenda	2021 Edition
N-740-2	Full Structural Dissimilar Metal Weld Overlay for Repair or Mitigation of Class 1, 2, and 3 Items	1986 Edition with the 1988 Addenda	2021 Edition
N-747	Reactor Vessel Head-to-Flange Weld Examination	1989 Edition	2015 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-749	Alternative Acceptance Criteria for Flaws in Ferritic Steel Components Operating in the Upper Shelf Temperature Range	1998 Edition with the 2000 Addenda	2021 Edition
N-751	Pressure Testing of Containment Penetration Piping	1989 Edition	2019 Edition
N-752	Risk-Informed Categorization and Treatment for Repair/ Replacement Activities in Class 2 and 3 Systems	1995 Edition with the 1996 Addenda	2017 Edition
N-752-1	Risk-Informed Categorization and Treatment for Repair/ Replacement Activities in Class 2 and 3 Systems	1995 Edition with the 1996 Addenda	2021 Edition
N-753	Vision Tests	1986 Edition with the 1988 Addenda	2004 Edition with the 2006 Addenda
N-754	Optimized Structural Dissimilar Metal Weld Overlay for Mitigation of PWR Class 1 Items	1986 Edition with the 1988 Addenda	2010 Edition
N-754-1	Optimized Structural Dissimilar Metal Weld Overlay for Mitigation of PWR Class 1 Items	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-754-2	Optimized Structural Dissimilar Metal Weld Overlay for Mitigation of PWR Class 1 Items	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-755	Use of Polyethylene (PE) Plastic Pipe	1995 Edition with the 1995 Addenda	2015 Edition
N-755-1	Use of Polyethylene (PE) Plastic Pipe	1995 Edition with the 1995 Addenda	2015 Edition
N-762	Temper Bead Procedure Qualification Requirements for Repair/Replacement Activities Without Postweld Heat Treatment	1995 Edition with the 1995 Addenda	2010 Edition
N-762-1	Temper Bead Procedure Qualification Requirements for Repair/ Replacement Activities Without Postweld Heat Treatment	1995 Edition with the 1995 Addenda	2010 Edition
N-765	Alternative to Inspection Interval Scheduling Requirements of IWA-2430	1989 Edition	2007 Edition with the 2008 Addenda
N-766	Nickel Alloy Reactor Coolant Inlay and Onlay for Mitigation of PWR Full Penetration Circumferential Nickel Alloy Dissimilar Metal Welds in Class 1 Items	1986 Edition with the 1988 Addenda	2017 Edition
N-766-1	Nickel Alloy Reactor Coolant Inlay and Onlay for Mitigation of PWR Full Penetration Circumferential Nickel Alloy Dissimilar Metal Welds in Class 1 Items	1995 Edition with the 1996 Addenda	2019 Edition
N-766-2	Nickel Alloy Reactor Coolant Inlay and Onlay for Mitigation of PWR Full Penetration Circumferential Nickel Alloy Dissimilar Metal Welds in Class 1 Items	1995 Edition with the 1996 Addenda	2019 Edition
N-766-3	Nickel Alloy Reactor Coolant Inlay and Onlay for Mitigation of PWR Full Penetration Circumferential Nickel Alloy Dissimilar Metal Welds in Class 1 Items	1995 Edition with the 1996 Addenda	2021 Edition
N-766-4	Nickel Alloy Reactor Coolant Inlay and Onlay for Mitigation of PWR Full Penetration Circumferential Nickel Alloy Dissimilar Metal Welds in Class 1 Items	1995 Edition with the 1996 Addenda	2021 Edition
N-768	Alternative Volumetric Coverage Requirements for Ultrasonic Examination of Class 1 and 2 Pressure Vessel Weld Joints Greater Than 2 in. (50 mm) in Thickness	2001 Edition with the 2003 Addenda	2021 Edition
N-769	Roll Expansion of Class 1 In-Core Housing Bottom Head Penetrations in BWRs	1989 Edition	2015 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (e)]
N-769-1	Roll Expansion of Class 1 In-Core Housing Bottom Head Penetrations in BWRs	1989 Edition	2015 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (e)]
N-769-2	Roll Expansion of Class 1 In-Core Housing Bottom Head Penetrations in BWRs	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (e)]
N-770	Alternative Examination Requirements and Acceptance Standards for Class 1 PWR Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082 or UNS W86182 Weld Filler Material With or Without Application of Listed Mitigation Activities	1989 Edition	2015 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-770-1	Alternative Examination Requirements and Acceptance Standards for Class 1 PWR Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082 or UNS W86182 Weld Filler Material With or Without Application of Listed Mitigation Activities	1989 Edition	2015 Edition
N-770-2	Alternative Examination Requirements and Acceptance Standards for Class 1 PWR Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082 or UNS W86182 Weld Filler Material With or Without Application of Listed Mitigation Activities	1989 Edition	2019 Edition
N-770-3	Alternative Examination Requirements and Acceptance Standards for Class 1 PWR Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082 or UNS W86182 Weld Filler Material With or Without Application of Listed Mitigation Activities	1989 Edition	2019 Edition
N-770-4	Alternative Examination Requirements and Acceptance Standards for Class 1 PWR Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082 or UNS W86182 Weld Filler Material With or Without Application of Listed Mitigation Activities	1989 Edition	2019 Edition
N-770-5	Alternative Examination Requirements and Acceptance Standards for Class 1 PWR Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082 or UNS W86182 Weld Filler Material With or Without Application of Listed Mitigation Activities	1989 Edition	2021 Edition
N-770-6	Alternative Examination Requirements and Acceptance Standards for Class 1 PWR Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082 or UNS W86182 Weld Filler Material With or Without Application of Listed Mitigation Activities	1989 Edition	2021 Edition
N-770-7	Alternative Examination Requirements and Acceptance Standards for Class 1 PWR Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082 or UNS W86182 Weld Filler Material With or Without Application of Listed Mitigation Activities	1989 Edition	2021 Edition
N-771	Alternative Requirements for Additional Examinations of Class 2 or 3 Items	1992 Edition	2021 Edition
N-773	Alternative Qualification Criteria for Eddy Current Examinations of Piping Inside Surfaces	1995 Edition with the 1996 Addenda	2015 Edition
N-775	Alternative Requirements for Bolting Affected by Borated Water Leakage	1989 Edition	2010 Edition with the 2011 Addenda
N-776	Alternative to IWA-5244 Requirements for Buried Piping	1989 Edition	2010 Edition
N-778	Alternative Requirements for Preparation and Submittal of Plans, Schedules, and Preservice and Inservice Inspection Summary Reports	1989 Edition	2007 Edition with the 2009 Addenda
N-778-1	Alternative Requirements for Preparation and Submittal of Plans, Schedules, and Preservice and Inservice Inspection Summary Reports	1989 Edition	2007 Edition with the 2009 Addenda
N-780	Alternative Requirements for Upgrade, Substitution, or Reconfiguration of Examination Equipment When Using Appendix VIII Qualified Ultrasonic Examination Systems	1989 Edition with the 1989 Addenda	2021 Edition
N-780-1	Alternative Requirements for Upgrade, Substitution, or Reconfiguration of Examination Equipment When Using Appendix VIII Qualified Ultrasonic Examination Systems	1989 Edition with the 1989 Addenda	2021 Edition
N-784	Experience Credit for Ultrasonic Examiner Certification	1995 Edition	2010 Edition
N-786	Alternative Requirements for Sleeve Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping	1995 Edition with the 1996 Addenda	2017 Edition
N-786-1	Alternative Requirements for Sleeve Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]

Code Case No.	Title	Applicability	
		From	Up to and Including
N-786-2	Alternative Requirements for Sleeve Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-786-3	Alternative Requirements for Sleeve Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-786-4	Alternative Requirements for Sleeve Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-788	Third Party NDE Certification Organizations	1995 Edition	2021 Edition
N-788-1	Third Party NDE Certificate Organization	1995 Edition	2021 Edition
N-789	Alternative Requirements for Pad Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping for Raw Water Service	1995 Edition with the 1996 Addenda	2017 Edition
N-789-1	Alternative Requirements for Pad Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping for Raw Water Service	1995 Edition with the 1996 Addenda	2017 Edition
N-789-2	Alternative Requirements for Pad Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping for Raw Water Service	1998 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-789-3	Alternative Requirements for Pad Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping for Raw Water Service	1998 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-789-4	Alternative Requirements for Pad Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping for Raw Water Service	1998 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-789-5	Alternative Requirements for Pad Reinforcement of Class 2 and 3 Moderate-Energy Carbon Steel Piping for Raw Water Service	1998 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-795	Alternative Requirements for BWR Class 1 System Leakage Test Pressure Following Repair/Replacement Activities	1998 Edition with the 1999 Addenda	2015 Edition
N-798	Alternative Pressure Testing Requirements for Class 1 Piping Between the First and Second Vent, Drain, and Test Isolation Devices	1992 Edition with the 1993 Addenda	2015 Edition
N-799	Dissimilar Metal Welds Joining Vessel Nozzles to Components	1995 Edition	2010 Edition
N-800	Alternative Pressure Testing Requirements for Class 1 Piping Between the First and Second Injection Valves	1992 Edition with the 1993 Addenda	2015 Edition
N-803	Similar and Dissimilar Metal Welding Using Ambient Temperature Automatic or Machine Dry Underwater Laser Beam Welding (ULBW) Temper Bead Technique	1980 Edition	2010 Edition
N-805	Alternative to Class 1 Extended Boundary End of Interval or Class 2 System Leakage Testing of the Reactor Vessel Head Flange O-Ring Leak-Detection System	1992 Edition	2013 Edition
N-806	Evaluation of Metal Loss in Class 2 and 3 Metallic Piping Buried in a Back-Filled Trench	1995 Edition	2021 Edition
N-806-1	Analytical Evaluation of Metal Loss in Class 2 and 3 Metallic Piping Buried in a Back-Filled Trench	1995 Edition	2021 Edition
N-809	Reference Fatigue Crack Growth Rate Curves for Austenitic Stainless Steels in Pressurized Water Reactor Environments	1989 Edition with the 1989 Addenda	2019 Edition
N-809-1	Reference Fatigue Crack Growth Rate Curves for Austenitic Stainless Steels in Pressurized Water Reactor Environments	1989 Edition with the 1989 Addenda	2021 Edition
N-813	Alternative Requirements for Preservice Volumetric and Surface Examination	1989 Edition	2013 Edition
N-813-1	Alternative Requirements for Preservice Volumetric and Surface Examination	1989 Edition	2013 Edition
N-823	Visual Examination	2001 Edition with the 2003 Addenda	2010 Edition with the 2011 Addenda
N-823-1	Visual Examination	2001 Edition with the 2003 Addenda	2013 Edition
N-824	Ultrasonic Examination of Cast Austenitic Piping Welds From the Outside Surface	2001 Edition	2013 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-825	Alternative Requirements for Examination of Control Rod Drive Housing Welds	1995 Edition with the 1996 Addenda	2013 Edition
N-826	Ultrasonic Examination of Full Penetration Vessel Weld Joints in Figures IWB-2500-1 Through IWB-2500-6	1995 Edition with the 1996 Addenda	2021 Edition
N-829	Austenitic Stainless Steel Cladding and Nickel Base Cladding Using Ambient Temperature Machine GTAW Temper Bead Technique	1995 Edition with the 1996 Addenda	2021 Edition
N-830	Direct Use of Master Fracture Toughness Curve for Pressure-Retaining Materials of Class 1 Vessels	1992 Edition	2021 Edition
N-830-1	Direct Use of Fracture Toughness for Flaw Evaluations of Pressure Boundary Materials in Class 1 Ferritic Steel Components	1992 Edition	2021 Edition
N-831	Ultrasonic Examination in Lieu of Radiography for Welds in Ferritic Pipe	1995 Edition with the 1996 Addenda	2019 Edition
N-831-1	Ultrasonic Examination in Lieu of Radiography for Welds in Ferritic or Austenitic Pipe	1995 Edition with the 1996 Addenda	2021 Edition
N-838	Flaw Tolerance Evaluation of Cast Austenitic Stainless Steel Piping	1989 Edition with the 1989 Addenda	2021 Edition
N-839	Similar and Dissimilar Metal Welding Using Ambient Temperature SMAW Temper Bead Technique	1995 Edition with the 1996 Addenda	2021 Edition
N-840	Cladding Repair by Underwater Electrochemical Deposition in Class 1 and 2 Applications	1995 Edition with the 1996 Addenda	2021 Edition
N-842	Alternative Inspection Program for Longer Fuel Cycles	2007 Edition with the 2008 Addenda	2021 Edition
N-843	Alternative Pressure Testing Requirements Following Repair/Replacement Activities for Class 1 Piping Between the First and Second Injection Isolation Valves	1980 Edition	2021 Edition
N-845	Qualification Requirements for Bolts and Studs	1995 Edition with the 1996 Addenda	2015 Edition
N-845-1	Qualification Requirements for Bolts and Studs	1995 Edition with the 1996 Addenda	2015 Edition
N-847	Partial Excavation and Deposition of Weld Metal for Mitigation of Class 1 Items	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-847-1	Partial Excavation and Deposition of Weld Metal for Mitigation of Class 1 Items	1995 Edition with the 1996 Addenda	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-848	Alternative Characterization Rules for Quasi-Laminar Flaws	1989 Edition with the 1989 Addenda	2021 Edition
N-848-1	Alternative Characterization Rules for Quasi-Laminar Flaws	1989 Edition with the 1989 Addenda	2021 Edition
N-849	In Situ VT-3 Examination of Removable Core Support Structures Without Removal	2007 Edition with the 2008 Addenda	2021 Edition
N-851	Use of Fracture Toughness Test Data to Establish Reference Temperature for Pressure Retaining Materials	1977 Edition with the Summer 1978 Addenda	2015 Edition
N-853	PWR Class 1 Primary Piping Alloy 600 Full Penetration Branch Connection Weld Metal Buildup for Material Susceptible to Primary Water Stress Corrosion Cracking	1995 Edition with the 1996 Addenda	2021 Edition
N-853-1	PWR Class 1 Primary Piping Alloy 600 Full Penetration Branch Connection Weld Metal Buildup for Material Susceptible to Primary Water Stress Corrosion Cracking	1995 Edition with the 1996 Addenda	2021 Edition
N-854	Alternative Pressure Testing Requirements for Class 2 and 3 Components Connected to the Class 1 Boundary	2001 Edition with the 2003 Addenda	2013 Edition
N-858	Alternative Volumetric Coverage Requirements for Ultrasonic Examination of Class 1 Nozzle-to-Vessel Welds	1998 Edition with the 2000 Edition	2021 Edition
N-860	Inspection Requirements and Evaluation Standards for Spent Nuclear Fuel Storage and Transportation Containment Systems	2010 Edition with the 2011 Addenda	2021 Edition
N-864	Reactor Vessel Threads in Flange Examinations	1998 Edition	2021 Edition
N-865	Alternative Requirements for Pad Reinforcement of Class 2 and 3 Atmospheric Storage Tanks	1998 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]

Code Case No.	Title	Applicability	
		From	Up to and Including
N-865-1	Alternative Requirements for Pad Reinforcement of Class 2 and 3 Atmospheric, and 0 psi to 15 psi (0 kPa to 100 kPa), Storage Tanks	1998 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]
N-865-2	Alternative Requirements for Pad Reinforcement of Class 2 and 3 Atmospheric, and 0 psi to 15 psi (0 kPa to 100 kPa), Storage Tanks	1998 Edition	2021 Edition [see Guideline for Cross-Referencing Section XI, Table 1, General Note (a)]"
N-867	Clarification of NDE Practical Examination Requirements	1995 Edition	2015 Edition
N-868	Third-Party NDE Certification for Non-U.S. Plant Sites	1995 Edition	2021 Edition
N-869	Evaluation Criteria for Temporary Acceptance of Flaws in Class 2 or 3 Piping	1995 Edition with the 1996 Addenda	2021 Edition
N-871	Repair of Buried Class 2 and 3 Piping Using Carbon Fiber-Reinforced Polymer Composite	1998 Edition	2021 Edition
N-871-1	Repair of Buried Class 2 and 3 Piping Using Carbon Fiber-Reinforced Polymer Composite	1998 Edition	2021 Edition
N-873	Examination Requirements for the Core Makeup Tanks	1998 Edition	2017 Edition
N-874	Temporary Acceptance of Leakage Through Brazed Joints of Class 3 Copper, Copper-Nickel, and Nickel-Copper Moderate Energy Piping	1995 Edition with the 1996 Addenda	2021 Edition
N-875	Alternative Inservice Inspection Requirements for Liquid-Metal Reactor Passive Components	1995 Edition	2021 Edition
N-876	Austenitic Stainless Steel Cladding and Nickel Base Cladding Using Ambient Temperature Automatic or Machine Dry Underwater Laser Beam Welding (ULBW) Temper Bead Technique	1995 Edition with the 1996 Addenda	2021 Edition
N-877	Alternative Characterization Rules for Multiple Subsurface Radially Oriented Planar Flaws	1998 Edition	2021 Edition
N-877-1	Alternative Characterization Rules for Multiple Radially Oriented Planar Flaws	1998 Edition	2021 Edition
N-878	Alternative to QA Program Requirements of IWA-4142	1998 Edition with the 2000 Addenda	2019 Edition
N-880	Alternative to Procurement Requirements of IWA-4143 for Small Nonstandard Welded Fittings	1998 Edition with the 2000 Addenda	2021 Edition
N-880-1	Alternative to Procurement Requirements of IWA-4143 for Small Nonstandard Welded Fittings	1998 Edition with the 2000 Addenda	2021 Edition
N-882	Alternative Requirements for Attaching Nonstructural Electrical Connections to Class 2 and 3 Components	1995 Edition with the 1996 Addenda	2021 Edition
N-882-1	Alternative Requirements for Attaching Nonstructural Electrical Connections to Class 2 and 3 Components	1995 Edition with the 1996 Addenda	2021 Edition
N-885	Alternative Requirements for Table IWB-2500-1, Examination Category B-N-1, Interior of Reactor Vessel, Category B-N-2, Welded Core Support Structures and Interior Attachments to Reactor Vessels, Category B-N-3, Removable Core Support Structures	1982 Edition	2021 Edition
N-885-1	Alternative Requirements for Table IWB-2500-1, Examination Category B-N-1, Interior of Reactor Vessel, Category B-N-2, Welded Core Support Structures and Interior Attachments to Reactor Vessels, Category B-N-3, Removable Core Support Structures	1992 Edition	2021 Edition
N-888	Similar and Dissimilar Metal Welding Using Ambient Temperature SMAW or Machine GTAW Temper Bead Technique	2001 Edition with the 2003 Addenda	2021 Edition
N-888-1	Similar and Dissimilar Metal Welding Using Ambient Temperature SMAW or Machine GTAW Temper Bead Technique	2001 Edition with the 2003 Addenda	2021 Edition
N-889	Reference Stress Corrosion Crack Growth Rate Curves for Irradiated Austenitic Stainless Steels in Light Water Reactor Environments	1995 Edition	2021 Edition
N-890	Materials Exempted From G-2110(b) Requirement	1986 Edition with the 1987 Addenda	2017 Edition
N-892	Alternative Requirement for Form OAR-1, Owner's Activity Report, Completion Time	1995 Edition	2017 Edition

Code Case No.	Title	Applicability	
		From	Up to and Including
N-892-1	Alternative Requirement for Form OAR-1, Owner's Activity Report, or Inservice Inspection Summary Report	1995 Edition	2017 Edition
N-896	Reference Crack Growth Rate Curves for Stress Corrosion Cracking of Low Alloy Steels in Boiling Water Reactor Environments	1998 Edition	2021 Edition
N-897	Analytical Evaluation Procedures for Axial Flaws in Partial-Penetration Nozzle Welds	2007 Edition	2021 Edition
N-899	Weld Residual Stress Distributions for Piping and Vessel Nozzle Butt Welds Fabricated With UNS N06082, UNS W86182, UNS N06052, or UNS W86152 Weld Filler Metal	1995 Edition	2021 Edition
N-906	Flaw Evaluation Procedure for Cast Austenitic Stainless Steel Piping and Adjacent Fittings	2004 Edition	2021 Edition
N-909	Reference Primary Water Stress Corrosion Crack Growth Rate Curves for Alloy 690 Materials and Associated Weld Materials Alloys 52, 152, and Variant Welds Exposed to Pressurized Water Reactor Environments	2007 Edition with the 2009 Addenda	2021 Edition
N-909-1	Reference Primary Water Stress Corrosion Crack Growth Rate Curves for Alloy 690 Materials and Associated Weld Materials Alloys 52, 152, and Variant Welds Exposed to Pressurized Water Reactor Environments	2007 Edition with the 2009 Addenda	2023 Edition
N-911	Purchase, Exchange, or Transfer of Material Between Nuclear Owners	2004 Edition with the 2006 Addenda	2021 Edition
N-912	Alternative Requirements for Qualification of Material Suppliers and Acceptance of Materials	2007 Edition	2021 Edition
N-913	Alternative Examination Requirements for Class 1 Pressure-Retaining Welds in Control Rod Drive Housings	2007 Edition	2021 Edition
N-917	Fatigue Crack Growth Rate Curves for Ferritic Steels in Boiling Water Reactor (BWR) Environments	1998 Edition	2021 Edition
N-921	Alternative 12-yr Inspection Interval Duration	2007 Edition with the 2008 Addenda	2021 Edition
N-922	Alternative Requirements for Application of Structural Factors to Secondary Stresses for Analytical Evaluation of Flaws in Piping in Accordance With IWB-3644, IWC-3644, or IWD-3644	2004 Edition	2021 Edition
N-923	Mechanical Piping Joints	2001 Edition with the 2003 Addenda	2021 Edition
N-925	Pressure Testing of Class 2 and 3 Items Following Repair or Replacement Activities	2001 Edition with the 2003 Addenda	2021 Edition
N-926	Alternative Examination Requirements for Unbonded Post-Tensioning Systems of Class CC Components	1998 Edition with the 2000 Addenda	2021 Edition
N-930	Alternative Experience Requirements for Nondestructive Examination Personnel for Ultrasonic Examination	2007 Edition	2021 Edition

NOTES:

(1) Applies to the 1974 Edition of Section V.

(2) Applies to the 1974 Edition with the Winter 1976 Addenda of Section V.

(3) Applies to the 1980 Edition of Section V.

GUIDELINE FOR CROSS-REFERENCING SECTION XI CASES

(23)

1 GENERAL

Table 1 applies to Cases listed in the General Note (a) at the bottom of the table. If a Case is not listed in the General Note (a), Table 1 does not apply.

1.1 Purpose. Table 1 provides the user of Cases a tool to identify the appropriate references in a Section XI Edition or Addenda, different from the one on which the Case is based. This allows management of the applicability of various Cases without having to revise the Cases.

1.2 How to Use the Table. Locate the column with the Section XI Edition or Addenda on which the Case is based. Move down that column to the reference in question. Follow that row to the column with the Edition or Addenda on which the Owner's current Section XI program is based. The appropriate reference for the program Edition or Addenda is the intersection of the reference row and the program Edition or Addenda column.

EXAMPLE: Using Case N-666-1. Case N-666-1 references are based on the 2004 Edition; however, the program is based on the 1998 Edition.

To use Table 1 in this situation, first find the column containing the Edition or Addenda on which the Case is based. Case N-666-1 is based on the 2004 Edition. Move down that column to the row containing the reference in question. For this example, use IWA-6300. Move across that row to the column containing the program Edition or Addenda. In this example the program uses 1998 Edition. The reference in the intersection of the row with IWA-6300 and the column for the 1998 Edition is "IWA-6300 and IWA-4180." To use this Case with the 1998 Edition of Section XI, the user would refer to both IWA-6300 and IWA-4180 for requirements.

**Table 1
Cross-Reference List for Section XI Cases (Cont'd)**

	E17-EZ1	E15	E13	E10-E11	A09	A08	E07	A06	A05	E04	A03	A02	E01	A96-A00
A-6300	A-6300	A-6300	A-6300	A-6300	A-6300	A-6300	A-6300	A-6300	A-6300	A-6300	A-6300	A-6300	A-6300	A-6300
A-6350	A-6350	A-6350	A-6350	A-6350	A-6350	A-6350	A-6350	A-6350	A-6350	A-6350	A-6350	A-6350	A-6350	A-6350
B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)	B-2411(b)
...
B-2420(b), (c)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)	B-2420(b)
B-2430	B-2430	B-2430	B-2430	B-2430	B-2430	B-2430	B-2430	B-2430	B-2430	B-2430	B-2430	B-2430	B-2430	B-2430
TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1	TB-2500-1
B-3140	B-3140	B-3140	B-3140	B-3140	B-3140	B-3140	B-3140	B-3140	B-3140	B-3140	B-3140	B-3140	B-3140	B-3140
B-3514	B-3514	B-3514	B-3514	B-3514	B-3514	B-3514	B-3514	B-3514	B-3514	B-3514	B-3514	B-3514	B-3514	B-3514
B-3517	B-3517	B-3517	B-3517	B-3517	B-3517	B-3517	B-3517	B-3517	B-3517	B-3517	B-3517	B-3517	B-3517	B-3517
B-3523	B-3523	B-3523	B-3523	B-3523	B-3523	B-3523	B-3523	B-3523	B-3523	B-3523	B-3523	B-3523	B-3523	B-3523
B-3600	B-3600	B-3600	B-3600	B-3600	B-3600	B-3600	B-3600	B-3600	B-3600	B-3600	B-3600	B-3600	B-3600	B-3600
B-3630	B-3630	B-3630	B-3630	B-3630	B-3630	B-3630	B-3630	B-3630	B-3630	B-3630	B-3630	B-3630	B-3630	B-3630
B-3640	B-3640	B-3640	B-3640	B-3640	B-3640	B-3640	B-3640	B-3640	B-3640	B-3640	B-3640	B-3640	B-3640	B-3640
...
B-5000	B-5000	B-5000	B-5000	B-5000	B-5000	B-5000	B-5000	B-5000	B-5000	B-5000	B-5000	B-5000	B-5000	B-5000
C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)	C-2430(a)(1)(b)
C-3600	C-3600	C-3600	C-3600	C-3600	C-3600	C-3600	C-3600	C-3600	C-3600	C-3600	C-3600	C-3600	C-3600	C-3600
C-3640	C-3640	C-3640	C-3640	C-3640	C-3640	C-3640	C-3640	C-3640	C-3640	C-3640	C-3640	C-3640	C-3640	C-3640
...
D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)	D-2430(a)(1)(b)
D-3600	D-3600	D-3600	D-3600	D-3600	D-3600	D-3600	D-3600	D-3600	D-3600	D-3600	D-3600	D-3600	D-3600	D-3600
D-3640	D-3640	D-3640	D-3640	D-3640	D-3640	D-3640	D-3640	D-3640	D-3640	D-3640	D-3640	D-3640	D-3640	D-3640

Legend:

- A = IWA
- B = IWB
- C = IWC
- D = IWD
- TB = Table IWB

GENERAL NOTES:

- (a) This table is for use with Cases N-532-4, N-561-3, N-561-4, N-562-3, N-562-4, N-576-1, N-576-2, N-609-1, N-638-4 through N-638-11, N-661-3, N-661-4, N-661-5, N-666, N-666-1, N-666-2, N-666-3, N-730, N-730-1, N-733, N-733-1, N-752, N-754-1, N-754-2, N-769, N-769-1, N-769-2, N-771, N-786-1 through N-786-4, N-789-2 through N-789-5, N-829, N-839, N-847, N-847-1, N-853, N-865, N-865-1, N-865-2, N-888, and N-888-1.
- (b) When using Case N-532-4 with Code Editions and Addenda later than the 2005 Addenda, the paragraph references listed in Table 1 shall apply.
- (c) When using Cases N-638-4, N-638-5, N-638-6, N-666, or N-666-1 with Code Editions and Addenda later than the 2004 Edition, the paragraph references listed in Table 1 shall apply.
- (d) When using Cases N-576-1 or N-576-2 with Code Editions and Addenda later than the 2000 Addenda, the paragraph references listed in Table 1 shall apply. Enter Table 1 in the 2000 Addenda column.
- (e) When using Cases N-730, N-730-1, N-769, N-769-1, or N-769-2 with Code Editions and Addenda later than the 2009 Addenda, the paragraph references listed in Table 1 shall apply. Enter Table 1 in the 2009 Addenda column.

Table 1
Cross-Reference List for Section XI Cases (Cont'd)

GENERAL NOTES (CONT'D):

- (f) When using Case N-733 with Code Editions and Addenda later than the 2006 Addenda, the paragraph references listed in Table 1 shall apply. Enter Table 1 in the 2006 Addenda column.
- When using Case N-733-1 with Code Editions and Addenda earlier than the 2007 Edition, the paragraph references listed in Table 1 shall apply. Enter Table 1 in the 2007 Edition column.
- (g) When using Case N-771 with Code Editions and Addenda later than the 2009 Addenda, the paragraph references listed in Table 1 shall apply. Enter Table 1 in the 2009 Addenda column.
- (h) When using Case N-609-1 with Code Editions and Addenda later than the 2005 Addenda, the paragraph references listed in Table 1 shall apply. Enter Table 1 in the 2006 Addenda column.
- (i) When using Cases N-561-3, N-561-4, N-562-3, N-562-4, N-661-4, and N-661-5 with Code Editions and Addenda other than the 2017 Edition, usage of IWA-4670 is limited to the 2013 Edition through the 2017 Edition and usage of IWA-4680 is limited to the 2017 Edition.